

4 機械関係

(1) 機械設備稼働状況

No. 1 (単位:時間)

区分	機器名称	機器番号	25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計	
自家発棟	非常用自家発電機	No.-4	42.8	0.5	0.7	0.6	0.1	0.2	0.1	0.2	0.2	0.1	0.2	0.1	2.0	5.0	47.8	
		No.-3	171.4	0.1	0.1	0.5	0.1	0.1	0.2	0.1	0.2	0.2	0.1	0.2	2.0	3.9	175.3	
第1ポンプ棟	主ポンプ	1号 (J-H-N6)	1,778.5	107.4	89.1	41.5	8.1	44.1	7.3	0.3	0.0	0.0	6.8	2.1	0.0	306.7	2,085.2	
		2号 (J-H-N3)	1,486.4	112.2	76.8	18.9	17.6	37.1	28.6	13.6	8.4	2.4	8.5	6.1	22.0	352.2	1,838.6	
		3号 (J-H-N5)	102,237.4	500.2	578.4	653.3	718.5	681.3	690.9	729.2	706.5	740.8	684.1	659.4	694.8	8,037.4	110,274.8	
		4号 (J-H-N2)	79,690.0	0.0	0.0	192.7	326.9	347.0	217.4	264.2	236.3	390.2	322.7	352.5	400.4	3,050.3	82,740.3	
		5号 インハータ盤	122,755.1	378.8	447.7	352.6	265.6	258.7	353.6	353.7	363.6	233.8	319.4	176.4	210.4	3,714.3	126,469.4	
第1ポンプ棟 し渣設備 (J-C-N1)	し渣スキップホイス	(2G)	1,873.5	-	-	-	-	-	-	-	-	-	-	-	-	0.0	1,873.5	
	細目自動除塵機	No.-1 (3A)	12,404.6	8.4	8.7	8.5	9.0	9.3	8.7	8.8	8.5	8.6	9.5	7.1	9.3	104.4	12,509.0	
		No.-2 (3B)	19,207.1	8.5	8.4	8.3	8.6	9.3	8.6	8.5	8.2	8.5	9.1	7.1	9.2	102.3	19,309.4	
		No.-3 (3C)	19,960.5	8.7	8.6	8.1	9.1	9.0	8.6	8.5	8.3	8.5	9.1	7.4	9.2	103.1	20,063.6	
	し渣破砕機	(3D)	422.1	-	-	-	-	-	-	-	-	-	-	-	-	0.0	422.1	
	し渣脱水機	(3E)	22,851.5	-	-	-	-	-	-	-	-	-	-	-	-	0.0	22,851.5	
	粗目自動除塵機	No.-1 (4A)	502.8	2.4	2.0	1.8	2.0	2.0	1.8	1.8	1.8	1.8	2.0	1.9	1.8	2.0	23.3	526.1
		No.-2 (7C)	452.0	2.1	1.3	1.2	1.1	1.5	1.2	1.1	1.2	1.5	1.4	1.2	1.5	16.3	468.3	
		No.-3 (7E)	472.8	1.9	1.6	1.2	1.3	1.5	1.5	1.4	1.4	1.7	1.4	1.2	1.6	17.7	490.5	
	し渣搬出機	No.-1 (4D)	1,277.0	9.0	6.3	5.1	5.5	5.9	6.6	5.3	5.3	6.2	5.8	5.0	6.3	72.3	1,349.3	
		No.-2 (4E)	1,455.3	9.6	6.7	5.4	5.8	6.4	7.0	5.6	5.7	6.6	6.2	5.3	6.7	77.0	1,532.3	
		No.-3 (4F)	24,300.4	37.7	33.9	32.4	34.9	34.3	32.2	34.1	30.5	33.9	34.1	30.2	35.8	404.0	24,704.4	
		No.-4 (4G)	23,540.6	-	-	-	-	-	-	-	-	-	-	-	-	0.0	23,540.6	
	し渣洗浄攪拌機	(5D)	24,909.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24,909.0	
	予備	(6A)	0.0	-	-	-	-	-	-	-	-	-	-	-	-	0.0	0.0	
沈砂池室床排水ポンプ	No.-1 (6B)	19.6	-	-	-	-	-	-	-	-	-	-	-	-	0.0	19.6		
	No.-2 (6C)	4,088.0	-	-	-	-	-	-	-	-	-	-	-	-	0.0	4,088.0		
	No.-3 (6D)	4,128.5	-	-	-	-	-	-	-	-	-	-	-	-	0.0	4,128.5		

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計	
第1ポンプ棟 沈砂設備 (J-C-N2)	高架水槽揚水ポンプ	No-1 (6E)		4,318.6	18.9	17.8	15.5	16.2	18.8	14.7	15.8	14.5	16.0	17.2	14.6	20.2	200.2	4,518.8	
		No-2 (6F)		4,355.6	18.0	17.2	14.7	15.7	18.0	14.4	15.1	13.9	15.4	16.6	14.5	19.7	193.2	4,548.8	
	沈砂池揚砂ポンプ	No-1 (2A)		1,571.9	4.9	1.9	2.9	4.4	2.6	3.4	3.4	3.3	3.5	2.6	2.7	2.3	37.9	1,609.8	
		No-2 (2B)		1,824.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	1,824.5
		No-3 (2C)		1,525.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	1,525.5
	沈砂洗浄攪拌機	(3A)		5,533.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	5,533.8
	沈砂搬出機	(3D)		6,319.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	6,319.7
沈砂スキップホイス	(3E)		228.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	228.7	
第1ポンプ棟	主ポンプ室床排水ポンプ	No-1 (2E)		6,177.3	48.9	44.7	35.1	35.4	46.3	29.2	32.5	29.5	40.5	42.9	37.9	43.0	465.9	6,643.2	
		No-2 (2F)		5,221.3	32.8	30.1	23.8	23.9	30.8	19.7	22.1	20.1	27.6	28.9	25.4	28.6	313.8	5,535.1	
	主ポンプ冷却水ポンプ	No-1 (2G)		114,058.6	263.2	379.7	269.0	338.7	395.9	384.3	384.2	406.7	399.3	418.5	460.0	218.3	4,317.8	118,376.4	
		No-2 (2H)		105,535.9	455.9	363.5	451.5	405.5	362.2	335.5	359.0	312.8	343.8	326.2	212.1	524.3	4,452.3	109,988.2	
	分配槽床排水ポンプ	No-1 (4D)		7.2	0.1	0.0	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.5	7.7	
		No-2 (4E)		5.2	0.1	0.0	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.5	5.7	
第1送風機棟 送風機設備 (C-C-C)	送風機3相420V	No-1 (2B)		73,221.3	94.5	0.0	0.0	103.3	200.9	120.5	69.7	60.4	145.1	204.4	20.9	178.6	1,198.3	74,419.6	
		No-2 (3B)		63,672.3	177.0	235.0	173.1	162.8	189.4	138.2	73.3	58.5	156.6	265.3	18.3	75.2	1,722.7	65,395.0	
		No-3 (4A)		104,327.9	337.0	337.0	418.1	485.5	381.6	358.9	296.3	384.4	339.9	314.7	403.4	492.0	4,548.8	108,876.7	
	送風機3相6600V	No-4 (C-H-C1)		103,829.5	309.1	255.4	244.3	154.8	118.6	89.4	125.9	157.3	437.2	490.4	325.1	476.2	3,183.7	107,013.2	
		No-5 (C-H-C2)		81,438.0	233.4	263.3	602.2	548.0	587.6	470.0	340.4	393.0	148.4	51.2	166.7	101.9	3,906.1	85,344.1	
		No-6 (C-H-C3)		64,119.3	469.1	301.5	39.3	190.9	144.7	259.4	187.7	16.1	0.2	1.2	32.9	8.5	1,651.5	65,770.8	
	潤滑油ポンプ	No-1 (7B)		111,365.8	161.7	424.5	205.1	598.5	130.8	488.9	117.2	199.8	638.5	361.3	197.2	208.5	3,732.0	115,097.8	
		No-2 (7C)		102,824.7	395.8	183.9	439.8	84.5	526.5	76.5	320.4	283.1	0.0	333.9	278.3	460.7	3,383.4	106,208.1	
		No-3 (9B)		74,369.6	211.2	361.7	162.1	643.7	145.6	619.6	172.1	188.8	158.3	192.0	170.2	72.3	3,097.6	77,467.2	
		No-4 (9C)		71,774.9	493.9	217.0	487.2	96.4	587.4	100.7	370.8	238.1	0.0	25.8	37.7	47.6	2,702.6	74,477.5	
	潤滑油冷却塔	No-1 (7F)		165,413.1	73.3	743.1	646.1	682.9	656.5	564.5	437.6	482.7	638.5	695.0	474.6	679.1	6,773.9	172,187.0	
		No-2 (9F)		105,535.3	73.3	578.7	649.1	739.9	732.9	720.0	542.8	426.7	158.3	59.0	207.7	136.9	5,025.3	110,560.6	
	冷却水ポンプ	No-1 (7D)		184,297.3	557.4	607.9	644.7	682.9	656.5	564.5	437.6	482.4	638.5	695.0	474.6	650.4	7,092.4	191,389.7	
		No-2 (7E)		31,078.0	705.0	578.7	55.4	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.0	44.8	1,384.1	32,462.1	
No-3 (9D)			143,048.7	0.1	0.1	593.8	739.9	732.9	720.0	542.8	426.8	158.3	59.0	207.7	94.4	4,275.8	147,324.5		

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計
第1送風機棟 A系 最初沈殿池設備 (C-C-D1)	汚泥掻寄機	A-1-1	(2E)	19,300.6	720.3	741.1	719.9	744.0	744.0	720.0	741.0	718.5	81.8	2.3	0.0	12.4	5,945.3	25,245.9
		A-1-2	(2F)	34,212.9	215.2	741.1	719.9	744.0	744.0	720.0	740.9	718.5	81.8	2.5	0.0	11.7	5,439.6	39,652.5
		A-2	(2G)	140,543.6	513.7	7.5	9.5	7.3	23.8	2.5	8.4	0.0	329.2	742.2	670.2	744.0	3,058.3	143,601.9
		A-3	(2A)	88,908.7	2.4	1.8	3.0	0.4	23.3	5.1	9.0	12.7	340.0	2.3	378.6	744.0	1,522.6	90,431.3
		A-4	(6B)	43,445.8	209.0	741.1	719.9	744.0	744.0	720.0	740.8	718.5	243.5	742.3	297.2	14.7	6,635.0	50,080.8
		A-5	(6C)	99,914.1	2.5	0.0	2.7	0.0	16.2	8.1	8.5	1.6	4.4	4.4	9.0	14.3	71.7	99,985.8
	A-6	(6D)	69,383.0	2.5	0.0	2.7	2.2	15.7	8.3	8.7	12.9	666.3	742.2	670.3	744.0	2,875.8	72,258.8	
	汚泥引抜ポンプ	A-1	(3E)	8,385.4	122.3	164.3	157.0	160.0	159.4	155.3	163.8	167.7	18.8	0.5	0.0	1.0	1,270.1	9,655.5
		A-2	(3F)	67,131.3	208.7	5.9	155.8	6.6	146.9	12.7	169.2	30.2	351.5	86.8	194.7	67.6	1,436.6	68,567.9
		A-3	(3G)	73,260.2	8.8	158.5	11.9	153.7	26.0	150.9	10.8	128.8	18.5	312.4	181.4	329.7	1,491.4	74,751.6
	スカム移送ポンプ	A-1	(4E)	1,747.9	0.0	0.6	0.6	3.3	0.0	1.7	0.3	0.0	0.0	2.5	0.6	0.5	10.1	1,758.0
		A-2	(4F)	1,596.3	1.9	0.6	0.6	0.0	1.9	0.0	2.3	1.1	0.6	0.3	0.0	0.8	10.1	1,606.4
	沈殿池管廊床排水P	A-1	(3B)	518.3	0.4	0.1	0.5	0.2	0.5	1.6	0.1	0.1	0.4	0.1	0.2	0.0	4.2	522.5
		A-2	(9F)	71.8	0.1	0.2	0.2	0.0	0.1	0.0	0.1	0.1	0.1	0.2	0.0	0.2	1.3	73.1
	送風機管廊床排水ポンプ	No-1	(3C)	121.4	0.2	0.1	0.1	0.1	0.1	0.2	0.1	0.0	0.1	0.0	0.0	0.0	1.0	122.4
		No-2	(3D)	673.0	0.2	0.5	1.0	0.7	0.8	0.3	0.2	0.0	1.2	0.5	0.2	0.5	6.1	679.1
		No-3	(9G)	155.1	0.1	0.4	0.1	0.1	1.0	0.4	0.1	0.1	0.0	0.0	0.4	0.1	2.8	157.9
	第1送風機棟 B系 最初沈殿池設備 (C-C-D2)	汚泥掻寄機	B-1	(F2C)	102,336.8	720.3	743.1	719.7	744.0	744.0	720.0	740.8	718.4	81.2	2.4	5.9	16.6	5,956.4
B-2			(F2D)	94,830.1	2.5	2.8	5.4	7.5	26.7	2.4	7.8	5.1	663.7	741.0	670.3	744.0	2,879.2	97,709.3
B-3			(F2E)	111,713.5	720.3	743.1	719.7	744.0	744.0	720.0	140.8	718.4	79.8	0.0	0.0	11.2	5,341.3	117,054.8
B-4			(F2F)	64,265.0	2.5	3.2	9.1	7.4	23.6	2.4	7.4	3.0	666.6	741.0	670.3	744.0	2,880.5	67,145.5
B-5			(F4E)	77,730.0	720.3	743.1	719.7	744.0	744.0	720.0	740.8	718.4	83.0	1.0	0.0	11.8	5,946.1	83,676.1
B-6			(F4F)	100,111.1	0.0	0.0	0.0	0.3	23.3	3.3	7.4	11.2	663.5	741.0	670.3	744.0	2,864.3	102,975.4
汚泥引抜ポンプ		B-1	(F2A)	82,223.2	15.3	370.5	28.4	371.2	63.1	352.5	27.8	291.1	34.2	312.9	78.8	325.6	2,271.4	84,494.6
		B-2	(F2B)	82,096.9	364.1	13.2	345.1	15.0	327.1	25.1	352.1	62.0	309.3	73.8	270.5	59.8	2,217.1	84,314.0
スカム移送ポンプ		B-1	(R2A)	984.1	0.6	0.4	1.0	1.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.8	4.2	988.3
		B-2	(R2B)	1,127.3	2.2	0.8	0.6	1.0	1.7	1.5	1.6	1.7	0.3	2.0	0.6	0.5	14.5	1,141.8
管廊床排水ポンプ		B-1	(R2E)	110.5	0.2	0.2	0.2	0.3	1.4	0.3	0.2	0.5	0.3	0.4	0.1	0.8	4.9	115.4
		B-2	(R2F)	72.5	0.1	0.1	0.1	0.0	0.1	0.1	0.2	0.0	0.1	0.0	0.0	0.1	0.9	73.4

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計	
第1送風機棟 A系 エアタン設備 (C-C-C2)	A-4エアレータ	A-4-1	(F2A)	148,150.9	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,150.9	
		A-4-2	(F2B)	148,482.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,482.9
		A-4-3	(F2C)	148,623.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,623.8
		A-4-4	(F2D)	147,807.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,807.7
		A-4-5	(F2E)	147,606.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,606.3
		A-4-6	(F2F)	148,092.1	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,092.1
		A-4-7	(F2G)	147,723.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,723.9
		A-4-8	(F2H)	147,175.2	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,175.2
	A-5エアレータ	A-5-1	(F3A)	155,223.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,223.6
		A-5-2	(F3B)	156,674.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,674.5
		A-5-3	(F3C)	156,748.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,748.3
		A-5-4	(F3D)	155,027.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,027.5
		A-5-5	(F3E)	156,772.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,772.9
		A-5-6	(F3F)	156,466.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,466.5
		A-5-7	(F3G)	156,599.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,599.3
		A-5-8	(F3H)	155,889.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,889.5
	A-6エアレータ	A-6-1	(R2A)	155,711.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,711.6
		A-6-2	(R2B)	156,258.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,258.8
		A-6-3	(R2C)	156,152.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,152.6
		A-6-4	(R2D)	154,393.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	154,393.9
		A-6-5	(R2E)	156,679.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,679.6
		A-6-6	(R2F)	155,738.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,738.7
		A-6-7	(R2G)	156,060.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,060.9
		A-6-8	(R2H)	155,251.4	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,251.4
第1送風機棟 B系 エアタン設備 (C-C-C3)	B-1エアレータ	B-1-1	(F2A)	177,194.8	720.3	743.0	720.0	744.0	733.1	720.0	743.9	720.0	744.0	744.0	103.7	526.6	7,962.6	185,157.4	
		B-1-2	(F2B)	177,421.6	720.3	743.0	720.0	744.0	744.0	720.0	743.9	720.0	744.0	744.0	103.7	526.6	7,973.5	185,395.1	
		B-1-3	(F2C)	177,092.1	720.3	743.0	720.0	744.0	744.0	720.0	743.9	720.0	744.0	744.0	103.7	526.6	7,973.5	185,065.6	
		B-1-4	(F2D)	175,665.8	168.6	234.4	720.0	744.0	744.0	720.0	743.9	720.0	744.0	744.0	103.7	526.6	6,913.2	182,579.0	

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計
第1送風機棟 B系 エアタン設備 (C-C-C3)	B-1エアレータ	B-1-5	(F2E)	175,878.2	720.3	508.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.7	1,232.4	177,110.6
		B-1-6	(F2F)	173,763.1	720.3	743.0	720.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,183.3	175,946.4
		B-1-7	(F2G)	177,676.9	720.3	743.0	720.0	744.0	744.0	720.0	743.9	720.0	744.0	744.0	103.7	526.6	7,973.5	185,650.4
		B-1-8	(F2H)	171,709.2	720.3	743.0	720.0	744.0	744.0	720.0	743.9	720.0	744.0	744.0	103.7	526.6	7,973.5	179,682.7
	B-2エアレータ	B-2-1	(F3A)	177,432.5	720.3	743.0	720.0	744.0	733.1	720.0	742.9	162.0	0.0	0.0	573.4	744.0	6,602.7	184,035.2
		B-2-2	(F3B)	172,439.6	720.3	743.0	720.0	744.0	744.0	720.0	743.9	162.0	0.0	0.0	573.1	744.0	6,614.3	179,053.9
		B-2-3	(F3C)	177,648.3	720.3	743.0	720.0	744.0	744.0	720.0	743.9	162.0	0.0	0.0	573.4	744.0	6,614.6	184,262.9
		B-2-4	(F3D)	177,309.6	168.6	234.6	720.0	744.0	744.0	720.0	743.9	162.0	0.0	0.0	22.1	744.0	5,003.2	182,312.8
		B-2-5	(F3E)	177,385.8	720.3	508.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	549.1	0.0	1,777.8	179,163.6
		B-2-6	(F3F)	177,557.2	720.3	743.0	553.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,016.9	179,574.1
		B-2-7	(F3G)	177,641.1	720.3	743.0	720.0	744.0	744.0	667.1	743.9	162.0	0.0	0.0	573.5	744.0	6,561.8	184,202.9
		B-2-8	(F3H)	176,350.5	720.3	743.0	720.0	744.0	744.0	720.0	743.9	162.0	0.0	0.0	573.4	744.0	6,614.6	182,965.1
	B-3エアレータ	B-3-1	(R2A)	186,091.9	720.3	743.0	720.0	744.0	733.1	720.0	743.9	720.0	744.0	744.0	672.0	744.0	8,748.3	194,840.2
		B-3-2	(R2B)	185,848.2	719.8	742.2	720.0	744.0	744.0	720.0	743.9	720.0	744.0	744.0	649.1	510.7	8,501.7	194,349.9
		B-3-3	(R2C)	178,552.8	0.0	0.0	476.8	744.0	744.0	720.0	743.9	720.0	744.0	744.0	672.0	744.0	7,052.7	185,605.5
		B-3-4	(R2D)	180,296.1	720.3	743.0	720.0	744.0	744.0	720.0	743.9	720.0	744.0	659.7	672.0	744.0	8,674.9	188,971.0
		B-3-5	(R2E)	185,311.1	720.3	743.0	268.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,731.6	187,042.7
		B-3-6	(R2F)	185,646.1	720.3	743.0	720.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,183.3	187,829.4
		B-3-7	(R2G)	183,668.5	720.3	743.0	720.0	744.0	744.0	720.0	743.9	720.0	744.0	744.0	672.0	744.0	8,759.2	192,427.7
		B-3-8	(R2H)	184,554.3	720.3	743.0	720.0	744.0	744.0	720.0	743.9	720.0	744.0	744.0	672.0	744.0	8,759.2	193,313.5
	B-4エアレータ	B-4-1	(F4A)	163,870.5	720.4	743.0	720.0	744.0	733.1	720.0	738.7	720.0	744.0	744.0	672.0	744.0	8,743.2	172,613.7
		B-4-2	(F4B)	162,229.8	720.4	743.0	720.0	744.0	744.0	720.0	739.8	720.0	744.0	728.0	672.0	744.0	8,739.2	170,969.0
		B-4-3	(F4C)	163,999.5	720.4	743.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	738.2	672.0	744.0	8,753.6	172,753.1
		B-4-4	(F4D)	163,208.1	720.4	743.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.4	171,967.5
		B-4-5	(F4E)	162,582.3	720.4	743.0	720.0	744.0	713.8	720.0	744.0	720.0	744.0	744.0	672.0	384.9	8,370.1	170,952.4
		B-4-6	(F4F)	163,416.6	720.4	743.0	720.0	744.0	713.8	720.0	744.0	720.0	744.0	744.0	672.0	740.0	8,725.2	172,141.8
		B-4-7	(F4G)	157,783.6	720.4	743.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	740.0	8,755.4	166,539.0
		B-4-8	(F4H)	163,303.7	720.4	743.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	740.0	8,755.4	172,059.1

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計	
第1送風機棟 B系 エアタン設備 (C-C-C3)	B-5エアレータ	B-5-1	(F5A)	164,106.1	720.4	743.0	720.0	744.0	733.1	720.0	739.6	141.0	0.0	0.0	0.0	694.0	5,955.1	170,061.2	
		B-5-2	(F5B)	163,885.5	720.4	743.0	720.0	744.0	744.0	720.0	744.0	141.0	0.0	0.0	0.0	694.0	5,970.4	169,855.9	
		B-5-3	(F5C)	163,163.8	720.4	743.0	720.0	744.0	744.0	720.0	744.0	141.0	0.0	0.0	0.0	694.0	5,970.4	169,134.2	
		B-5-4	(F5D)	164,157.0	720.4	743.0	720.0	744.0	744.0	720.0	744.0	141.0	0.0	0.0	0.0	694.0	5,970.4	170,127.4	
		B-5-5	(F5E)	163,456.2	720.4	743.0	720.0	744.0	713.8	720.0	744.0	141.0	0.0	0.0	0.0	335.5	5,581.7	169,037.9	
		B-5-6	(F5F)	163,512.0	720.4	743.0	622.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	667.8	2,754.1	166,266.1
		B-5-7	(F5G)	163,543.0	720.4	743.0	720.0	744.0	744.0	720.0	744.0	141.0	0.0	0.0	0.0	694.0	5,970.4	169,513.4	
		B-5-8	(F5H)	162,022.8	720.4	743.0	720.0	744.0	744.0	720.0	744.0	141.0	0.0	0.0	0.0	694.0	5,970.4	167,993.2	
	B-6エアレータ	B-6-1	(R4A)	163,657.5	720.4	743.0	720.0	744.0	733.1	720.0	744.0	720.0	744.0	730.8	660.8	744.0	8,724.1	172,381.6	
		B-6-2	(R4B)	157,636.0	720.4	743.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.4	166,395.4	
		B-6-3	(R4C)	164,069.2	720.4	743.0	720.0	744.0	744.0	720.0	742.2	720.0	744.0	744.0	672.0	744.0	8,757.6	172,826.8	
		B-6-4	(R4D)	163,695.7	720.4	743.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.4	172,455.1	
		B-6-5	(R4E)	162,270.7	720.4	743.0	720.0	744.0	714.0	720.0	744.0	720.0	744.0	744.0	672.0	384.7	8,370.1	170,640.8	
		B-6-6	(R4F)	164,102.5	720.4	743.0	720.0	744.0	714.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,729.4	172,831.9	
		B-6-7	(R4G)	162,738.1	720.4	743.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.4	171,497.5	
		B-6-8	(R4H)	163,150.1	720.4	743.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.4	171,909.5	
	エアタン管廊床 排水ポンプ	B-1	(R3A)	232.6	0.2	0.3	0.4	0.3	2.2	0.4	0.4	0.2	0.2	0.2	0.0	0.5	5.3	237.9	
		B-2	(R3B)	149.8	0.2	0.3	0.2	0.3	2.2	0.4	0.4	0.2	0.2	0.2	0.1	0.7	5.4	155.2	
第1送風機棟 A系 最終沈殿池設備 (C-C-E1)	汚泥掻寄機	A-1-1	(2A)	233,635.2	718.0	738.5	719.5	739.5	742.4	719.2	743.0	718.0	742.1	741.3	672.0	742.0	8,735.5	242,370.7	
		A-1-2	(2B)	236,628.4	715.1	738.5	719.3	737.2	741.8	718.8	742.8	709.2	695.5	682.1	622.5	724.4	8,547.2	245,175.6	
		A-2	(2C)	232,494.2	696.0	738.5	719.5	738.6	742.2	718.8	742.8	718.0	742.8	741.4	672.0	742.0	8,712.6	241,206.8	
		A-3	(6B)	223,525.9	718.4	738.5	719.9	739.5	743.1	719.4	743.5	718.2	739.1	740.8	663.7	736.4	8,720.5	232,246.4	
		A-4	(7B)	161,772.1	718.7	739.1	720.0	739.3	742.9	719.4	743.3	718.3	741.7	741.2	220.5	11.1	7,555.5	169,327.6	
		A-5	(7C)	166,564.3	718.9	739.1	720.0	739.5	743.1	719.6	743.5	718.6	743.8	738.5	672.0	742.3	8,738.9	175,303.2	
		A-6	(7D)	167,956.0	718.8	739.1	720.0	739.4	743.1	719.6	743.5	718.5	743.7	741.7	672.0	742.3	8,741.7	176,697.7	

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計	
第1送風機棟 A系 最終沈殿池設備 (C-C-E1)	返送汚泥ポンプ	A-1	(3A)	134,338.7	12.9	5.0	7.4	739.8	441.1	47.6	16.7	596.1	78.3	17.4	523.3	75.8	2,561.4	136,900.1	
		A-2	(3B)	162,509.3	34.9	713.8	52.6	43.7	219.3	672.3	52.6	0.0	642.4	159.4	449.1	157.9	3,198.0	165,707.3	
		A-3	(3C)	166,241.6	691.7	54.1	670.5	360.6	217.4	28.1	691.4	138.1	30.1	595.3	149.4	633.3	4,260.0	170,501.6	
		A-4	(9E)	158,357.7	720.3	742.9	720.0	740.3	744.0	720.0	744.0	719.2	744.0	741.9	672.0	742.3	8,750.9	167,108.6	
		A-5	(9F)	151,367.7	720.3	742.9	720.0	740.3	744.0	720.0	744.0	719.2	744.0	741.9	672.0	742.5	8,751.1	160,118.8	
	スカム分離機	A-1	(2D)	52,409.9	98.9	79.5	72.1	73.9	78.8	67.0	58.5	55.2	63.3	67.4	88.3	63.2	866.1	53,276.0	
	スカム移送ポンプ	A-1	(2E)	24,423.7	3.6	70.6	5.0	67.3	1.8	59.7	3.7	44.1	62.1	13.8	75.4	61.3	468.4	24,892.1	
		A-2	(2F)	24,654.8	92.8	7.1	65.2	2.6	74.9	4.9	52.0	9.5	0.0	50.0	11.7	0.0	370.7	25,025.5	
	余剰汚泥ポンプ	A-1	(4B)	40,131.2	6.7	115.5	8.9	132.4	23.9	88.8	9.1	98.6	11.4	91.2	25.8	153.0	765.3	40,896.5	
		A-2	(4C)	42,981.0	114.4	5.0	65.3	2.1	69.2	4.2	93.3	14.3	99.2	16.7	103.8	23.5	611.0	43,592.0	
		A-3	(9C)	15,180.4	5.7	81.7	5.1	122.9	21.3	104.6	8.1	95.1	13.3	101.6	30.1	69.9	659.4	15,839.8	
		A-4	(9D)	14,973.9	80.7	3.2	94.6	4.1	102.1	7.6	109.2	19.5	113.7	25.3	47.2	0.0	607.2	15,581.1	
	消泡水ポンプ	A-1	(5C)	102,992.6	7.4	173.7	16.1	146.2	161.1	11.9	0.8	0.0	0.0	0.0	0.0	120.0	637.2	103,629.8	
		A-2	(5D)	115,425.2	177.7	6.4	162.9	22.9	7.3	162.7	184.4	185.0	191.8	188.9	172.4	66.3	1,528.7	116,953.9	
	管廊床排水ポンプ	管理棟	(4E)	949.3	0.2	0.2	0.9	0.2	0.7	0.1	0.2	0.1	0.2	0.1	0.0	0.3	3.2	952.5	
		終沈A-1	(4F)	765.4	1.4	0.5	0.7	10.6	1.0	0.6	0.6	0.5	0.5	0.2	0.4	0.1	17.1	782.5	
		終沈A-2	(9B)	287.3	0.3	0.8	0.3	0.2	0.3	0.1	0.3	0.0	0.2	0.3	1.3	0.0	4.1	291.4	
		濃縮A-1	(4G)	180.1	1.1	1.2	0.8	0.6	0.2	0.5	0.2	0.0	0.0	0.0	0.0	0.0	4.6	184.7	
		濃縮A-2	(4H)	1,061.4	1.2	0.9	0.6	0.5	0.2	1.2	14.3	4.8	1.0	0.6	0.7	1.9	27.9	1,089.3	
	放流水消毒設備	A系次亜塩注入ポンプ	No-1		40,053.7	-	-	-	-	-	-	-	-	-	-	-	-	0.0	40,053.7
No-2				63,307.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	63,307.6
No-3				66,540.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	66,540.3
B系次亜塩注入ポンプ		No-4		51,686.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	51,686.8
		No-5		39,011.2	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	39,011.2
		No-6		44,626.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	44,626.5

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計
第1送風機棟 B系 最終沈殿池設備 (C-C-E2)	汚泥掻寄機	B-1	(F2B)	183,989.6	718.2	738.5	719.7	739.1	742.7	719.2	743.3	718.3	743.1	741.6	672.0	742.4	8,738.1	192,727.7
		B-2	(F2C)	185,935.3	718.5	738.5	719.7	738.6	742.7	719.2	743.2	718.2	743.5	741.6	672.0	742.4	8,738.1	194,673.4
		B-3	(F2D)	185,660.1	718.8	738.5	719.8	739.3	743.1	719.2	743.7	718.6	743.7	741.9	672.0	742.4	8,741.0	194,401.1
		B-4	(F4B)	162,237.0	718.6	738.5	719.9	739.2	742.7	719.4	743.5	718.5	743.7	741.8	672.0	742.4	8,740.2	170,977.2
		B-5	(F4C)	162,554.8	718.0	738.5	719.2	739.2	743.1	719.4	743.4	718.5	743.7	741.8	672.0	742.4	8,739.2	171,294.0
		B-6	(F4D)	162,492.2	720.3	738.5	719.2	739.1	742.9	719.4	743.3	718.3	743.7	741.8	672.0	742.4	8,740.9	171,233.1
	返送汚泥ポンプ	B-1	(F2E)	181,282.9	720.3	742.0	719.2	740.3	744.0	720.0	744.0	719.2	744.0	741.6	672.0	742.5	8,749.1	190,032.0
		B-2	(F2F)	175,239.0	720.3	742.0	719.2	740.3	744.0	720.0	744.0	719.2	744.0	742.0	672.0	741.9	8,748.9	183,987.9
		B-3	(F4E)	160,306.1	720.3	742.0	719.2	740.3	744.0	720.0	744.0	719.2	744.0	742.0	672.0	742.3	8,749.3	169,055.4
		B-4	(F4F)	157,165.0	720.3	742.0	719.2	740.3	744.0	720.0	744.0	719.2	744.0	742.0	672.0	742.3	8,749.3	165,914.3
	余剰汚泥ポンプ	B-1	(F3B)	22,504.6	5.4	123.3	8.6	131.1	28.2	126.5	10.9	133.4	17.3	138.0	27.6	119.0	869.3	23,373.9
		B-2	(F3C)	25,947.1	136.5	5.1	139.7	4.9	137.5	9.0	179.8	32.0	147.0	34.8	112.7	26.3	965.3	26,912.4
	消泡水ポンプ	B-1	(F3E)	68,329.6	173.6	193.5	170.7	168.1	165.8	173.6	200.4	183.1	193.7	181.5	165.2	182.1	2,151.3	70,480.9
		B-2	(F3F)	67,017.2	1.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.4	67,018.6
	スカム移送ポンプ	B-1	(R2A)	33,450.5	14.2	329.4	22.1	339.0	5.9	333.2	25.9	303.4	376.0	75.2	305.7	294.0	2,424.0	35,874.5
		B-2	(R2B)	38,177.7	326.6	12.5	317.8	12.0	371.0	27.2	350.9	65.9	0.0	392.4	86.2	0.2	1,962.7	40,140.4
	スカム分離機	B-1	(R2E)	66,501.0	315.6	312.7	313.5	328.8	361.3	341.1	358.3	343.8	350.0	342.0	373.7	266.2	4,007.0	70,508.0
	管廊床排水ポンプ	B-1	(R2G)	136.2	0.1	0.4	0.2	0.2	1.2	0.2	0.1	0.1	0.1	0.1	0.0	0.3	3.0	139.2
		B-2	(R2H)	308.8	1.1	0.4	0.2	0.1	0.5	0.1	0.1	0.2	0.1	0.1	0.0	0.2	3.1	311.9
	井水棟設備	深井戸揚水ポンプ	No.-1		78,524.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
No.-2				50,224.0	34.5	156.7	136.7	93.9	215.3	264.5	48.9	43.0	44.2	43.8	39.9	41.6	1,163.0	51,387.0
No.-3				42,247.0	24.3	75.4	549.3	494.6	271.4	299.5	31.5	29.7	30.1	30.2	25.8	29.0	1,890.8	44,137.8
送水ポンプ		No.-1		97,009.8	239.7	240.4	238.5	256.1	271.2	236.5	264.7	288.5	196.0	267.3	210.6	262.2	2,971.7	99,981.5
		No.-2		100,961.4	268.0	263.9	241.5	191.3	234.2	221.9	239.1	240.0	420.1	236.4	232.7	480.0	3,269.1	104,230.5
		No.-3		90,763.8	212.8	239.0	244.2	292.6	240.8	259.3	240.2	190.8	120.0	237.4	232.3	0.3	2,509.7	93,273.5
次亜塩注入ポンプ		No.-1		36,068.0	9.9	11.5	10.8	10.0	10.0	9.5	10.4	10.0	15.7	13.2	8.5	8.7	128.2	36,196.2
		No.-2		20,091.9	9.0	10.0	8.8	9.3	10.3	10.8	9.6	11.7	5.9	8.4	10.9	9.1	113.8	20,205.7
		No.-3		20,074.7	8.5	8.8	10.3	10.9	10.1	9.7	12.2	8.2	8.3	8.5	7.0	11.0	113.5	20,188.2

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計
井水棟設備	急速ろ過器逆洗ポンプ	No-1		846.5	0.5	0.4	0.8	0.2	0.5	0.3	0.5	0.2	0.0	0.2	0.2	0.2	4.0	850.5
		No-2		572.5	0.3	0.5	0.5	0.5	0.3	1.0	0.9	0.7	0.5	0.5	0.5	0.5	0.5	6.7
	急速ろ過器	No-1		47,183.1	14.1	16.3	14.3	14.1	14.2	14.4	14.5	14.4	17.9	16.5	13.9	13.3	177.9	47,361.0
		No-2		31,291.3	13.1	13.7	14.9	15.1	15.4	15.8	17.8	15.3	12.1	13.7	11.9	15.7	174.5	31,465.8
A・B 系重力濃縮設備 (F-C-P1)	し渣破碎機	A-1	(5D)	32,805.0	61.1	0.0	0.0	338.7	75.8	0.0	0.0	290.4	68.0	311.8	413.6	221.9	1,781.3	34,586.3
		A-2	(5C)	28,392.4	410.5	464.5	459.0	117.8	410.9	465.9	508.0	195.8	446.3	131.1	1.2	207.7	3,818.7	32,211.1
	濃縮汚泥掻寄機	A-1	(2C)	203,317.9	717.0	740.5	720.0	737.7	741.9	716.1	739.3	711.8	739.7	741.0	670.8	737.4	8,713.2	212,031.1
		A-2	(3C)	175,730.9	716.6	740.0	720.0	736.5	741.9	716.1	739.3	711.8	739.7	741.0	670.8	737.4	8,711.1	184,442.0
	濃縮汚泥引抜ポンプ	A-1	(2E)	29,216.9	66.5	207.0	64.5	187.8	10.3	176.9	8.1	42.5	90.6	263.1	126.7	198.2	1,442.2	30,659.1
		A-2	(2F)	31,372.9	193.6	71.7	172.8	58.3	175.8	25.7	191.1	146.7	156.9	90.4	153.9	44.5	1,481.4	32,854.3
	床排水ポンプ	A系	(2G)	3,013.0	14.5	15.6	19.9	18.6	21.6	14.0	0.0	29.6	15.6	22.1	13.6	16.3	201.4	3,214.4
	汚泥分離機	B-1	(3B)	16,071.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16,071.6
	し渣脱水機	B-1	(3H)	16,481.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16,481.5
	濃縮汚泥掻寄機	B-1	(4A)	124,762.4	713.7	740.6	717.0	733.3	740.8	716.4	711.7	702.1	740.1	681.1	608.6	551.7	8,357.1	133,119.5
		B-2	(4B)	96,396.8	716.5	736.3	720.0	729.5	741.4	691.3	726.1	682.2	332.6	714.2	608.6	423.8	7,822.5	104,219.3
	濃縮汚泥引抜ポンプ	B-1	(4D)	3.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.6
し渣破碎機	B-1	(5E)	52,862.4	416.7	422.8	408.8	411.9	417.0	400.5	419.6	418.0	472.3	526.4	482.6	525.3	5,321.9	58,184.3	
C系 重力濃縮設備 (F2-C-P1)	濃縮汚泥引抜ポンプ	C-1	(F1C)	1,926.9	2.9	81.7	6.0	109.0	4.1	94.9	2.8	82.6	5.9	76.0	5.3	74.8	546.0	2,472.9
		C-2	(F1D)	1,851.7	82.1	3.3	89.3	3.0	111.9	3.6	100.6	6.5	72.7	5.6	67.6	5.3	551.5	2,403.2
	床排水ポンプ	No. 1	(R1E)	336.6	2.0	7.6	6.4	36.7	23.4	8.5	15.3	12.9	12.4	4.2	1.9	2.6	133.9	470.5
		No. 2	(R1F)	347.9	5.1	7.8	23.8	8.6	62.0	8.3	15.2	12.9	12.5	4.2	1.9	2.6	164.9	512.8
A系 ベルト濃縮設備	A系汚泥スクリーン		(2A)	81,845.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	81,845.5
	余剰汚泥供給ポンプ	No. 1	CRT	18,014.4	13.7	727.4	40.4	734.3	13.7	661.3	10.5	686.4	34.8	637.6	504.7	740.5	4,805.3	22,819.7
		No. 2	CRT	16,667.7	706.1	13.9	677.5	9.7	715.7	57.7	730.7	33.6	704.7	105.1	163.6	0.0	3,918.3	20,586.0
	濃縮汚泥移送ポンプ	No. 1	CRT	2,759.9	60.3	67.0	68.6	64.7	67.7	62.6	71.5	66.4	75.4	63.2	86.4	107.6	861.4	3,621.3
No. 2		CRT	1,783.4	41.1	49.2	49.7	47.0	49.8	47.8	47.9	42.4	47.8	47.6	13.1	0.1	483.5	2,266.9	

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計
A系 ベルト濃縮設備	高分子凝集剤 定量供給機	No. 1	CRT	634.4	14.8	14.2	13.9	12.2	11.6	11.4	15.0	14.2	17.5	16.1	15.2	15.6	171.7	806.1
		No. 2	CRT	634.3	14.8	14.0	14.2	12.0	11.7	11.6	15.0	14.2	17.4	16.1	15.0	15.4	171.4	805.7
	高分子凝集剤 供給ポンプ	No. 1	CRT	17,286.9	13.8	727.3	40.2	734.1	13.8	708.4	11.1	686.3	37.4	637.5	504.7	740.5	4,855.1	22,142.0
		No. 2	CRT	18,101.7	706.0	14.0	677.7	9.9	715.6	10.6	730.1	33.7	702.1	105.2	163.6	0.0	3,868.5	21,970.2
	濃縮用空気圧縮機	No. 1	CRT	3,359.4	72.4	69.9	63.4	68.0	64.1	61.4	65.1	61.7	62.6	68.1	58.7	67.5	782.9	4,142.3
		No. 2	CRT	3,316.6	69.4	68.8	66.9	65.9	65.7	66.0	65.0	61.0	68.7	63.7	59.1	63.9	784.1	4,100.7
	補機室床排水ポンプ	A-1	(5B)	923.7	0.0	1.4	2.8	1.6	3.9	1.6	3.0	1.8	2.2	2.4	2.1	2.4	25.2	948.9
		A-2	(5C)	626.3	0.0	1.4	2.4	1.6	3.8	1.6	1.9	1.1	1.7	2.5	2.1	2.2	22.3	648.6
B系 加圧浮上 濃縮設備 (F-C-J1)	余剰汚泥供給ポンプ	B-1	(F5A)	89,032.9	552.3	455.2	328.0	312.9	723.7	366.9	739.0	422.4	99.8	550.9	669.5	739.9	5,960.5	94,993.4
		B-2	(F6A)	48,251.9	334.6	0.0	318.8	427.1	0.6	165.6	312.2	0.0	666.7	194.5	73.2	643.5	3,136.8	51,388.7
		B-3	(F7A)	80,523.4	330.2	572.8	552.8	744.0	527.6	186.9	21.0	473.0	718.5	738.0	597.2	96.4	5,558.4	86,081.8
	加圧水循環ポンプ	B-1	(R2C)	87,709.6	181.2	77.4	108.9	312.9	723.7	366.9	595.0	422.5	53.4	550.9	669.5	739.9	4,802.2	92,511.8
		B-2	(R3C)	49,678.6	334.7	0.0	318.0	427.2	0.6	165.6	112.2	0.0	690.7	191.3	0.0	643.4	2,883.7	52,562.3
		B-3	(R4C)	79,935.5	330.1	572.8	552.9	744.0	527.6	186.8	20.7	472.8	741.0	741.2	670.3	96.5	5,656.7	85,592.2
	濃縮用空気圧縮機	B-1	(F3G)	10,132.1	26.1	713.6	53.7	721.7	29.0	719.3	21.1	669.2	51.9	694.2	52.7	691.1	4,443.6	14,575.7
		B-2	(F3H)	13,752.7	693.4	26.3	662.6	18.2	684.8	0.0	328.4	46.1	690.9	49.0	617.8	48.8	3,866.3	17,619.0
	沈殿汚泥揺寄機	B-1	(F4D)	124,303.6	720.0	743.4	720.0	740.0	744.0	719.4	742.5	715.4	744.0	744.0	672.0	741.5	8,746.2	133,049.8
		B-2	(F4F)	99,900.4	720.0	743.4	720.0	740.0	744.0	719.4	742.5	715.4	744.0	744.0	672.0	741.5	8,746.2	108,646.6
	フロス移送ポンプ	B-1	(F3B)	8,198.3	7.4	77.9	5.5	84.8	3.4	61.7	2.7	83.3	8.1	93.4	7.5	113.5	549.2	8,747.5
		B-2	(F3C)	8,490.5	81.1	3.1	72.2	1.8	71.2	1.9	78.4	5.2	122.5	17.8	98.1	8.2	561.5	9,052.0
	A系汚泥スクリーン		(F3E)	7,890.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7,890.8
	沈殿汚泥引抜ポンプ		(F3F)	46.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	46.2
	補機室床排水ポンプ	B-1	(F2E)	574.7	0.7	17.4	1.4	19.3	0.5	16.7	0.6	18.8	1.2	16.7	1.3	17.9	112.5	687.2
		B-2	(F2F)	646.0	16.5	7.0	17.4	0.5	16.6	0.4	17.6	1.1	29.0	1.2	15.0	1.2	123.5	769.5
消化タンク設備 (L-C-Q1)	消化タンク攪拌機	A-1	(F3C)	201,408.4	720.9	715.4	717.6	722.3	684.4	712.0	731.1	711.6	742.4	730.4	672.0	721.4	8,581.5	209,989.9
		A-2	(F3D)	40,047.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	40,047.5
		A-3	(F3E)	156,716.9	720.9	727.7	720.0	729.3	723.5	709.9	741.4	710.7	742.6	739.8	672.0	739.3	8,677.1	165,394.0
		A-4	(F4G)	114,406.0	719.7	727.7	714.2	730.2	723.6	182.6	738.7	711.6	742.8	478.3	49.0	723.8	7,242.2	121,648.2

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計	
消化タンク設備 (L-C-Q1)	消化管廊床排水ポンプ	No-1	(F2E)	126.3	23.4	20.2	0.1	0.0	0.0	0.2	0.0	0.0	0.1	0.1	0.1	0.2	44.4	170.7	
		No-2	(F2F)	177.4	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.3	0.6	0.0	0.0	0.0	0.0	1.4	178.8
	雑用水加圧ポンプ	No-1	(F3B)	495.7	0.0	0.0	0.0	0.0	0.0	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.1	496.8
	循環汚泥ポンプ	A-1	(R3C)	143,592.5	717.2	476.9	291.3	721.3	712.0	419.3	361.1	710.7	737.2	169.0	595.5	736.3	6,647.8	150,240.3	
		A-2	(R3D)	2,978.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,978.2
		A-3	(R2C)	119,814.9	717.2	472.5	417.3	320.3	712.3	710.9	350.3	402.6	737.2	738.4	504.2	737.7	6,820.9	126,635.8	
		A-4	(R2D)	115,094.4	406.9	247.6	708.3	721.1	421.4	291.0	742.1	710.4	241.7	569.2	663.0	699.3	6,422.0	121,516.4	
A-5		(F3C)	89,063.8	290.5	744.0	708.6	401.0	292.9	697.1	741.1	308.1	495.3	732.2	232.8	0.6	5,644.2	94,708.0		
A系ボイラー設備 (L-C-R1)	重油移送ポンプ	No-1	(F3G)	12.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	12.7	
		No-2	(F3H)	12.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	12.5	
	消化用空気圧縮機	No-1	(F2C)	3,452.3	1.1	29.5	2.0	29.0	1.5	32.4	0.9	104.2	5.7	171.3	10.4	100.5	488.5	3,940.8	
		No-2	(F2D)	3,383.5	29.1	1.4	26.7	0.9	33.3	1.1	46.8	4.1	310.1	24.0	135.9	4.0	617.4	4,000.9	
	床排水ポンプ		(F2E)	10,385.5	0.8	0.7	0.7	0.8	1.1	2.1	1.7	0.3	0.7	0.7	0.0	1.3	10.9	10,396.4	
	管廊床排水ポンプ		(F2F)	130.1	0.1	0.1	0.1	0.2	0.0	0.2	0.7	0.0	0.0	0.2	0.0	0.1	1.7	131.8	
	A-1 温水ボイラー制御盤	抽気時間		100.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	100.9
		オイル燃焼時間		1,166.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.1	1,166.9
		ガス燃焼時間		159,474.5	0.0	0.0	0.0	299.8	375.6	707.4	728.2	712.8	730.6	694.9	668.5	734.0	5,651.8	165,126.3	
		抽気時間		12.1	0.1	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.6	12.7	
		オイル燃焼時間		6.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.1	6.2	
ガス燃焼時間			48,830.0	715.6	723.5	707.4	502.5	311.3	5.3	296.4	645.0	448.8	496.4	400.1	480.4	5,732.7	54,562.7		
余剰ガス 燃焼装置	電気室電源盤内	燃焼時間	46,371.4	0.3	0.3	0.7	1.0	0.3	0.3	0.3	0.3	0.3	0.2	0.3	0.3	0.3	4.6	46,376.0	
	ボイラー設備盤 R22A内取付	ガス燃焼用送風機		47,946.4	0.6	0.7	0.7	0.7	0.8	0.5	0.5	0.6	0.6	0.7	0.5	0.5	7.4	47,953.8	
		ガス昇圧	No-1-1	23,375.9	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	2.4	23,378.3	
		ブロウ	No-1-2	23,546.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	2.4	23,548.7	
脱水機設備 (H-C-K1)	脱水用空気圧縮機	A-1	(2A)	44,534.5	390.2	14.5	319.5	378.7	14.1	304.2	376.7	20.4	0.2	311.1	29.3	337.4	2,496.3	47,030.8	
		A-2	(2B)	41,285.8	376.1	381.9	25.7	371.8	390.0	30.0	366.7	333.3	356.3	369.1	342.3	24.0	3,367.2	44,653.0	
		A-3	(10C)	39,012.6	14.5	367.6	345.0	7.0	376.2	334.1	6.0	312.9	356.3	58.0	313.0	362.2	2,852.8	41,865.4	
		B-1	(F5E)	720.2	6.1	6.5	6.1	6.4	6.7	7.0	7.1	6.4	6.7	6.0	5.4	6.6	77.0	797.2	
		B-2	(F5F)	871.6	6.1	6.5	6.1	6.4	6.7	7.0	7.1	6.4	6.7	6.0	5.4	6.6	77.0	948.6	

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計
脱水機設備 (H-C-K1)	補機室床排水ポンプ	A-1	(2E)	209.2	0.3	0.5	0.5	0.3	0.5	0.2	0.3	0.1	0.3	0.2	0.1	0.4	3.7	212.9
		A-2	(2F)	189.6	0.3	0.5	0.5	0.3	0.5	0.2	0.2	0.1	0.2	0.2	0.1	0.3	3.4	193.0
		A-3	(2G)	2,683.5	54.5	49.6	32.4	18.5	13.5	12.2	13.7	11.3	12.1	8.1	6.0	7.7	239.6	2,923.1
		B-1	(R5B)	49.6	0.0	0.2	0.0	0.2	0.0	0.0	0.0	0.1	0.0	0.0	0.0	1.6	2.1	51.7
		B-2	(R5C)	49.1	0.3	0.0	0.4	0.0	0.3	0.0	0.2	0.0	0.1	0.1	0.1	0.5	0.1	2.0
	ろ布洗浄ポンプ	A-1	(3C)	51,700.3	341.6	6.9	287.0	346.5	6.8	285.8	320.8	15.0	0.0	250.5	333.6	608.3	2,802.8	54,503.1
		A-2	(3D)	50,392.3	323.1	316.5	22.0	281.5	361.9	23.4	314.8	293.8	334.7	338.1	331.7	20.1	2,961.6	53,353.9
		A-3	(10F)	41,142.9	18.5	306.9	317.8	63.7	346.9	314.9	3.8	278.8	332.4	65.5	0.1	0.0	2,049.3	43,192.2
		B-1	(R4C)	5,531.0	0.0	7.4	0.0	6.6	0.1	11.8	0.0	5.7	0.0	9.8	0.0	1.8	43.2	5,574.2
		B-2	(R4D)	6,319.6	8.5	0.1	9.3	2.7	8.8	8.8	5.1	0.0	7.3	0.0	1.8	0.0	52.4	6,372.0
	ろ布駆動装置	A-1	(5B)	72,881.4	332.3	314.0	310.8	344.5	290.4	313.6	315.9	293.0	330.9	338.5	330.5	407.1	3,921.5	76,802.9
		A-2	(6B)	64,995.5	328.6	314.0	309.2	345.2	355.4	309.3	266.0	287.1	332.1	339.0	331.5	395.6	3,913.0	68,908.5
		A-3	(7C)	57,582.0	321.6	315.9	309.9	345.3	355.9	309.5	318.9	290.9	332.0	339.5	332.2	398.0	3,969.6	61,551.6
		A-4	(8C)	58,170.4	331.2	314.8	311.4	343.4	353.3	312.2	318.7	289.7	332.3	317.3	331.7	223.8	3,779.8	61,950.2
		A-5	(R2F)	43,175.4	330.9	316.4	310.2	346.6	356.1	314.0	318.7	284.2	332.8	317.2	321.6	219.4	3,768.1	46,943.5
		A-6	(F2D)	37,697.9	328.8	311.4	304.8	341.1	345.9	306.8	312.4	279.9	71.1	0.0	0.0	214.0	2,816.2	40,514.1
		B-1	(F4A)	11,728.8	8.6	16.0	9.3	8.1	8.8	20.5	5.1	5.7	7.3	9.8	1.8	1.8	102.8	11,831.6
	脱水汚泥供給ポンプ	A-1	(5E)	63,948.0	302.8	385.3	278.5	315.7	261.2	278.4	286.5	259.7	301.1	310.0	304.3	365.8	3,649.3	67,597.3
		A-2	(6E)	57,344.6	298.6	384.7	279.4	315.5	325.3	281.7	235.2	259.7	302.6	310.0	303.3	361.9	3,657.9	61,002.5
		A-3	(7D)	50,732.9	279.8	286.9	279.3	314.7	324.9	281.7	289.8	258.1	292.9	307.7	305.7	359.5	3,581.0	54,313.9
		A-4	(8D)	51,704.6	301.5	284.7	279.6	313.6	323.8	284.2	289.8	261.1	292.9	287.4	305.7	207.0	3,431.3	55,135.9
		A-5	(R3A)	38,018.6	300.8	285.1	278.7	315.6	325.2	283.6	287.2	254.5	330.8	288.7	292.7	206.1	3,449.0	41,467.6
		A-6	(R4A)	33,475.1	302.8	284.8	277.6	313.5	312.3	281.6	284.4	251.2	62.3	0.0	0.0	200.3	2,570.8	36,045.9
		B-1	(R7A)	10,183.0	7.6	6.6	8.4	5.6	8.0	17.4	4.3	4.9	6.5	8.8	1.0	0.9	80.0	10,263.0
	凝集剤注入ポンプ	A-1	(5F)	63,981.7	302.8	285.4	278.5	315.7	261.2	278.4	286.5	259.7	301.1	310.0	304.3	365.9	3,549.5	67,531.2
		A-2	(6F)	57,288.0	298.6	284.7	279.4	315.5	325.3	281.7	235.2	259.7	302.6	310.0	303.3	362.0	3,558.0	60,846.0
		A-3	(7E)	50,802.8	279.8	287.0	279.3	314.7	324.9	281.7	289.8	258.1	292.9	307.7	305.7	359.6	3,581.2	54,384.0
		A-4	(8E)	51,736.0	301.5	284.7	279.6	313.6	323.8	284.2	289.8	261.1	292.9	287.4	305.7	207.0	3,431.3	55,167.3

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計
脱水機設備 (H-C-K1)	凝集剤注入ポンプ	A-5 (F3A)		38,077.3	300.8	285.1	278.7	315.6	325.2	283.6	287.2	254.5	300.8	288.7	292.7	206.1	3,419.0	41,496.3
		A-6 (F4A)		33,510.5	302.8	284.8	277.0	313.5	312.3	281.6	284.4	251.2	62.3	0.0	0.0	200.7	2,570.6	36,081.1
		B-1 (F7A)		10,200.6	7.6	6.8	8.4	5.6	8.0	17.4	4.3	4.9	6.5	8.8	1.0	0.9	80.2	10,280.8
	高架水槽揚水ポンプ	A-1 (4A)		3,478.4	23.2	0.7	0.0	21.7	0.6	0.0	21.1	1.4	0.0	14.2	1.9	0.0	84.8	3,563.2
		A-2 (5A)		3,397.7	0.0	22.7	1.6	0.0	23.3	13.6	0.0	18.0	18.8	5.3	15.8	1.2	120.3	3,518.0
		A-3 (6A)		3,571.6	0.0	0.0	18.0	0.5	0.0	63.7	0.6	0.0	0.0	0.0	0.0	18.4	101.2	3,672.8
	高圧ろ布洗ポンプ	B-1 (R5D)		8,151.9	0.0	35.1	0.0	29.6	0.0	33.3	16.7	7.9	7.8	0.0	0.2	13.0	143.6	8,295.5
		B-2 (R6E)		7,978.1	36.1	4.4	26.2	8.6	25.1	0.0	7.0	0.0	0.0	0.0	0.0	0.6	108.0	8,086.1
	ケーキ圧送ポンプ	B-1 (F2A)		3,037.2	1.9	1.8	2.1	1.4	2.0	1.7	1.1	2.2	1.8	2.7	0.4	0.2	19.3	3,056.5
	第2ポンプ棟 放流ポンプ設備 (E-C-O1)	放流ポンプ (高圧)	No.-1 (K-H-01)		746.1	0.2	0.2	0.5	0.3	45.6	0.1	0.3	0.1	0.1	0.1	0.1	0.2	47.8
No.-2 (K-H-02)				233.2	0.2	0.2	0.1	0.2	20.3	0.1	0.4	0.1	0.1	0.1	0.1	0.3	22.2	255.4
No.-3 (K-H-03)				118.6	0.1	0.3	0.1	0.1	5.3	0.1	0.2	0.1	0.0	0.1	0.2	0.2	6.8	125.4
No.-4 (K-H-04)				98.3	0.1	0.3	0.2	0.1	4.7	0.1	0.2	0.1	0.0	0.1	0.2	0.2	6.3	104.6
ポンプ室床排水ポンプ		No.-1 (2E)		14.6	0.0	0.0	0.0	0.0	0.1	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.4	15.0
		No.-2 (3E)		16.5	0.1	0.0	0.0	0.0	0.1	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.5	17.0
放流ポンプ 冷却水ポンプ		No.-1 (2F)		289.4	0.5	0.3	0.2	0.0	45.9	0.3	0.2	0.3	0.0	0.1	0.7	0.8	49.3	338.7
		No.-2 (3F)		414.6	0.2	0.6	0.8	0.7	2.9	0.2	0.6	0.3	0.2	0.4	0.0	0.2	7.1	421.7
		予備 (2G)		0.0	-	-	-	-	-	-	-	-	-	-	-	0	0.0	0.0
		予備 (3G)		0.0	-	-	-	-	-	-	-	-	-	-	-	0	0.0	0.0
放流水計測室 (E-C-H1)	放流ポンプ (既設)	No.-1 (4A)		449.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	449.6
		No.-2 (4B)		546.7	0.1	0.1	0.3	0.0	3.8	0.1	0.1	0.1	0.0	0.0	0.0	0.0	4.6	551.3
		No.-3 (4C)		234.8	0.1	0.2	0.2	0.0	3.2	0.1	0.2	0.0	0.0	0.0	0.0	0.0	4.0	238.8
A系 急速ろ過設備 (M-C-S1)	汚泥処理送水ポンプ	No.-1 (R6A)		30,325.7	239.9	1.7	131.5	466.4	77.9	1.0	48.1	357.1	445.5	74.3	0.0	2.6	1,846.0	32,171.7
		No.-2 (R6B)		23,745.2	224.7	165.0	1.0	194.0	399.8	29.9	1.0	39.8	44.7	299.4	151.1	130.0	1,680.4	25,425.6
		No.-3 (R6C)		24,292.9	39.6	436.5	34.4	3.7	38.8	400.1	33.5	1.7	1.5	43.6	305.6	375.5	1,714.5	26,007.4
		No.-4 (R3A)		8,532.1	1.1	155.6	356.2	16.2	0.6	57.9	402.3	54.8	1.0	0.3	131.5	30.4	1,207.9	9,740.0
	逆洗排水ポンプ	A-1 (R4D)		27,207.6	215.9	108.1	345.8	34.3	96.9	339.0	118.5	110.4	131.1	220.1	106.8	164.7	1,991.6	29,199.2
		A-2 (R5D)		25,145.6	201.7	15.0	113.3	334.7	58.1	116.4	69.3	0.0	0.0	0.0	0.0	179.3	1,087.8	26,233.4
		A-3 (R6D)		22,464.0	23.2	371.4	25.2	113.7	288.8	22.7	303.9	362.5	379.8	257.0	344.0	168.7	2,660.9	25,124.9

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計	
A系 急速ろ過設備 (M-C-S1)	ポンプ室床排水ポンプ	No-1 (R3B)		11.1	0.4	0.1	0.1	0.0	0.0	0.0	0.0	0.2	0.3	0.0	0.0	0.0	1.1	12.2	
		No-2 (R3C)		6.8	0.1	0.1	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.4	7.2
	急ろ管廊床排水ポンプ	A-1 (R3D)		6.3	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.0	0.0	0.7	7.0
		A-2 (R3E)		104.2	0.4	0.3	0.3	0.2	0.3	1.0	0.2	0.2	0.0	0.4	0.5	0.5	4.3	108.5	
		A-3 (R11B)		10.9	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.8	11.7
		A-4 (R11C)		8.8	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.2	0.0	0.0	0.0	0.0	0.8	9.6
	バルブピット床排水ポンプ	A-1 (R3F)		615.3	3.0	2.4	8.3	1.6	5.1	4.2	1.5	2.4	3.5	6.6	8.8	11.3	58.7	674.0	
	連絡管廊床排水ポンプ	No-1 (R3G)		1,239.7	5.9	6.1	6.0	6.2	6.1	5.1	6.3	6.2	6.2	6.2	5.6	6.0	71.9	1,311.6	
		No-2 (R3H)		16.7	0.1	0.1	0.0	0.1	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.6	17.3	
	空洗プロワ	A-1 (F5B)		1,944.6	11.3	9.8	11.5	2.6	20.4	1.7	25.0	26.2	27.4	5.3	8.1	27.3	176.6	2,121.2	
		A-2 (F6B)		2,035.4	14.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	14.9	2,050.3	
	揚水ポンプ	No-3 (M-H-M4)		6,271.7	149.9	145.3	142.4	186.2	164.3	171.7	148.3	146.8	206.9	220.0	189.7	165.1	2,036.6	8,308.3	
		No-4 (M-H-M3)		36.1	0.1	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.2	0.9	37.0	
		No-5 (M-H-M2)		40,628.9	199.9	246.6	274.4	259.0	239.1	230.8	269.4	282.5	241.5	233.9	196.1	246.6	2,919.8	43,548.7	
No-6 (M-H-M1)			42,713.0	335.7	309.8	276.8	230.2	249.5	247.0	301.8	262.1	275.0	255.8	258.1	309.4	3,311.2	46,024.2		
C系 最初沈殿池設備 (C2-C-D1)	汚泥掻寄機	C-1 (F3C)		14,073.0	0.0	0.0	0.0	0.3	25.0	1.8	8.5	11.2	665.8	743.1	671.4	740.7	2,867.8	16,940.8	
		C-2 (F3D)		121,060.0	341.1	742.3	720.0	744.0	743.8	720.0	741.0	719.1	77.3	0.0	8.7	12.5	5,569.8	126,629.8	
		C-3 (F3E)		41,297.4	393.1	2.7	90.0	7.2	27.0	4.4	9.9	6.0	168.9	389.2	5.8	17.4	1,121.6	42,419.0	
		C-4 (F4C)		26,456.7	0.0	7.5	14.8	7.2	28.8	4.4	9.6	2.0	5.6	1.1	5.8	17.4	104.2	26,560.9	
		C-5 (F4D)		80,673.8	390.4	4.4	0.0	0.2	29.9	1.8	8.4	11.2	669.0	743.1	671.4	740.7	3,270.5	83,944.3	
		C-6 (F4E)		31,322.9	334.7	742.3	720.0	744.0	743.8	720.0	741.0	719.1	79.5	1.1	0.0	14.8	5,560.3	36,883.2	
	汚泥引抜ポンプ	C-1 (F2C)		40,255.2	17.0	401.9	30.2	390.2	65.2	368.5	28.4	346.0	46.6	419.6	106.7	438.4	2,658.7	42,913.9	
		C-2 (F2D)		43,258.3	394.0	14.2	372.3	15.4	343.8	26.2	385.6	68.0	417.9	99.8	368.2	82.8	2,588.2	45,846.5	
	スカム移送ポンプ	C-1 (R4A)		3,137.0	0.6	5.5	0.1	7.6	2.9	4.8	0.9	0.0	0.1	2.2	0.7	2.3	27.7	3,164.7	
		C-2 (R4B)		3,259.4	6.3	0.0	7.2	1.1	4.5	1.4	1.8	2.7	1.5	0.0	0.3	0.0	26.8	3,286.2	
	C系 最終沈殿池設備 (C2-C-E1)	汚泥掻寄機	C-1 (F3C)		126,203.0	718.8	738.8	719.5	738.7	742.8	719.6	743.4	718.2	743.8	743.1	671.3	741.5	8,739.5	134,942.5
C-2 (F3D)				133,970.3	718.0	738.8	719.5	738.7	742.6	718.4	743.4	717.6	743.4	742.9	671.1	741.5	8,735.9	142,706.2	
C-3 (F3E)				126,199.3	597.1	738.8	719.5	739.0	743.2	719.7	743.6	718.5	743.9	743.3	671.2	718.7	8,596.5	134,795.8	
C-4 (F4C)				106,507.3	718.8	738.8	719.5	668.4	743.1	719.6	743.5	718.5	743.9	743.2	671.2	742.3	8,670.8	115,178.1	
C-5 (F4D)				107,356.8	718.8	738.8	719.5	668.2	743.1	719.6	743.5	718.2	743.8	743.2	671.2	742.4	8,670.3	116,027.1	
C-6 (F4E)				107,266.5	718.8	738.8	719.7	738.0	742.9	719.6	743.4	715.6	743.7	743.4	671.2	742.4	8,737.5	116,004.0	

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計
C系 最終沈殿池設備 (C2-C-E1)	返送汚泥ポンプ	C-1	(F5A)	85,293.3	720.4	25.7	670.6	740.2	170.8	672.4	744.0	124.4	666.2	743.5	641.0	742.6	6,661.8	91,955.1
		C-2	(F6A)	83,209.8	578.2	741.4	52.6	716.3	744.0	62.4	692.5	719.0	78.1	597.9	146.8	607.5	5,736.7	88,946.5
		C-3	(F7A)	82,480.6	34.0	719.0	720.0	33.7	620.2	720.0	60.5	597.2	744.0	159.7	555.7	141.9	5,105.9	87,586.5
		C-4	(R5A)	71,124.0	33.8	718.6	720.0	33.6	620.2	720.0	60.5	597.2	743.8	159.4	499.1	742.6	5,648.8	76,772.8
		C-5	(R6A)	58,346.2	718.5	24.5	670.0	739.2	170.8	672.4	744.0	124.4	666.2	743.6	196.1	624.3	6,094.0	64,440.2
		C-6	(R7A)	67,145.6	689.9	742.6	52.6	715.2	744.0	62.4	692.5	719.0	78.1	597.9	647.4	141.8	5,883.4	73,029.0
	余剰汚泥ポンプ	C-1	(F3A)	31,720.8	13.0	307.1	23.8	333.7	59.0	241.7	18.6	221.0	33.7	257.6	64.0	314.3	1,887.5	33,608.3
		C-2	(F3B)	33,056.4	248.0	9.2	291.3	9.2	235.3	17.1	241.2	43.8	323.9	68.1	234.2	52.4	1,773.7	34,830.1
	スカム移送ポンプ	C-1	(F2B)	24,777.8	23.3	539.6	41.4	490.6	80.0	503.8	37.5	458.2	577.6	117.8	382.0	518.1	3,769.9	28,547.7
		C-2	(F2C)	25,635.4	510.0	16.9	475.5	16.6	431.9	37.4	518.0	93.0	0.0	433.5	111.9	0.0	2,644.7	28,280.1
	スカム分離機	C-1	(F2F)	53,128.6	531.2	553.2	513.6	506.4	510.0	537.9	547.2	545.0	571.7	546.0	488.7	512.1	6,363.0	59,491.6
	消泡水ポンプ	C系	(R4C)	49,357.9	163.3	155.2	163.6	156.8	151.9	179.9	163.7	165.1	179.1	168.2	159.3	170.8	1,976.9	51,334.8
		C/D系	(R4D)	34,555.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	34,555.9
		D系	(R4E)	13,436.0	163.8	156.3	163.9	157.0	149.5	159.3	164.3	165.2	180.1	167.6	159.8	171.5	1,958.3	15,394.3
C系 エアタン設備 (C2-C-C1)	C-1エアレータ	C-1-1	(F3B)	120,312.5	716.7	742.9	720.0	744.0	732.9	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,744.5	129,057.0
		C-1-2	(F3C)	120,738.3	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.2	129,497.5
		C-1-3	(F3D)	105,540.1	720.3	742.9	720.0	744.0	744.0	720.0	716.1	720.0	744.0	744.0	672.0	744.0	8,731.3	114,271.4
		C-1-4	(F3E)	108,821.5	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	740.5	8,755.7	117,577.2
		C-1-5	(F3F)	109,127.5	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	740.5	8,755.7	117,883.2
		C-1-6	(F3G)	95,320.1	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	740.5	8,755.7	104,075.8
		C-1-7	(F3H)	109,080.3	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	740.5	8,755.7	117,836.0
	C-2エアレータ	C-2-1	(F4B)	126,637.8	720.3	742.9	720.0	744.0	733.3	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,748.5	135,386.3
		C-2-2	(F4C)	123,824.0	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.2	132,583.2
		C-2-3	(F4D)	123,391.0	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.2	132,150.2
		C-2-4	(F4E)	121,086.4	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.2	129,845.6
		C-2-5	(F4F)	126,267.0	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.2	135,026.2
		C-2-6	(F4G)	126,285.3	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.2	135,044.5
		C-2-7	(F4H)	126,414.2	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.2	135,173.4

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計
C系 エアタン設備 (C2-C-C1)	C-3エアレータ	C-3-1	(R2B)	125,622.1	720.3	742.9	720.0	744.0	733.4	720.0	743.5	720.0	744.0	744.0	672.0	744.0	8,748.1	134,370.2
		C-3-2	(R2C)	125,347.4	720.3	742.9	720.0	744.0	744.0	720.0	743.5	720.0	744.0	744.0	672.0	744.0	8,758.7	134,106.1
		C-3-3	(R2D)	126,246.1	720.3	742.9	720.0	744.0	744.0	720.0	743.5	720.0	744.0	744.0	672.0	744.0	8,758.7	135,004.8
		C-3-4	(R2E)	126,351.8	720.3	742.9	720.0	744.0	744.0	720.0	743.5	720.0	744.0	744.0	672.0	744.0	8,758.7	135,110.5
		C-3-5	(R2F)	126,303.7	720.3	742.9	720.0	744.0	744.0	720.0	743.5	720.0	744.0	744.0	672.0	744.0	8,758.7	135,062.4
		C-3-6	(R2G)	123,033.4	720.3	742.9	720.0	744.0	744.0	720.0	743.5	720.0	744.0	744.0	672.0	744.0	8,758.7	131,792.1
		C-3-7	(R2H)	125,991.9	720.3	742.9	720.0	744.0	744.0	720.0	743.5	720.0	744.0	744.0	672.0	744.0	8,758.7	134,750.6
	C-4エアレータ	C-4-1	(R3B)	107,059.7	720.3	742.9	720.0	744.0	733.4	720.0	743.5	720.0	744.0	744.0	672.0	744.0	8,748.1	115,807.8
		C-4-2	(R3C)	106,947.8	720.3	742.9	720.0	744.0	744.0	720.0	743.5	720.0	744.0	744.0	672.0	744.0	8,758.7	115,706.5
		C-4-3	(R3D)	107,080.0	720.3	742.9	720.0	744.0	744.0	720.0	743.5	720.0	744.0	744.0	672.0	744.0	8,758.7	115,838.7
		C-4-4	(R3E)	107,042.5	720.3	742.9	720.0	744.0	744.0	720.0	743.5	720.0	744.0	744.0	672.0	744.0	8,758.7	115,801.2
		C-4-5	(R3F)	107,057.0	720.3	742.9	720.0	744.0	744.0	720.0	743.5	720.0	744.0	511.6	0.0	0.0	7,110.3	114,167.3
		C-4-6	(R3G)	107,075.8	720.3	742.9	720.0	744.0	744.0	720.0	743.5	720.0	744.0	744.0	672.0	744.0	8,758.7	115,834.5
		C-4-7	(R3H)	107,052.0	720.3	742.9	720.0	744.0	744.0	720.0	743.5	720.0	744.0	744.0	672.0	744.0	8,758.7	115,810.7
	C-5エアレータ	C-5-1	(F8B)	107,483.2	720.3	742.9	720.0	744.0	733.3	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,748.5	116,231.7
		C-5-2	(F8C)	107,479.6	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.2	116,238.8
		C-5-3	(F8D)	107,812.1	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.2	116,571.3
		C-5-4	(F8E)	107,499.3	717.7	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	662.9	744.0	8,747.5	116,246.8
		C-5-5	(F8F)	102,919.0	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.2	111,678.2
		C-5-6	(F8G)	107,805.2	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.2	116,564.4
		C-5-7	(F8H)	107,489.0	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.2	116,248.2
	C-6エアレータ	C-6-1	(R8B)	106,032.0	720.3	742.9	720.0	744.0	733.3	720.0	744.0	720.0	744.0	697.4	562.2	744.0	8,592.1	114,624.1
		C-6-2	(R8C)	106,842.9	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.2	115,602.1
		C-6-3	(R8D)	107,130.4	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.2	115,889.6
		C-6-4	(R8E)	106,851.9	720.3	742.9	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	60.4	744.0	8,147.6	114,999.5
		C-6-5	(R8F)	106,223.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.0	0.0	0.0	0.0	0.0	744.0	106,967.7
		C-6-6	(R8G)	106,836.3	720.3	742.7	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,759.0	115,595.3
		C-6-7	(R8H)	107,060.2	720.3	742.7	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	0.0	8,015.0	115,075.2

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計	
C系 エアタン設備 (C2-C-C1)	送風機	No.7	(C2-H-C1)	54,811.3	292.7	576.5	596.8	531.6	548.3	507.3	686.9	716.6	743.9	738.5	667.8	735.0	7,341.9	62,153.2	
	冷却水ポンプ	No.1	(F3G)	28,000.1	221.1	527.0	215.8	475.4	105.8	442.8	116.8	309.2	265.1	0.0	379.6	255.9	3,314.5	31,314.6	
		No.2	(F3H)	27,606.6	77.5	50.9	389.0	67.1	453.4	74.8	572.8	408.2	479.1	739.0	288.9	480.0	4,080.7	31,687.3	
第1ポンプ棟	シャワー水	No.1	(7A)	279.0	1.6	4.3	0.0	1.7	0.0	0.0	1.0	45.4	0.0	0.0	0.5	45.9	100.4	379.4	
		No.2	(7B)	917.7	1.5	0.0	5.8	0.0	4.0	0.0	2.9	0.0	24.1	0.0	55.2	6.5	100.0	1017.7	
B系 消化タンク設備	消化タンク攪拌機	B-1		71,003.1	575.5	526.5	471.3	436.3	413.6	418.1	491.2	454.9	654.4	657.0	523.6	533.2	6,155.6	77,158.7	
		B-2		2,740.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,740.2
	管廊床排水ポンプ			17.5	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	17.6	
	エレベーター棟床排水ポンプ			33.4	0.1	0.3	0.1	0.0	0.3	0.0	0.1	0.1	0.4	0.0	0.0	0.1	1.5	34.9	
	雑用水加圧ポンプ			74,507.4	575.9	527.0	471.8	437.5	414.0	418.6	491.5	455.3	654.5	657.1	523.8	533.5	6,160.5	80,667.9	
	循環汚泥ポンプ	B-1		39,580.9	0.0	0.1	0.1	0.0	0.0	0.0	0.0	7.1	0.0	0.7	5.3	304.9	717.2	1,035.4	40,616.3
		B-2		240.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	240.3
		B-4		35,865.4	719.3	723.7	709.6	721.9	714.5	710.8	729.1	710.1	734.3	733.3	366.0	22.2	7,594.8	43,460.2	
消化用空気圧縮機	No.1		1,503.6	1.1	26.1	1.9	31.7	1.1	29.2	0.9	25.2	1.2	25.2	1.8	26.6	172.0	1,675.6		
	No.2		2,235.0	25.6	1.2	26.1	1.0	31.7	1.1	28.2	1.6	26.0	1.7	22.7	0.9	167.8	2,402.8		
B系 ボイラー設備	管廊床排水ポンプ			67.3	0.3	0.2	0.4	0.5	0.1	0.7	2.1	0.0	1.8	2.0	0.7	0.1	8.9	76.2	
	B系 温水ボイラー制御盤	オイル燃焼時間		2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.1	2.1	
		ガス燃焼時間		47320.0	453.1	402.2	353.7	333.0	289.8	298.3	347.4	390.6	492.7	529.9	415.5	516.6	4822.8	52142.8	
汚泥乾燥設備 (N-C-T)	空気圧縮機	No.1	(F3A)	26263.5	452.1	527.8	539.6	270.9	0.0	2.3	527.6	61.0	478.8	529.1	531.1	156.0	4076.3	30339.8	
		No.2	(F3B)	29626.9	75.5	1.6	3.3	250.6	525.0	539.0	152.5	409.0	99.4	74.1	0.0	221.6	2351.6	31978.5	
	砂ろ過水ポンプ	No.1	(R3B)	34393.0	262.0	354.0	683.7	263.0	0.0	0.0	385.0	69.7	605.9	188.1	523.7	274.6	3609.7	38002.7	
		No.2	(R3C)	34130.8	428.1	388.5	0.3	431.4	744.0	688.8	408.8	545.0	127.7	272.9	148.9	449.3	4633.7	38764.5	
	砂ろ過水送水ポンプ	No.1	(R3F)	25655.5	193.7	271.7	310.9	323.5	128.0	458.5	144.2	405.9	96.0	204.4	493.1	200.0	3229.9	28885.4	
		No.2	(R3G)	25172.2	324.8	296.6	194.1	193.7	430.3	54.4	430.0	61.5	445.1	137.4	0.0	334.9	2902.8	28075.0	
脱臭ファン		(R4G)	10855.5	61.2	34.8	65.6	72.5	31.3	48.7	70.6	41.1	43.9	83.2	32.7	33.2	618.8	11474.3		
汚泥乾燥設備 (N-C-U1)	1系排ガスファン		(R1A)	68509.2	690.1	742.5	682.9	694.3	744.0	635.1	218.6	11.3	733.6	208.4	672.0	723.7	6756.5	75265.7	
	1系スクラバ循環ポンプ	No.1	(R2B)	33601.6	51.1	546.3	77.5	503.6	148.4	567.8	241.4	543.4	198.2	86.4	355.7	417.2	3737.0	37338.6	
		No.2	(R2C)	35265.5	639.0	196.2	605.6	190.8	598.1	121.0	552.2	71.5	535.3	373.0	317.0	306.6	4506.3	39771.8	

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計	
汚泥乾燥設備 (N-C-U1)	1系熱風炉用ブロワ	No. 1 (R2E)		38228.0	171.0	403.2	315.0	406.1	338.4	286.7	217.4	474.3	296.4	114.3	99.7	112.5	3235.0	41463.0	
		No. 2 (R2F)		39135.6	549.6	339.9	409.2	333.6	408.4	425.8	526.6	239.8	451.0	627.1	573.0	628.7	5512.7	44648.3	
	1系冷却塔循環ポンプ	No. 1-1 (R1E)		37429.5	404.5	45.6	720.0	87.8	217.1	712.3	720.5	322.0	141.8	741.0	575.2	571.5	5259.3	42688.8	
		No. 1-2 (R1F)		38072.3	310.8	691.8	0.0	645.4	524.1	0.0	0.0	403.5	600.5	0.0	0.0	163.5	3339.6	41411.9	
		No. 2-1 (R1G)		37748.1	428.4	19.7	694.2	661.0	0.0	617.7	65.7	372.0	540.9	0.0	0.0	259.5	3659.1	41407.2	
		No. 2-2 (R1H)		38054.2	286.6	688.2	0.0	1.4	724.2	89.6	666.5	315.7	164.8	734.9	672.0	475.2	4819.1	42873.3	
	脱水汚泥移送ポンプ	No. 1 CRT		10623.2	156.9	157.3	149.8	114.9	185.0	284.8	154.3	148.0	160.9	92.5	150.8	153.4	1908.6	12531.8	
		No. 2 CRT		12755.3	113.4	131.3	119.3	156.2	110.0	0.0	137.1	118.3	126.0	84.1	111.8	131.0	1338.5	14093.8	
D系 最初沈殿池設備 (C2-C-D2)	汚泥掻寄機	D-1 (F2C)		4463.6	0.0	0.0	0.0	0.2	28.9	1.8	9.2	11.3	165.3	389.7	3.6	17.6	627.6	5091.2	
		D-2 (F2D)		48825.8	720.6	742.9	720.0	740.3	744.0	249.2	11.3	1.2	4.2	0.0	0.0	12.7	3946.4	52772.2	
		D-3 (F2E)		17259.3	11.1	6.5	9.0	7.1	23.9	474.7	740.9	718.8	740.2	743.8	672.0	744.0	4892.0	22151.3	
		D-4 (F3C)		3786.6	720.6	742.9	717.0	740.3	744.0	720.0	697.6	6.6	5.4	1.8	0.0	14.0	5110.2	8896.8	
		D-5 (F3D)		50298.4	11.0	6.5	8.9	7.1	23.9	4.2	57.9	718.8	740.2	743.6	670.9	744.0	3737.0	54035.4	
		D-6 (F3E)		2891.0	720.6	742.9	720.0	740.3	744.0	720.0	699.1	10.3	5.3	7.6	1.2	17.4	5128.7	8019.7	
	汚泥引抜ポンプ	D-1 (R2H)		13394.7	14.9	366.9	27.5	351.5	111.7	401.3	32.8	62.3	40.9	359.1	94.0	372.9	2235.8	15630.5	
		D-2 (R3H)		15103.5	356.9	12.7	344.4	41.8	338.7	28.1	409.9	313.4	367.0	86.6	303.6	68.3	2671.4	17774.9	
	D系 エアタン設備 (C2-C-C2)	D-1エアレータ	D-1-1 (F2A)		52154.7	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	60913.9
			D-1-2 (F2B)		52181.9	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	60941.1
D-1-3 (F2C)				51758.6	720.5	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.1	60517.7	
D-2エアレータ		D-2-1 (F2D)		52180.1	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	60939.3	
		D-2-2 (F2E)		52184.8	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	60944.0	
		D-2-3 (F2F)		52173.1	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	60932.3	
D-3エアレータ		D-3-1 (F3A)		52181.5	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	60940.7	
		D-3-2 (F3B)		52180.3	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	60939.5	
		D-3-3 (F3C)		52156.5	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	60915.7	
D-4エアレータ		D-4-1 (F3D)		43987.3	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	52746.5	
		D-4-2 (F3E)		51476.2	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	60235.4	
		D-4-3 (F3F)		51670.0	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	60429.2	

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計	
D系 エアタン設備 (C2-C-C2)	D-5エアレータ	D-5-1	(F4A)	51482.9	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	60242.1	
		D-5-2	(F4B)	51436.0	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	60195.2	
		D-5-3	(F4C)	51862.0	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	60621.2	
	D-6エアレータ	D-6-1	(F4D)	51672.7	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	60431.9	
		D-6-2	(F4E)	51169.9	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	59929.1	
		D-6-3	(F4F)	46078.5	720.6	742.9	720.0	744.0	744.0	720.0	743.7	720.0	744.0	744.0	672.0	744.0	8759.2	54837.7	
D系 最終沈殿池設備 (C2-C-E2)	汚泥掻寄機	D-1	(R1A)	52511.6	718.7	738.8	719.4	739.3	743.2	720.0	742.7	718.9	710.0	647.1	663.4	740.5	8602.0	61113.6	
		D-2	(R1B)	52487.2	718.7	738.8	719.4	739.3	743.2	720.0	743.1	717.5	743.3	743.3	672.0	740.7	8739.3	61226.5	
		D-3	(R2A)	52490.2	718.8	738.8	719.4	737.7	743.2	720.0	743.3	718.2	743.5	743.4	672.0	740.7	8739.0	61229.2	
		D-4	(R2B)	51843.5	718.9	738.8	719.4	737.7	743.2	720.0	743.2	717.8	743.5	743.4	672.0	740.9	8738.8	60582.3	
		D-5	(R2C)	51840.5	718.9	738.8	719.4	738.0	743.2	720.0	743.3	717.5	743.5	743.4	672.0	740.2	8738.2	60578.7	
		D-6	(R2D)	51845.9	718.9	738.8	719.4	738.0	743.2	720.0	743.2	717.8	743.5	743.4	672.0	740.3	8738.5	60584.4	
	返送汚泥ポンプ	D-1	(F3A)	36437.2	719.9	24.4	720.0	740.3	170.3	673.2	743.7	128.6	666.5	743.6	580.9	736.8	6648.2	43085.4	
		D-2	(F4A)	34002.1	33.0	742.9	670.7	716.5	744.0	62.2	693.2	718.7	77.9	598.1	239.9	619.8	5916.9	39919.0	
		D-3	(F5A)	34848.1	720.6	495.5	52.4	33.5	620.5	720.0	59.5	597.4	744.0	159.4	524.7	148.8	4876.3	39724.4	
		D-4	(R3A)	36421.0	33.4	719.1	670.4	33.7	620.5	720.0	59.5	597.4	744.0	159.4	524.5	744.0	5625.9	42046.9	
		D-5	(R4A)	34015.1	720.6	24.2	52.7	740.3	170.3	673.2	743.8	125.1	680.5	743.6	148.0	624.2	5446.5	39461.6	
		D-6	(R5A)	33442.4	692.4	742.9	720.0	716.4	744.0	62.2	693.2	178.7	63.5	598.0	672.0	139.4	6022.7	39465.1	
	余剰汚泥ポンプ	D-1	(F2E)	11663.2	11.1	211.7	15.7	250.1	42.2	199.7	15.1	179.1	27.0	207.1	52.3	102.1	1313.2	12976.4	
		D-2	(F2F)	11893.3	230.2	7.2	218.0	8.2	181.1	14.1	185.1	30.5	248.1	51.8	203.9	185.1	1563.3	13456.6	
沈砂設備 (J-C-N1A) <設備更新>	床排水ポンプ	No. 1	(F3E)	1.8	0.1	0.0	0.1	0.1	0.0	0.0	0.2	0.1	0.0	0.0	0.1	0.1	0.8	2.6	
		No. 2	(F3F)	5.8	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	5.9
		No. 3	(F3G)	2.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1	2.7	
	加圧水ポンプ	No. 1	(F2C)	341.4	0.9	16.0	1.1	15.0	0.3	16.2	1.0	12.2	0.6	0.0	0.0	17.3	80.6	422.0	
		No. 2	(F2D)	367.0	19.9	0.8	14.8	1.0	17.7	0.6	16.1	3.4	16.4	15.8	15.0	1.4	122.9	489.9	
	揚砂ポンプ	No. 2	(F3C)	109.0	4.6	1.0	1.3	1.3	2.8	1.2	2.7	0.5	1.7	0.3	0.9	1.0	19.3	128.3	
No. 3		(F3D)	104.3	3.0	1.9	0.8	1.1	1.0	1.5	1.2	1.1	1.4	0.2	0.7	1.0	14.9	119.2		

区分	機器名称	機器番号		25年度末	26年4月	5月	6月	7月	8月	9月	10月	11月	12月	27年1月	2月	3月	年計	累計	
A系エアタン設備	反応槽攪拌装置	4-1	(F2F)	11710.8	720.0	744.0	714.6	744.0	744.0	720.0	744.0	720.0	743.5	744.0	225.0	14.0	7577.1	19287.9	
		4-2	(F2G)	11710.8	720.0	744.0	713.6	744.0	744.0	720.0	744.0	720.0	743.5	744.0	225.0	14.0	7576.1	19286.9	
		4-3	(F2H)	11710.8	720.0	744.0	719.4	740.3	744.0	720.0	744.0	720.0	743.5	744.0	225.0	14.0	7578.2	19289.0	
		5-1	(F2C)	11710.8	715.3	744.0	719.4	744.0	744.0	720.0	744.0	720.0	743.5	744.0	672.0	744.0	8754.2	20465.0	
		5-2	(F2D)	11710.8	720.0	743.6	714.1	744.0	744.0	720.0	744.0	720.0	743.5	744.0	672.0	744.0	8753.2	20464.0	
		5-3	(F2E)	11710.8	720.0	744.0	719.4	740.0	744.0	720.0	744.0	720.0	743.5	744.0	672.0	744.0	8754.9	20465.7	
		6-1	(R2D)	11710.3	713.4	744.0	719.4	744.0	744.0	720.0	744.0	720.0	743.5	744.0	672.0	744.0	8752.3	20462.6	
		6-2	(R2E)	11693.3	720.0	743.6	714.3	744.0	744.0	720.0	744.0	720.0	743.5	744.0	672.0	744.0	8753.4	20446.7	
		6-3	(R2F)	11710.3	720.0	744.0	719.4	739.2	744.0	720.0	744.0	720.0	743.5	744.0	672.0	744.0	8754.1	20464.4	
	凝集剤注入ポンプ	A-1	(R1C)		2825.3	128.0	183.4	114.3	310.3	205.0	0.0	603.7	286.4	277.1	507.5	54.1	141.1	2810.9	5636.2
		A-2	(R1D)		3393.2	229.4	188.6	241.5	167.1	337.6	443.6	125.0	144.0	157.2	134.5	343.5	141.0	2653.0	6046.2