

4 機 械 関 係

(1) 機械設備稼動状況

浄化センター（その1）

（単位：時間）

設備	機 器 名	No	25年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	26年度計	26年度まで累計	
沈砂池設備	揚 砂 ポ ン プ	No.1-1	70.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	70.9	
		No.1-2	82.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	82.6
	細 目 除 塵 機	No.1	1,011.2	0.5	0.4	0.7	0.5	0.7	0.3	0.4	0.6	0.2	0.3	0.0	0.8	5.4	1,016.6	
		し 渣 搬 出 コ ン ベ ア	No.1	949.4	0.9	0.9	1.5	1.2	1.2	1.3	0.8	1.1	0.9	0.4	0.0	1.4	11.6	961.0
			No.2	964.8	1.0	0.9	1.5	1.2	1.3	1.3	0.7	1.1	0.9	0.4	0.0	1.4	11.7	976.5
	着 水 井 攪 拌 機	No.3	997.0	1.3	1.1	1.5	1.5	1.0	1.2	1.1	1.1	0.8	0.5	0.1	1.3	12.5	1,009.5	
		No.1	114,882.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	114,882.1	
	床 排 水 ポ ン プ	No.1	20.5	0.1	0.1	0.1	0.1	0.1	0.0	0.1	1.3	0.1	0.1	0.1	0.1	0.1	2.3	22.8
し 渣 ・ 沈 砂 洗 浄 機		No.1	1,106.2	1.5	1.2	1.5	1.2	1.0	1.3	1.2	1.3	0.9	0.7	0.2	1.5	13.5	1,119.7	
		No.1	186.3	1.1	0.9	1.4	1.5	1.0	0.9	0.8	1.0	0.8	0.3	0.1	1.2	11.0	197.3	
最初沈殿池		生 汚 泥 引 抜 ポ ン プ	No.1	10,006.7	133.2	2.0	127.4	1.9	142.4	2.8	115.4	6.3	67.1	14.9	73.0	5.3	691.7	10,698.4
	No.2		10,073.4	3.6	140.0	7.0	141.3	1.8	141.6	2.7	53.2	1.8	78.4	3.4	100.8	675.6	10,749.0	
	床 排 水 ポ ン プ	No.1	39.6	7.1	12.3	4.6	5.2	6.5	5.0	6.6	27.6	58.7	26.7	13.9	9.4	183.6	223.2	
		1 系 初 沈 汚 泥 掻 寄 機	No.1-1	144,741.0	0.1	132.5	719.7	742.6	743.0	719.3	737.4	586.1	0.6	0.2	204.6	741.3	5,327.4	150,068.4
	No.1-2		102,920.0	0.2	133.5	719.7	742.6	743.2	719.3	737.3	716.9	655.6	425.9	329.8	520.5	6,444.5	109,364.5	
	2 系 汚 泥 掻 寄 機	No.2	49,209.3	704.4	616.8	0.6	0.8	0.6	0.2	0.6	132.9	742.0	738.6	522.2	739.8	4,199.5	53,408.8	
		3 系 汚 泥 掻 寄 機	No.3	61,201.6	705.2	742.5	719.9	743.4	742.6	719.5	738.6	719.1	743.4	740.1	669.9	644.4	8,628.6	69,830.2
	池 排 水 ポ ン プ		No.1	58.3	0.0	1.8	0.0	0.0	0.0	0.0	0.0	0.7	0.0	0.0	2.7	1.7	6.9	65.2
		初 沈 ス カ ム 排 水 ポ ン プ	No.1	3,649.7	15.1	0.5	10.3	0.2	14.5	1.1	14.2	2.2	44.2	4.7	25.3	0.9	133.2	3,782.9
	No.2		4,017.7	0.3	13.6	0.7	7.1	0.0	12.5	0.2	22.4	1.1	29.2	1.1	21.1	109.3	4,127.0	
汚泥処理設備	濃 縮 汚 泥 掻 寄 機	No.1	87,892.0	716.5	742.4	718.0	741.0	739.8	717.0	727.8	716.8	736.4	740.8	663.9	741.7	8,702.1	96,594.1	
		No.2	42,040.5	716.8	742.6	718.3	741.3	739.7	717.2	720.5	716.8	735.2	741.4	664.8	741.8	8,696.4	50,736.9	
	脱 水 ろ 液 移 送 ポ ン プ	No.1	31,770.5	442.2	17.7	407.4	7.0	457.8	8.8	397.8	64.8	355.4	66.3	317.4	205.2	2,747.8	34,518.3	
		No.2	41,301.5	16.2	447.5	19.4	430.5	12.7	393.5	10.7	348.4	192.9	323.2	10.0	177.6	2,382.6	43,684.1	
	汚 泥 貯 留 槽 攪 拌 機	No.1	104,203.1	545.0	389.9	326.9	350.3	335.0	340.2	351.5	335.2	351.0	335.7	314.8	368.3	4,343.8	108,546.9	
		汚 泥 供 給 ポ ン プ	No.1	2,022.8	226.2	9.4	14.8	6.0	31.6	1.6	24.1	0.0	1.0	0.0	0.0	8.9	323.6	2,346.4
	No.2		1,744.6	13.0	138.1	4.2	12.0	1.2	3.7	8.5	2.5	4.6	6.5	25.3	101.8	321.4	2,066.0	
	No.3		10,496.3	4.1	0.1	189.5	8.6	171.5	9.2	185.5	24.6	207.1	62.4	42.1	13.3	918.0	11,414.3	
	No.4		11,281.4	0.1	104.6	7.7	192.7	4.0	186.1	0.3	181.7	8.0	137.1	132.2	97.1	1,051.6	12,333.0	
	濃 縮 汚 泥 移 送 ポ ン プ	No.1	7,210.0	37.4	13.2	36.6	2.4	33.9	0.7	26.2	30.4	35.4	31.2	24.8	29.7	301.9	7,511.9	
		No.2	5,995.3	29.4	32.5	7.8	28.8	2.1	26.4	3.2	27.8	25.0	2.6	24.9	29.9	240.4	6,235.7	
	給 水 ポ ン プ	No.1	719.2	15.1	0.3	9.3	0.1	8.7	0.1	7.5	0.9	7.8	0.5	8.7	0.1	59.1	778.3	
		No.2	812.2	0.0	11.9	0.0	9.3	0.1	8.4	0.0	6.7	0.1	8.0	0.0	11.7	56.2	868.4	
	脱 臭 フ ェ ン	No.1	176,083.4	717.8	743.4	718.8	742.8	742.9	719.4	740.5	719.4	738.0	742.8	671.1	743.1	8,740.0	184,823.4	
		ろ 布 洗 浄 ポ ン プ	No.3	14,565.0	10.9	0.1	247.1	9.4	216.0	3.2	231.0	26.0	263.4	25.5	222.4	6.2	1,261.2	15,826.2
	No.4		No.4	15,197.4	0.0	131.7	6.5	238.1	4.2	237.2	0.0	231.2	4.1	227.4	0.0	141.1	1,221.5	16,418.9
		床 排 水 ポ ン プ	No.1	4,225.6	41.9	3.3	39.3	1.5	75.2	5.0	95.4	34.6	77.6	機器更新			373.8	4,599.4
	No.1		—	—	—	—	—	—	—	—	—	—	6.2	35.1	2.7	44.0	44.0	
	No.2		3,777.0	1.2	36.0	1.6	43.5	4.1	49.5	11.3	76.3	27.4	機器更新			250.9	4,027.9	
No.2	—		—	—	—	—	—	—	—	—	—	24.1	3.4	26.7	54.2	54.2		

浄化センター（その2）

（単位：時間）

設備	機器名	No	25年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	26年度計	26年度まで累計
汚泥処理設備	空気圧縮機	No.1	2,526.4	80.9	70.1	37.1	53.6	80.0	84.1	87.8	85.3	90.1	89.8	80.0	28.5	867.3	3,393.7
		No.2	2,851.8	81.1	70.5	37.0	55.1	80.6	84.4	88.0	85.6	90.7	90.2	80.4	28.5	872.1	3,723.9
	溶解槽攪拌機	No.1	746.0	41.6	18.4	3.5	4.3	4.6	1.7	2.8	1.1	1.1	1.0	2.6	12.6	95.3	841.3
		No.2	26,785.9	0.2	16.6	16.4	13.3	18.4	21.0	16.3	19.9	18.7	18.4	17.9	12.3	189.4	26,975.3
	薬品定量供給機	No.1	131.2	5.6	3.8	0.5	0.7	0.8	0.3	0.8	0.2	0.0	0.2	0.8	3.4	17.1	148.3
	薬品供給機	No.1	774.5	0.1	2.3	4.5	4.0	3.3	4.3	3.5	3.9	4.7	4.9	3.7	2.8	42.0	816.5
	薬品供給ポンプ	No.1	2,078.6	226.9	15.7	14.9	6.0	31.8	1.7	24.2	0.0	1.1	0.0	25.4	9.0	356.7	2,435.3
		No.2	1,711.2	13.2	132.8	4.2	12.0	1.2	3.7	8.5	2.5	4.6	6.6	0.0	102.4	291.7	2,002.9
		No.3	10,568.5	4.0	0.1	190.7	7.8	169.6	5.0	185.4	20.0	214.9	18.1	169.5	3.5	988.6	11,557.1
		No.4	11,262.2	0.2	104.8	6.7	193.5	6.1	190.5	0.4	186.4	0.2	181.4	5.1	107.0	982.3	12,244.5
脱水機	No.1	3,767.4	239.2	147.5	19.0	18.0	32.8	5.3	32.6	2.5	5.6	6.5	25.3	110.7	645.0	4,412.4	
	No.2	21,783.7	4.2	104.7	197.2	201.3	175.5	195.3	185.8	206.3	215.1	199.5	174.3	110.4	1,969.6	23,753.3	
送風	送風機	No.1-1	76,982.7	0.0	0.2	4.1	5.6	0.0	1.3	0.6	1.2	0.0	0.4	4.7	3.3	21.4	77,004.1
		No.1-2	71,923.7	0.0	0.2	4.0	5.6	0.0	1.2	0.7	1.1	0.0	0.3	4.8	3.2	21.1	71,944.8
		No.2-1	73,671.2	630.9	15.3	0.0	0.2	0.0	0.0	25.7	0.0	0.0	6.2	0.0	509.6	1,187.9	74,859.1
		No.2-2	17,863.2	82.1	726.5	699.0	729.0	744.0	712.5	709.8	717.5	744.0	733.1	664.0	222.0	7,483.5	25,346.7
エアタンク	水中攪拌機	No.1-1	41,404.8	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,760.0	50,164.8
		No.1-2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
		No.2-1	43,823.7	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,760.0	52,583.7
		No.2-2	72.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	72.0
	散気装置	No.3-1	61,417.3	713.6	744.0	697.6	729.4	743.5	715.7	739.2	720.0	742.5	742.1	669.3	728.2	8,685.1	70,102.4
		No.3-2	61,187.5	713.6	744.0	697.5	729.4	743.6	715.7	739.2	720.0	742.5	742.1	669.3	734.9	8,691.8	69,879.3
最終沈殿池	1系返送汚泥ポンプ	No.1	23,384.8	703.6	10.3	664.0	10.7	733.2	10.2	725.4	82.4	734.2	107.8	632.9	34.4	4,449.1	27,833.9
		No.2	24,232.0	10.3	731.8	35.0	721.2	10.6	702.8	10.9	635.1	9.7	630.2	34.2	701.8	4,233.6	28,465.6
	2系返送汚泥ポンプ	No.1	30,423.0	703.7	10.3	664.5	10.8	733.3	10.5	724.9	82.3	734.2	107.8	634.6	34.5	4,451.4	34,874.4
		No.2	30,906.0	10.3	731.7	34.7	717.9	10.7	702.5	11.4	636.4	9.7	630.2	34.3	702.6	4,232.4	35,138.4
	余剰汚泥ポンプ	No.1	14,479.9	0.0	0.0	26.0	67.5	72.5	68.7	65.7	53.6	50.7	68.5	33.0	50.0	556.2	15,036.1
		No.2	1,425.5	64.4	62.7	37.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	165.0	1,590.5
		No.3	2,916.7	32.8	37.2	39.8	41.3	43.4	38.5	31.9	33.1	31.9	29.5	33.1	22.6	415.1	3,331.8
	1系終沈汚泥掻寄機	No.1-1	162,075.8	711.6	738.3	711.8	736.9	735.1	712.4	731.5	711.9	735.2	731.5	606.3	735.5	8,598.0	170,673.8
		No.1-2	166,264.3	711.6	738.5	712.0	736.9	731.3	712.3	731.3	711.6	735.4	733.5	663.4	735.7	8,653.5	174,917.8
	2系終沈汚泥掻寄機	No.2	137,808.7	711.5	738.0	711.8	736.7	734.8	712.3	731.8	710.9	735.3	733.1	662.7	734.9	8,653.8	146,462.5
	3系終沈汚泥掻寄機	No.3	61,056.5	715.7	740.5	715.2	740.1	738.4	715.2	736.1	715.5	739.8	737.0	666.8	689.3	8,649.6	69,706.1
	A・T床排水ポンプ	No.1	2,156.9	22.9	41.3	35.0	36.7	29.8	22.5	20.0	15.4	14.0	15.2	13.7	24.0	290.5	2,447.4
	終沈床排水ポンプ	No.1	2,103.6	0.7	0.1	0.7	0.3	3.0	0.1	1.7	0.5	2.3	1.0	2.7	0.6	13.7	2,117.3
		No.2	1,790.1	0.1	0.9	0.1	16.1	0.2	1.3	0.1	0.6	0.1	4.3	0.1	1.3	25.2	1,815.3
	終沈スカム排水ポンプ	No.1	10,569.0	50.9	0.7	48.4	0.7	50.7	0.9	52.9	8.8	57.0	7.4	55.1	4.1	337.6	10,906.6
No.2		9,043.5	1.1	49.7	2.8	46.3	1.1	53.7	1.0	44.4	0.8	41.0	2.3	77.8	322.0	9,365.5	
池排水ポンプ	No.1	64.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	64.7	

浄化センター（その3）

（単位：時間）

設備	機器名	No	25年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	26年度計	26年度まで累計
用水設備	原水ポンプ	No.1	35,796.3	3.5	0.1	3.8	0.1	4.1	0.1	22.4	0.4	3.8	0.4	4.9	0.3	43.9	35,840.2
		No.2	32,395.8	0.1	3.1	0.1	4.9	0.3	4.2	0.2	4.3	0.3	4.3	0.9	3.8	26.5	32,422.3
		No.3	3,880.5	127.9	204.1	295.1	324.2	309.0	343.7	318.3	387.9	351.2	341.3	314.3	249.4	3,566.4	7,446.9
	消泡水ポンプ	No.1	1,902.6	7.3	0.1	4.8	0.0	2.2	0.1	14.3	1.2	13.1	0.0	9.1	0.7	52.9	1,955.5
		No.2	1,637.6	0.1	9.6	1.0	2.7	0.1	2.9	0.0	8.0	0.1	5.4	0.0	11.6	41.5	1,679.1
	逆洗排水ポンプ	No.1	4,135.6	0.3	0.1	0.4	0.0	8.5	0.0	7.9	0.0	4.3	0.1	6.0	3.7	31.3	4,166.9
		No.2	4,376.9	0.1	4.3	0.0	4.4	0.1	17.1	0.0	4.4	0.2	8.6	4.4	4.8	48.4	4,425.3
	濾過水移送ポンプ	No.1	6,522.5	13.5	0.0	74.5	1.2	73.0	1.6	77.8	10.2	87.9	13.7	76.2	2.6	432.2	6,954.7
		No.2	6,986.3	0.2	45.0	2.3	79.8	2.2	75.2	0.1	78.0	1.3	71.9	6.2	54.1	416.3	7,402.6
	空気圧縮機	No.1	12,699.5	6.8	0.2	0.6	0.1	8.8	0.3	17.6	0.4	10.5	1.6	7.6	0.3	54.8	12,754.3
		No.2	12,904.1	0.2	8.0	0.5	4.9	13.8	19.3	0.3	10.4	0.2	10.4	0.7	9.6	78.3	12,982.4
	用水床排水ポンプ	No.1	70.6	52.2	0.9	42.8	1.5	44.9	0.7	41.4	4.8	66.8	17.1	37.4	2.3	312.8	70.6
		No.2	98.8	1.1	55.3	2.9	56.6	1.4	54.5	1.0	46.1	0.9	37.0	2.5	54.5	313.8	98.8
	ろ過器	No.1	3,880.5	127.9	204.1	295.1	324.2	309.0	343.7	318.3	387.9	351.2	341.3	314.3	249.4	3,566.4	7,446.9
No.2		3,880.9	0.0	2.2	0.2	0.0	0.0	3.2	3.6	0.0	2.1	0.1	362.6	679.4	1,053.4	68,434.3	
次亜塩素酸ソーダ注入ポンプ	No.1	67,380.9	713.2	738.8	695.5	732.4	743.4	707.4	731.2	718.3	736.9	737.9	305.7	2.8	7,563.5	86,966.9	
	No.2	79,403.4	0.0	0.2	1.6	0.5	0.5	1.2	0.6	0.5	4.8	0.1	0.2	39.8	50.0	9,166.2	
	No.3	9,116.2	0.0	0.2	1.6	0.5	0.5	1.2	0.6	0.5	4.8	0.1	0.2	39.8	50.0	9,166.2	
機械濃縮設備	余剰汚泥貯留槽攪拌機	No.1	87,712.8	715.5	742.5	713.2	743.7	744.0	715.2	735.3	715.3	744.0	742.0	670.7	736.1	8,717.5	96,430.3
	汚泥供給ポンプ	No.1	25,830.7	369.6	8.9	370.9	6.4	447.8	9.7	423.5	60.0	379.5	59.5	291.3	22.3	2,449.4	28,280.1
		No.3	25,963.5	6.7	375.8	20.5	421.9	13.2	417.6	11.0	395.7	10.4	375.8	23.7	344.6	2,416.9	28,380.4
	浮上濃縮機	No.1	51,792.5	376.3	384.8	391.3	428.3	460.9	427.2	434.5	455.6	389.9	435.3	314.9	366.9	4,865.9	56,658.4
	凝集剤供給機	No.1	451.2	3.2	3.3	3.4	3.6	5.3	7.6	7.6	8.8	7.6	7.7	4.7	5.5	68.3	519.5
		No.2	463.1	3.2	3.4	3.2	3.8	5.0	7.6	7.8	8.9	8.0	7.8	4.8	5.7	69.2	532.3
	凝集剤注入ポンプ	No.1	26,021.6	372.3	9.1	373.5	6.6	450.7	9.8	426.3	60.4	382.1	59.9	293.9	22.5	2,467.1	28,488.7
		No.2	26,124.2	6.8	378.9	20.7	424.6	13.3	420.2	11.1	398.0	10.6	378.3	23.8	346.7	2,433.0	28,557.2
	濃縮汚泥貯留槽攪拌機	No.1	22,702.2	0.2	0.1	0.1	0.1	3.4	3.8	1.3	2.6	1.7	3.6	1.7	0.0	18.6	22,720.8
	濃縮汚泥移送ポンプ	No.1	1,367.4	20.2	0.6	20.9	0.6	22.4	0.3	18.6	2.3	18.1	2.1	14.1	0.8	121.0	1,488.4
		No.2	1,340.9	0.4	21.3	0.1	20.3	0.6	21.6	0.3	15.4	0.5	16.9	0.6	15.4	113.4	1,454.3
	凝集剤溶解槽攪拌機	No.1	4,627.3	31.9	35.2	33.7	40.0	50.7	37.6	33.7	38.1	34.3	32.1	20.4	24.2	411.9	5,039.2
		No.2	4,681.1	34.4	34.1	37.4	38.2	51.2	40.5	34.0	38.9	33.8	32.7	20.1	23.8	419.1	5,100.2
	空気圧縮機	No.1	15,093.0	190.0	0.0	190.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	380.0	15,473.0
		No.2	14,620.0	10.0	210.0	30.0	260.0	300.0	230.0	240.0	230.0	230.0	220.0	190.0	210.0	2,360.0	16,980.0
	起泡水ポンプ	No.1	24,379.3	365.9	15.0	365.1	14.0	441.0	14.9	420.3	66.3	374.2	67.0	286.9	32.2	2,462.8	26,842.1
		No.3	27,771.3	13.7	371.9	27.4	416.2	21.2	414.5	19.0	387.1	20.5	369.1	32.0	333.1	2,425.7	30,197.0
	起泡助剤希釈槽攪拌機	No.1	315.2	2.5	1.3	2.6	2.5	2.6	4.0	2.6	2.8	3.9	1.3	1.3	1.4	28.8	344.0
	起泡助剤注入ポンプ	No.1	136,158.8	365.9	15.0	365.1	14.0	441.0	17.9	420.3	66.3	374.2	67.0	286.9	30.5	2,464.1	138,622.9
		No.3	26,017.6	13.7	371.9	27.4	416.2	21.3	412.0	19.0	387.1	20.5	369.1	32.0	334.8	2,425.0	28,442.6
脱気槽攪拌機	No.1	52,492.0	381.8	389.0	394.7	432.5	464.3	431.5	441.6	455.5	396.8	438.3	320.0	367.2	4,913.2	57,405.2	
床排水ポンプ	No.1	710.6	4.2	0.1	2.3	0.1	7.0	1.9	11.3	0.4	1.4	0.3	1.5	0.2	30.7	741.3	
	No.2	727.2	0.3	2.8	0.2	2.2	0.2	3.5	0.2	1.5	0.1	1.7	0.2	1.6	14.5	741.7	

中継ポンプ場（その1）

（単位：時間）

設備	機器名	No	25年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	26年度計	26年度まで累計	
獅子崎	細目除塵機	No.1		10.0	10.3	10.0	10.3	10.3	10.0	10.3	10.0	10.3	10.3	10.0	12.4	124.2		
	破砕機	No.1		23.3	24.0	23.3	24.0	24.0	23.3	24.0	23.3	24.0	24.0	23.3	28.9	289.4		
	汚水ポンプ	No.1	56,506.1	0.3	0.4	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	4.3	0.5	6.3	56,512.4
		No.2	55,540.5	0.3	0.5	0.1	4.5	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.4	1.9	8.2	55,548.7
		No.3	5,292.6	0.0	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.0	5,293.6
		No.4	46,178.2	711.8	716.2	724.2	700.4	723.8	734.2	755.4	673.7	789.3	716.4	662.4	724.7	8,632.5	54,810.7	
		No.5	将来設備															
	水中ミキサー	No.1	81,143.4	0.0	0.0	71.8	718.7	724.5	739.0	765.8	676.0	789.8	94.5	671.6	736.7	5,988.4	87,131.8	
No.2		123,421.0	479.6	719.7	742.7	719.6	724.7	739.0	765.8	676.0	789.9	721.6	671.6	734.5	8,484.7	131,905.7		
脱臭ファン	No.1	75,986.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	744.0	672.0	744.0	8,760.0	84,746.0	
鶴賀	細目除塵機	No.1		10.0	10.3	10.0	10.3	10.3	10.0	10.3	10.0	10.3	10.3	10.0	12.4	124.2		
	破砕機	No.1		23.3	24.0	23.3	24.0	24.0	23.3	24.0	23.3	24.0	24.0	23.3	28.9	289.4		
	汚水ポンプ	No.1	64,987.5	54.6	41.6	29.3	0.0	21.7	0.1	21.4	231.1	21.0	0.2	14.3	0.0	435.3	65,422.8	
		No.2	65,432.7	0.1	3.8	1.2	26.2	0.1	31.5	0.0	247.7	1.3	12.2	5.5	19.7	349.3	65,782.0	
		No.3	3,714.6	2.3	2.3	1.8	2.1	2.3	2.2	2.5	98.5	2.4	0.9	2.1	1.0	120.4	3,835.0	
		No.4	41,487.9	654.0	667.7	688.1	673.6	700.1	698.4	732.1	325.6	764.3	701.5	630.0	706.3	7,941.7	49,429.6	
		No.5	将来設備															
	水中ミキサー	No.1	151,514.3	720.2	719.7	744.1	719.7	724.7	738.6	768.3	673.9	789.0	429.7	576.6	740.2	8,344.7	159,859.0	
No.2		51,035.7	720.3	719.8	744.1	719.7	724.4	738.6	768.3	337.9	789.7	422.0	573.5	740.5	7,998.8	59,034.5		
脱臭ファン	No.1		720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	744.0	672.0	744.0	8,760.0		
須津	破砕機	No.1-1	111,530.1	654.5	666.2	692.2	689.0	692.7	699.1	726.2	633.1	309.9	198.5	637.2	701.6	7,300.2	118,830.3	
		No.1-2	111,571.4	655.4	666.2	692.2	689.0	693.3	700.9	726.6	634.9	766.7	682.3	637.2	701.6	8,246.3	119,817.7	
	汚水ポンプ	No.1	59,707.1	652.7	0.3	689.6	21.4	668.2	2.2	722.4	3.1	764.0	7.6	367.1	0.1	3,898.7	63,605.8	
		No.2	57,295.8	0.3	663.1	0.3	665.1	28.5	698.4	18.5	630.4	0.6	678.4	268.0	699.0	4,350.6	61,646.4	
		No.3	将来設備															
		No.4	283.2	2.5	2.6	2.5	2.6	6.2	2.2	2.0	1.5	2.2	2.5	6.9	2.3	36.0	319.2	
	水中ミキサー	No.1	452.3	720.3	719.8	743.8	720.4	718.2	744.3	768.2	670.5	796.2	713.7	672.2	744.4	8,732.0	9,184.3	
		No.2	452.3	720.3	719.8	743.8	720.6	718.2	744.3	768.2	670.5	796.2	710.6	672.2	744.4	8,729.1	9,181.4	
	脱臭ファン	No.1	103,993.3	719.4	718.9	742.9	720.5	712.8	743.4	767.1	669.8	795.7	714.1	666.6	743.8	8,715.0	112,708.3	
	床排水ポンプ	No.1	28.8	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.2	29.0	
		No.2	16.4	0.0	0.1	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.0	0.0	0.0	0.3	16.7	
	シール水ポンプ	No.1	22,101.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	22,101.0	
No.2		15,866.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	15,866.1		

中継ポンプ場（その2）

（単位：時間）

設備	機器名	No	25年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	26年度計	26年度まで累計
堂谷	破 碎 機	No.1-1	90,260.4	582.2	581.9	604.9	590.8	602.3	594.6	633.1	546.2	631.7	606.7	563.6	617.0	7,155.0	97,415.4
		No.1-2	90,260.4	582.2	581.9	604.9	590.8	602.3	594.6	633.1	546.2	631.7	606.7	563.6	617.0	7,155.0	97,415.4
	汚 水 ポ ン プ	No.1	45,192.8	582.2	89.6	604.9	103.1	602.3	96.9	633.1	92.5	631.7	116.1	563.6	105.5	4,221.5	49,414.3
		No.2	50,010.4	79.2	581.9	93.1	590.8	118.7	594.6	114.2	546.2	157.8	606.7	99.5	617.0	4,199.7	54,210.1
		No.3	将来設備														
		No.4	181.8	4.6	4.9	4.0	4.4	5.0	8.8	4.8	3.1	5.7	4.8	4.3	5.6	60.0	241.8
		No.5	将来設備														
	水 中 ミ キ サ ー	No.1	139,514.3	719.7	719.0	742.7	718.7	719.8	742.8	767.4	674.1	785.1	715.6	669.7	743.6	8,718.2	148,232.5
		No.2	56,221.9	719.7	719.0	742.2	718.7	719.8	742.8	767.4	674.1	670.4	715.9	669.7	742.9	8,602.6	64,824.5
	脱 臭 フ ァ ン	No.1	43,601.2	155.6	152.9	156.0	148.8	149.6	157.7	165.5	147.7	173.5	156.2	229.9	269.5	2,062.9	45,664.1
	床 排 水 ポ ン プ	No.1	4.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4.1
		No.2	3.5	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1	3.6
	シ ー ル 水 ポ ン プ	No.1	12,108.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	12,108.3
		No.2	12,579.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	12,579.8
四辻	破 碎 機	No.1-1	79,473.6	588.8	586.1	532.4	596.9	611.2	613.6	617.3	554.9	592.3	620.0	520.6	637.1	7,071.2	86,544.8
		No.1-2	76,338.2	588.8	586.1	532.4	596.9	611.2	613.6	617.3	554.9	592.3	620.0	520.6	637.1	7,071.2	83,409.4
	汚 水 ポ ン プ	No.1	44,335.9	588.8	75.9	532.4	77.4	611.2	88.9	617.3	67.5	592.3	113.9	520.6	92.1	3,978.3	48,314.2
		No.2	46,853.1	83.5	586.1	24.9	596.9	111.0	613.6	102.8	554.9	96.0	620.0	44.8	637.1	4,071.6	50,924.7
		No.3	78.8	3.5	3.0	3.2	4.1	3.4	3.3	3.6	2.8	3.8	3.4	3.3	3.5	40.9	119.7
		No.4	将来設備														
	水 中 ミ キ サ ー	No.1	146,095.7	720.4	719.0	744.0	719.2	720.7	742.5	764.0	671.1	796.4	716.1	671.2	744.3	8,728.9	154,824.6
		No.2	15,981.8	720.5	719.0	744.0	719.2	720.7	742.5	764.1	671.1	796.4	716.1	671.6	744.4	8,729.6	24,711.4
	脱 臭 フ ァ ン	No.1	39,166.1	151.6	150.8	154.0	148.0	149.3	153.2	145.3	140.3	167.5	149.2	137.4	152.3	1,798.9	40,965.0
	床 排 水 ポ ン プ	No.1	3.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.0
		No.2	4.7	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1	4.8
	シ ー ル 水 ポ ン プ	No.1	10,758.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10,758.4
		No.2	11,718.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	11,718.9