

4 機械関係

(1) 機械設備稼働状況(No.1)

(単位:時間)

設備	機器名	No	平成25年度 までの累計	平成26年									平成27年			合計	平成26年度 までの累計
				4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月		
着水井	揚水ポンプ	No.1	15,163.36	67.72	82.42	127.82	146.30	125.48	76.33	75.37	73.42	142.03	142.98	70.80	75.45	1,206.12	16,369.48
		No.2	14,585.16	72.05	65.17	14.62	0.00	100.40	79.78	80.28	61.22	0.00	0.00	60.60	79.25	613.37	15,198.53
最初沈殿池	※ 掻き寄せ機	No.1	43,058.60	12.20	13.90	11.90	12.00	31.40	10.60	11.50	13.90	3.50	27.50	0.00	0.50	148.90	43,207.50
		No.2	9,046.80	12.10	13.90	11.90	12.00	36.10	10.60	11.10	11.60	3.40	28.30	0.10	0.40	151.50	9,198.30
		No.3	32,416.50	717.00	742.20	717.00	741.70	741.60	717.10	743.20	713.80	741.90	736.80	670.30	740.20	8,722.80	41,139.30
	初沈引抜ポンプ	No.1	5,755.89	47.45	49.30	40.87	40.07	47.80	37.05	40.07	39.83	58.58	10.83	36.50	39.23	487.58	6,243.47
		No.2	6,590.66	49.82	52.95	45.90	42.20	44.57	38.53	45.53	50.62	10.58	76.85	42.50	57.27	557.32	7,147.98
	※ スカム移送ポンプ		2,982.70	17.70	18.70	15.40	17.50	12.80	15.70	14.90	13.90	14.20	12.70	12.60	14.30	180.40	3,163.10
	※ 床排水ポンプ		603.10	4.90	4.90	4.40	4.50	5.60	4.00	4.50	4.30	3.80	3.60	3.90	5.40	53.80	656.90
	池排水ポンプ	No.1	7,049.79	103.35	85.93	149.58	71.02	89.15	98.05	92.18	88.27	99.73	77.60	104.25	102.98	1,162.09	8,211.88
No.2		7,713.79	108.78	137.78	81.72	147.90	85.93	86.62	107.00	113.00	107.32	124.38	88.98	112.83	1,302.24	9,016.03	
生物反応槽	エアタン攪拌装置	No.1-1	79,114.34	0.00	0.00	97.88	647.48	650.73	626.83	646.23	624.87	647.22	689.63	584.37	647.75	5,862.99	84,977.33
		No.1-2	79,740.22	0.00	0.00	97.92	647.42	650.73	626.70	647.73	624.75	647.30	665.07	584.13	647.75	5,839.50	85,579.72
		No.2-1	71,521.25	625.55	647.83	530.62	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.28	0.00	1,804.28	73,325.53
		No.2-2	71,523.27	626.78	646.73	530.55	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1,804.06	73,327.33
		No.3-1	31,751.96	671.88	694.48	671.63	693.30	695.58	671.63	694.25	669.05	694.65	714.82	627.10	691.43	8,189.80	39,941.76
		No.3-2	31,750.55	672.12	694.75	671.07	693.57	695.03	671.88	694.38	669.15	694.68	714.88	628.42	691.48	8,191.41	39,941.96
		No.3-3	31,757.48	672.45	695.02	672.23	693.83	695.50	671.78	694.80	669.60	695.02	714.90	627.12	691.48	8,193.73	39,951.21
	エアタン曝気装置	No.1-1	107,467.82	0.00	0.00	109.10	744.00	744.00	719.58	744.00	717.60	743.12	716.28	672.00	744.00	6,653.68	114,121.50
		No.1-2	107,456.22	0.00	0.00	110.67	744.00	721.53	630.25	651.20	630.98	653.35	695.22	587.55	646.43	6,071.18	113,527.40
		No.1-3	106,728.61	0.00	0.00	110.67	744.00	744.00	719.55	741.70	717.72	743.12	739.88	672.00	744.00	6,676.64	113,405.25
		No.1-4	107,411.19	0.00	0.00	110.67	744.00	744.00	719.55	744.00	715.97	743.12	739.88	672.00	744.00	6,677.19	114,088.38
		No.2-1	77,455.83	720.00	743.97	637.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2,101.24	79,557.07
		No.2-2	77,440.62	639.27	666.05	637.38	0.00	0.00	0.00	0.00	0.02	0.00	0.00	0.00	0.00	1,942.72	79,383.34
		No.2-3	77,434.78	719.92	743.78	637.37	0.00	0.00	0.00	0.02	0.00	0.02	0.00	0.00	0.00	2,101.11	79,535.89
No.2-4	77,456.82	720.00	743.97	634.78	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	2,098.77	79,555.59		

※ アワーメーター値

## (1) 機械設備稼働状況(No.2)

(単位:時間)

設備	機器名	No	平成25年度 までの累計	平成26年												平成27年			合計	平成26年度 までの累計
				4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月					
生物 反応槽	循環水ポンプ	No.1-1	0.10	0.02	0.02	110.38	734.82	739.32	716.05	737.90	710.78	738.25	729.22	669.07	743.83	6,629.66	6,629.76			
		No.1-2	9,838.14	0.02	0.00	110.48	728.20	728.82	696.48	727.10	696.68	722.10	715.75	654.68	723.55	6,503.86	16,342.00			
		No.2-1	680.00	719.85	743.68	609.23	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.45	0.03	2,073.26	2,753.26		
		No.2-2	35,280.20	687.35	708.25	608.32	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	2,003.99	37,284.19		
	PAC注入ポンプ	No.1	59,652.39	360.67	361.17	336.08	360.75	414.30	374.87	5.18	0.03	0.03	0.07	25.37	336.57	2,575.09	62,227.48			
		No.2	32,771.57	720.00	741.93	719.75	742.98	743.88	719.27	744.00	713.98	742.75	732.20	672.00	744.00	8,736.74	41,508.31			
		No.4	64,906.18	359.30	382.80	383.65	383.20	329.58	343.77	738.48	713.95	743.12	731.95	646.60	407.43	6,163.83	71,070.01			
	※ 床排水ポンプ		61.00	0.30	0.20	0.20	0.30	0.50	0.10	0.20	0.20	0.20	0.40	0.20	0.20	3.00	64.00			
	※ 管廊床排水ポンプ	No.1	68.50	0.30	0.10	0.10	0.10	0.10	0.00	0.00	0.10	1.10	0.10	0.30	0.60	2.90	71.40			
		No.2	1,550.80	33.20	29.80	22.20	16.60	16.30	11.60	10.80	10.60	15.50	27.60	29.50	38.50	262.20	1,813.00			
No.3		301.90	4.30	2.90	2.30	1.50	3.20	1.80	2.20	1.90	1.70	3.10	1.90	1.90	28.70	330.60				
脱臭	※ 脱臭ファン		82,878.10	720.60	745.10	716.70	719.00	744.10	719.00	744.50	716.50	743.60	740.30	659.40	718.60	8,687.40	91,565.50			
送風機	送風機	No.2	29,364.27	455.12	527.13	512.68	654.87	707.05	392.17	688.18	674.82	672.82	737.25	654.50	731.47	7,408.06	36,772.33			
		No.3	1.56	0.08	0.08	0.18	0.08	0.13	0.10	0.12	0.07	0.07	0.15	0.13	0.10	1.29	2.85			
		No.4	75,041.17	704.10	349.60	412.43	11.32	351.82	424.28	303.18	322.70	238.48	304.93	153.27	237.83	3,813.94	78,855.11			
		No.5	72,200.73	0.07	339.27	290.20	672.63	221.75	431.08	248.25	202.28	257.55	89.10	238.32	192.58	3,183.08	75,383.81			
最 終 沈 殿 池	返送汚泥ポンプ	No.1	125,121.00	719.83	742.57	712.33	743.62	743.77	719.27	743.77	711.55	741.43	729.88	667.68	743.93	8,719.63	133,840.63			
		No.2	1,566.02	0.07	1.17	1.63	0.02	0.03	0.15	0.03	2.33	0.22	0.07	4.02	0.05	9.79	1,575.81			
		No.3	31.87	0.00	0.25	0.03	0.02	0.63	0.15	0.02	1.97	0.02	0.05	1.62	0.03	4.79	36.66			
		No.4	32,714.75	719.95	743.73	719.70	743.97	743.25	719.43	743.95	711.98	741.48	730.57	670.37	743.97	8,732.35	41,447.10			
	余剰汚泥ポンプ	No.1	3,921.54	28.47	1.77	27.68	26.73	31.23	28.13	27.23	24.30	24.95	25.33	37.07	30.92	313.81	4,235.35			
		No.2	4,075.28	29.90	57.67	28.23	31.08	30.08	26.47	30.65	33.32	35.32	51.07	31.25	40.88	425.92	4,501.20			
	※ 汚泥かき寄せ機	No.1-1	99,538.20	0.30	0.20	115.40	740.30	737.60	716.00	740.80	712.80	740.90	735.70	669.10	738.10	6,647.20	106,185.40			
		No.1-2	82,199.50	0.30	0.20	115.50	740.30	737.50	716.00	741.50	712.80	739.90	735.70	669.00	738.10	6,646.80	88,846.30			
		No.2	65,705.20	715.70	739.60	599.20	0.30	4.50	0.20	0.20	0.20	0.20	0.20	0.20	0.20	2,060.70	67,765.90			
		No.3	32,595.90	716.20	740.00	715.50	740.80	738.20	715.70	742.00	713.00	740.50	735.90	669.50	739.30	8,706.60	41,302.50			

※ アワーメーター値

(1) 機械設備稼働状況(No.3)

(単位:時間)

設備	機器名	No	平成25年度 までの累計	平成26年												平成27年			合計	平成26年度 までの累計
				4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月					
最終沈殿池	※ スカム移送ポンプ		4,803.50	22.10	24.10	18.60	19.50	12.50	16.90	16.90	16.80	18.50	15.60	14.10	17.50	213.10	5,016.60			
	※ スカム分離機		6,401.50	50.40	54.00	43.40	47.00	31.80	41.80	40.10	38.00	40.20	34.90	32.90	39.20	493.70	6,895.20			
	※ スカム脱水機		7,694.30	75.80	80.50	64.90	70.90	47.40	63.50	60.40	56.10	58.50	50.70	47.70	57.00	733.40	8,427.70			
	※ 床排水ポンプ		143.00	0.80	0.80	0.50	1.00	4.70	0.70	1.50	0.40	0.50	1.10	0.60	1.00	13.60	156.60			
	※ 消泡水ポンプ		58,864.20	390.30	402.50	423.00	402.60	391.30	390.20	402.90	411.70	434.00	424.50	392.60	461.90	4,927.50	63,791.70			
急速ろ過棟	原水ポンプ	No.1-1	43,456.73	241.70	299.70	259.23	246.82	192.53	183.60	230.58	249.20	233.75	202.72	272.40	162.77	2,775.00	46,231.73			
		No.1-2	44,983.06	221.58	267.72	198.08	236.53	130.73	229.80	238.42	273.98	216.02	250.30	137.68	258.18	2,659.02	47,642.08			
		No.2	892.87	16.05	22.83	17.07	33.40	172.83	30.92	28.37	9.90	17.72	38.27	26.92	29.60	443.88	1,336.75			
		No.3	7,965.34	237.85	151.47	237.33	191.32	164.97	226.30	248.22	178.40	220.00	208.15	180.67	227.72	2,472.40	10,437.74			
	逆洗ポンプ	No.1	148.90	0.75	0.83	0.92	0.92	1.05	0.65	0.75	0.50	0.75	0.48	0.72	0.50	8.82	157.72			
		No.2	158.22	0.75	1.08	1.00	0.85	0.50	0.57	0.60	1.00	0.92	1.33	0.73	0.83	10.16	168.38			
	逆洗排水ポンプ	No.1	13,271.72	58.73	47.08	40.10	79.40	57.72	42.50	45.18	33.57	5.08	31.03	54.80	60.52	555.71	13,827.43			
		No.2	8,562.27	46.73	102.47	72.87	39.02	36.58	31.08	47.93	80.32	110.07	113.80	51.95	29.70	762.52	9,324.79			
	逆洗ブロワ	No.1	154.86	0.75	0.83	0.83	0.83	1.07	0.67	0.75	0.50	0.75	0.50	0.75	0.50	8.73	163.59			
		No.2	169.58	0.75	1.08	1.08	1.00	0.50	0.58	0.58	1.00	0.92	1.33	0.60	0.83	10.25	179.83			
	次亜塩注入ポンプ		95,946.89	716.15	740.83	710.12	706.63	658.72	669.45	741.65	710.52	686.35	697.27	616.12	677.35	8,331.16	104,278.05			
	※ 空気圧縮機	No.1	402.30	3.00	3.10	2.90	3.20	3.60	3.90	2.80	2.60	2.60	6.10	2.60	2.50	38.90	441.20			
		No.2	421.10	3.00	3.40	3.50	3.20	3.00	2.80	3.00	3.20	3.00	3.60	2.40	3.10	37.20	458.30			
	※ 床排水ポンプ	No.1	470.90	4.20	4.00	3.70	4.00	4.40	6.80	6.30	4.50	5.40	4.20	10.20	5.10	62.80	533.70			
No.2		484.80	4.80	4.70	4.50	4.00	4.30	3.80	3.40	5.70	4.00	4.70	5.10	4.00	53.00	537.80				
放流ポンプ棟	放流ポンプ	No.1	19.68	0.03	0.05	0.02	0.03	1.22	0.03	0.03	0.02	0.02	0.00	0.02	0.03	1.50	21.18			
		No.2	22.73	0.03	0.02	0.03	0.03	1.22	0.02	0.03	0.02	0.02	0.03	0.02	0.03	1.50	24.23			
	次亜塩注入ポンプ	No.1	63,641.56	376.05	360.82	335.75	268.83	412.68	385.70	360.20	311.83	584.45	731.32	667.75	744.00	5,539.38	69,180.94			
		No.2	55,180.39	343.97	383.18	383.97	475.67	339.83	330.40	383.80	402.23	158.82	0.00	3.62	0.02	3,205.51	58,385.90			
自家発電	自家発		71.41	0.08	0.08	1.13	0.10	0.10	1.03	0.08	0.00	0.52	0.43	0.15	0.18	3.88	75.29			
	※ 燃料移送ポンプ	No.1	0.51	0.00	0.00	0.00	0.10	0.00	0.00	0.00	0.00	0.10	0.00	0.00	0.00	0.20	0.71			
		No.2	0.41	0.00	0.00	0.00	0.10	0.00	0.00	0.00	0.00	0.10	0.00	0.00	0.00	0.20	0.61			

※ アワーメーター値

## (1) 機械設備稼働状況(No.4)

(単位:時間)

設備	機器名	No	平成25年度 までの累計	平成26年								平成27年			合計	平成26年度 までの累計		
				4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月			3月	
汚 泥 施 設	余剰汚泥分離機		22,086.06	140.23	143.12	132.42	130.98	137.73	121.07	132.15	132.65	109.03	160.15	144.70	163.97	1,648.20	23,734.26	
	余剰汚泥スクリーンかす脱水機		21,948.24	139.40	142.95	131.12	130.45	137.25	120.85	131.38	133.10	111.13	160.45	146.73	165.83	1,650.64	23,598.88	
	余剰汚泥供給ポンプ	No.1	0.00							340.38	94.50	157.05	78.50	0.00	2.03	10.42	682.88	682.88
		No.2	0.00							17.88	235.35	165.32	237.97	325.40	300.72	315.27	1,597.91	1,597.91
	余剰汚泥貯留槽攪拌機	No.1	62,656.32	683.02	686.73	642.42	648.65	564.40	461.10	632.73	613.60	614.90	632.85	577.32	635.87	7,393.59	70,049.91	
		No.2	61,549.20	683.02	686.73	642.42	648.65	655.85	639.68	632.73	613.60	614.90	582.92	48.20	640.70	7,089.40	68,638.60	
	分離液ピット攪拌機	No.1	63,334.74	372.27	269.38	286.90	220.95	299.67	308.33	228.68	13.75	8.07	108.40	139.87	123.27	2,379.54	65,714.28	
		No.2	66,616.41	372.27	269.38	286.90	220.95	299.67	308.33	228.68	13.75	8.07	0.00	40.38	123.27	2,171.65	68,788.06	
	分離液排水ポンプ	No.1	11,080.22	55.48	52.87	48.48	50.98	46.45	51.77	55.58	46.28	53.52	45.65	55.05	52.12	614.23	11,694.45	
		No.2	11,536.09	52.48	56.35	55.30	53.35	57.05	49.52	57.15	57.62	50.43	60.87	44.50	58.73	653.35	12,189.44	
	ベルト濃縮凝集剤 注入ポンプ	No.1	18,598.50	169.18	170.15	325.93	391.60	387.20	340.00	94.37	157.32	78.70	0.00	2.07	10.45	2,126.97	20,725.47	
		No.2	20,169.02	221.78	227.88	57.63	0.30	0.20	18.57	235.65	165.40	237.80	325.90	301.00	315.83	2,107.94	22,276.96	
	ベルト濃縮機	No.1	32,120.55	409.57	415.88	400.27	410.05	404.42	20.62	100.57	166.65	85.75	1.97	4.30	1.58	2,421.63	34,542.18	
		No.2	0.00							359.15	245.70	170.78	247.30	336.48	312.27	337.68	2,009.36	2,009.36
	汚泥貯留槽攪拌機	No.1	117,599.91	720.00	742.95	719.15	743.95	744.00	711.65	739.42	717.77	736.53	738.02	670.28	743.65	8,727.37	126,327.28	
No.2		791.46	0.07	0.05	0.05	0.05	0.05	0.05	0.05	0.03	0.07	0.05	0.05	0.05	0.62	792.08		
ろ布洗浄水ポンプ	No.1	7,510.95	14.28	23.22	23.40	22.18	10.80	15.63	9.87	18.32	8.00	8.37	8.60	14.13	176.80	7,687.75		
	No.2	7,502.67	29.68	23.88	30.28	21.48	33.80	29.28	28.12	10.07	9.80	8.28	7.78	20.25	252.70	7,755.37		
洗浄水ポンプ	No.3	436.81	36.80	33.23	30.20	33.62	30.23	32.87	39.80	49.08	51.57	57.88	57.58	51.08	503.94	940.75		

※ アワーメーター値

※ 9月より遠心濃縮凝集剤注入ポンプ→ベルト濃縮凝集剤注入ポンプに機器名を変更(同一器使用のため機器名のみ変更)

※ 9月より遠心濃縮機→ベルト濃縮機No.1にそれぞれ機器名を変更(濃縮機更新のため)

※ 遠心濃縮機運転時間、4・5月でそれぞれ0.13(合計0.26)時間運転。

※ No.2ベルト濃縮機新設および、余剰汚泥供給ポンプ(No.1.2)、更新につき、記録は9月以降を記載。

(1) 機械設備稼働状況(No.5)

(単位:時間)

設備	機器名	No	平成25年度 までの累計	平成26年												平成27年			合計	平成26年度 までの累計
				4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月					
汚 泥 施 設	凝集剤溶解タンク攪拌機	No.1	1130.57	8.27	9.88	12.13	8.67	10.38	8.68	10.40	8.67	8.68	10.60	8.67	10.43	115.46	1,246.03			
		No.2	110.70	10.42	7.40	5.83	8.73	7.28	9.03	7.27	8.13	7.28	8.73	8.77	8.73	97.60	208.30			
	汚泥脱水機凝集剤 注入ポンプ	No.1	5798.30	7.18	14.63	20.37	12.88	11.92	13.22	12.17	9.53	1.08	0.52	0.75	1.63	105.88	5,904.18			
		No.2	5572.90	18.22	14.00	13.62	11.63	13.38	13.03	6.10	1.18	1.00	0.77	0.80	12.70	106.43	5,679.33			
		No.3	1021.61	86.38	75.68	72.83	78.60	73.02	73.32	95.47	114.07	121.92	138.45	133.37	119.02	1,182.13	2,203.74			
	ケーキ搬出コンベア		1508.07	126.23	117.90	119.05	116.33	110.85	114.40	130.73	142.22	143.22	159.63	156.38	152.88	1,589.82	3,097.89			
	生物脱臭装置		30150.09	710.47	739.63	707.20	733.02	733.72	702.93	729.97	707.33	734.72	724.03	655.05	729.55	8,607.62	38,757.71			
	ケーキ移送ポンプ		11729.90	79.03	79.03	80.38	74.55	78.92	90.73	117.55	127.95	121.93	140.30	138.38	132.13	1,260.88	12,990.78			
	ケーキ移送フィーダ		5550.02	79.03	79.03	80.38	74.53	78.92	90.73	117.70	127.97	121.92	140.30	138.40	132.02	1,260.93	6,810.95			
	汚泥供給ポンプ	No.1	6058.02	7.10	14.47	20.13	12.68	11.80	13.08	11.87	9.33	1.08	0.50	0.75	1.62	104.41	6,162.43			
		No.2	5866.87	18.05	13.85	13.48	11.45	13.27	12.88	5.98	1.17	0.98	0.77	0.78	12.67	105.33	5,972.20			
		No.3	1019.17	86.37	75.67	72.82	78.60	73.00	73.27	95.45	114.07	121.90	138.40	133.30	118.95	1,181.80	2,200.97			
	汚泥脱水機	No.1	14933.46	44.18	47.25	53.92	43.82	44.75	45.13	38.35	28.63	18.02	16.77	16.55	34.62	431.99	15,365.45			
		No.3	1172.03	99.40	88.00	83.27	90.75	83.42	85.93	109.38	131.52	140.50	157.68	154.08	136.88	1,360.81	2,532.84			
	※ 汚泥処理棟 給水ポンプ	No.1	1314.60	4.90	5.50	5.50	5.00	5.40	5.40	5.50	4.20	2.50	2.00	3.00	3.00	51.90	1,366.50			
		No.2	1374.30	5.40	5.80	6.70	5.20	5.60	5.60	4.20	3.60	2.70	3.50	2.10	6.70	57.10	1,431.40			
	※ 汚泥処理棟 床排水ポンプ	No.1	29.10	0.00	0.00	0.00	0.10	0.70	0.10	0.00	0.10	0.10	0.00	0.10	0.70	1.90	31.00			
		No.2	12.50	0.60	0.50	2.00	0.40	0.30	0.30	0.50	0.40	0.50	0.70	0.60	1.90	8.70	21.20			
※ 脱臭ファン		103044.10	721.10	741.90	722.60	745.50	737.30	748.40	714.50	717.70	745.80	733.50	663.70	742.40	8,734.40	111,778.50				

※ アワーメーター値

## (1) 機械設備稼働状況(No.6)

(単位:時間)

設備	機器名	No	平成25年度 までの累計	平成26年									平成27年			合計	平成26年度 までの累計
				4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月		
八木嶋 ポンプ場	破砕機	No.1	74,124.89	364.93	371.58	356.10	368.75	426.87	499.75	498.87	105.00	0.00	0.00	0.00	0.00	2,991.85	77,116.74
		No.2	66,508.52	364.72	371.58	356.10	368.25	212.28	0.00	0.00	0.00	0.00	0.00	0.00	488.67	2,161.60	68,670.12
	攪拌機	No.1	32,448.25	0.00	0.00	70.33	164.33	176.48	187.52	175.45	171.35	174.22	176.52	162.10	179.20	1,637.50	34,085.75
		No.2	24,116.36	720.00	744.00	496.35	185.43	184.68	178.18	184.92	178.02	186.62	183.62	167.80	185.25	3,594.87	27,711.23
	汚水ポンプ	No.1-1	53,119.87	383.57	335.97	336.73	287.62	406.02	357.88	360.45	402.37	426.62	438.57	669.33	743.25	5,148.38	58,268.25
		No.1-2	62,739.95	336.27	407.70	382.95	456.17	339.18	361.57	382.63	312.20	315.63	291.98	0.17	0.12	3,586.57	66,326.52
		No.2	1,172.27	0.05	0.05	0.03	0.07	6.57	0.12	5.98	0.07	0.03	4.75	0.07	0.05	17.84	1,190.11
	揚水ポンプ		1.22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00	0.02	1.24
	生物脱臭装置		43,819.57	720.00	744.00	720.00	744.00	744.00	720.00	744.00	718.22	743.82	741.00	669.62	743.68	8,752.34	52,571.91
※ 脱臭ファン		58,957.43	710.50	751.50	720.20	720.50	745.00	718.20	816.00	644.00	828.50	640.50	794.80	719.00	8,808.70	67,766.13	
向河原 ポンプ場	破砕機	No.1	33,227.82	304.17	328.03	315.35	333.27	324.47	254.90	0.05	0.00	0.00	0.02	0.13	301.72	2,162.11	35,389.93
		No.2	33,221.04	304.15	328.03	315.35	333.27	324.52	278.35	328.05	290.70	299.45	299.02	269.60	345.75	3,716.24	36,937.28
	攪拌機	No.1	9,251.66	185.43	192.88	186.38	193.25	189.80	182.87	191.83	184.52	189.70	191.00	179.02	201.45	2,268.13	11,519.79
		No.2	13,375.29	182.53	187.07	179.12	98.07	161.53	179.58	187.13	182.63	190.05	190.93	171.35	189.37	2,099.36	15,474.65
	汚水ポンプ	No.1-1	12,315.73	109.08	109.38	82.17	105.52	198.52	124.50	110.88	134.78	111.68	163.68	46.18	112.43	1,408.80	13,724.53
		No.1-2	12,220.05	90.77	121.43	110.03	110.10	112.40	129.47	110.35	89.97	132.10	105.55	195.77	73.43	1,381.37	13,601.42
		No.2	8,662.70	104.58	97.63	123.78	118.70	29.08	28.80	108.13	66.27	55.95	29.78	28.00	160.28	950.98	9,613.68
	自家発		11.19	0.08	0.10	0.33	0.08	0.07	0.37	0.10	0.08	0.57	0.10	0.08	0.10	2.06	13.25
※ 脱臭ファン		37,969.98	718.30	743.60	718.90	719.80	746.00	714.60	814.20	650.00	835.40	647.80	691.70	723.70	8,724.00	46,693.98	
マンホール ポンプ	八-1-1 マンホールポンプ	No.1	15,919.10	124.72	130.67	135.83	142.77	176.18	138.22	140.43	132.45	145.45	151.25	138.92	157.42	1,714.31	17,633.41
		No.2	15,251.68	126.60	136.10	138.13	147.40	193.08	142.58	146.67	144.32	151.63	153.37	139.58	155.85	1,775.31	17,026.99
	八-1-2 マンホールポンプ	No.1	3,660.34	19.25	20.98	20.55	21.78	29.57	19.35	20.12	19.82	21.18	20.00	17.95	20.13	250.68	3,911.02
		No.2	3,677.05	19.43	21.33	20.65	23.22	32.03	20.92	21.48	21.53	22.32	21.30	18.48	21.18	263.87	3,940.92
	八-1-3 マンホールポンプ	No.1	4,330.98	39.40	41.43	41.53	40.88	58.90	37.78	41.70	34.15	35.53	43.23	38.12	46.87	499.52	4,830.50
		No.2	4,182.10	42.52	44.60	44.20	44.43	66.53	40.60	44.18	37.05	38.85	49.15	43.22	52.67	548.00	4,730.10
	八-1 マンホールポンプ	No.1	1,975.34	30.35	31.20	30.53	32.08	39.42	30.93	31.62	30.22	31.08	54.48	58.18	49.03	449.12	2,424.46
		No.2	2,342.71	31.20	32.37	31.97	33.13	41.22	31.55	32.75	32.23	33.00	16.47	0.00	11.92	327.81	2,670.52

※ アワーメーター値