

4 機械関係

(1) 機械設備稼働状況

No. 1 (単位:時間)

区分	機器名称	機器番号	26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計
自家発棟	非常用自家発電機	No.-4	47.8	0.2	0.1	0.2	0.2	0.2	0.2	0.1	0.1	0.2	0.2	1.1	1.4	4.2	52.0
		No.-3	175.3	0.1	0.2	0.2	0.1	0.1	0.2	0.2	0.2	0.2	0.1	2.1	1.1	4.8	180.1
第1ポンプ棟	主ポンプ	1号 (J-H-N6)	2,085.2	0.0	0.0	11.5	72.2	21.8	46.1	0.2	18.6	17.4	16.8	20.2	4.8	229.6	2,314.8
		2号 (J-H-N3)	1,838.6	9.0	9.6	32.4	59.6	31.6	38.8	7.1	18.4	15.3	0.0	3.9	13.2	238.9	2,077.5
		3号 (J-H-N5)	110,274.8	685.3	698.4	663.2	626.5	691.2	619.4	626.2	592.4	655.2	550.7	588.2	646.3	7,643.0	117,917.8
		4号 (J-H-N2)	82,740.3	413.6	327.3	380.6	407.7	373.4	345.3	279.9	313.7	290.0	385.5	304.3	276.7	4,098.0	86,838.3
		5号 インハータ盤	126,469.4	177.2	320.1	211.5	177.9	231.2	228.4	400.7	327.5	305.7	342.6	300.4	375.1	3,398.3	129,867.7
第1ポンプ棟 し渣設備 (J-C-N1)	し渣スキップホイス	(2G)	1,873.5	-	-	-	-	-	-	-	-	-	-	-	-	0.0	1,873.5
	細目自動除塵機	No.-1 (3A)	12,509.0	7.2	7.9	7.9	8.8	8.1	8.9	8.3	7.8	9.3	8.4	9.2	16.1	107.9	12,616.9
		No.-2 (3B)	19,309.4	8.5	8.1	8.0	8.2	7.9	8.6	8.2	7.9	9.6	8.4	9.2	14.2	106.8	19,416.2
		No.-3 (3C)	20,063.6	8.5	8.2	7.9	8.5	8.2	8.7	8.5	7.8	9.3	8.8	9.0	16.2	109.6	20,173.2
	し渣破砕機	(3D)	422.1	-	-	-	-	-	-	-	-	-	-	-	-	0.0	422.1
	し渣脱水機	(3E)	22,851.5	-	-	-	-	-	-	-	-	-	-	-	-	0.0	22,851.5
	粗目自動除塵機	No.-1 (4A)	526.1	2.2	2.0	1.8	2.0	1.6	1.7	2.0	1.8	2.1	2.4	2.3	2.1	24.0	550.1
		No.-2 (7C)	468.3	1.5	1.7	1.3	1.2	1.1	1.2	1.3	1.4	1.6	2.2	1.6	0.5	16.6	484.9
		No.-3 (7E)	490.5	1.9	1.9	1.5	1.5	1.1	1.3	1.7	1.7	1.8	1.7	1.7	2.2	20.0	510.5
	し渣搬出機	No.-1 (4D)	1,349.3	5.9	7.0	6.0	6.4	5.3	5.6	6.3	6.0	6.2	6.3	5.7	5.8	72.5	1,421.8
		No.-2 (4E)	1,532.3	7.5	7.4	6.4	6.8	5.6	5.9	6.7	6.4	6.6	6.7	6.1	6.1	78.2	1,610.5
		No.-3 (4F)	24,704.4	32.3	35.4	33.5	34.5	33.0	31.5	33.8	32.8	35.1	33.6	29.6	51.4	416.5	25,120.9
		No.-4 (4G)	23,540.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0
	し渣洗浄攪拌機	(5D)	24,909.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24,909.0
	予備	(6A)	0.0	-	-	-	-	-	-	-	-	-	-	-	-	0.0	0.0
沈砂池室床排水ポンプ	No.-1 (6B)	19.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	19.6
	No.-2 (6C)	4,088.0	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	4,088.0
	No.-3 (6D)	4,128.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	4,128.5

No. 2 (単位:時間)

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計	
第1ポンプ棟 沈砂設備 (J-C-N2)	高架水槽揚水ポンプ	No-1	(6E)	4,518.8	18.8	17.5	18.2	18.7	17.0	17.6	15.6	14.9	14.7	15.5	14.4	15.8	198.7	4,717.5	
		No-2	(6F)	4,548.8	18.2	17.1	17.4	18.4	16.3	17.1	15.0	14.5	14.2	14.8	14.3	15.5	192.8	4,741.6	
	沈砂池揚砂ポンプ	No-1	(2A)	1,609.8	2.9	1.1	3.2	3.1	4.6	5.2	4.3	6.2	4.0	4.4	3.6	6.1	48.7	1,658.5	
		No-2	(2B)	1,824.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	1,824.5
		No-3	(2C)	1,525.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	1,525.5
	沈砂洗浄攪拌機		(3A)	5,533.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	5,533.8
	沈砂搬出機		(3D)	6,319.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	6,319.7
沈砂スキップホイス		(3E)	228.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	228.7	
第1ポンプ棟	主ポンプ室床排水ポンプ	No-1	(2E)	6,643.2	42.3	36.6	45.8	53.5	45.9	50.4	37.6	39.9	37.7	38.8	38.1	39.1	505.7	7,148.9	
		No-2	(2F)	5,535.1	28.1	24.4	29.9	33.6	29.4	31.7	23.9	24.6	23.3	24.0	23.4	24.2	320.5	5,855.6	
	主ポンプ冷却水ポンプ	No-1	(2G)	118,376.4	462.3	418.0	332.9	500.5	288.7	508.8	0.1	388.5	426.1	408.5	269.9	265.7	4,270.0	122,646.4	
		No-2	(2H)	109,988.2	257.4	325.9	386.5	255.7	455.6	211.0	743.1	334.7	313.8	335.4	425.6	477.7	4,522.4	114,510.6	
	分配槽床排水ポンプ	No-1	(4D)	7.7	0.1	0.1	0.2	0.2	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.7	8.4
		No-2	(4E)	5.7	0.1	0.1	0.2	0.2	0.0	0.0	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.8	6.5
第1送風機棟 送風機設備 (C-C-C)	送風機3相420V	No-1	(2B)	74,419.6	363.2	427.0	344.1	346.7	221.7	209.9	93.6	191.2	245.8	102.3	243.3	207.4	2,996.2	77,415.8	
		No-2	(3B)	65,395.0	230.0	412.3	311.7	298.8	76.7	0.1	58.4	219.0	323.7	103.0	138.4	257.8	2,429.9	67,824.9	
		No-3	(4A)	108,876.7	62.9	0.0	0.0	0.0	280.5	501.5	595.0	412.3	306.0	142.3	429.7	548.8	3,279.0	112,155.7	
	送風機3相6600V	No-4	(C-H-C1)	107,013.2	294.3	342.8	243.1	202.9	311.3	422.3	483.1	523.5	542.4	89.2	398.2	502.1	4,355.2	111,368.4	
		No-5	(C-H-C2)	85,344.1	304.0	325.6	369.6	443.2	324.6	148.7	92.4	35.5	36.2	438.0	102.3	92.3	2,712.4	88,056.5	
		No-6	(C-H-C3)	65,770.8	0.2	2.1	2.3	1.4	0.2	3.5	0.2	0.1	1.7	15.6	51.8	0.0	79.1	65,849.9	
	潤滑油ポンプ	No-1	(7B)	115,097.8	416.9	321.5	415.0	463.9	101.5	561.5	140.6	612.6	71.4	120.2	25.7	581.3	3,832.1	118,929.9	
		No-2	(7C)	106,208.1	67.9	235.6	37.3	0.0	401.1	46.0	535.9	101.3	644.9	204.1	551.7	101.5	2,927.3	109,135.4	
		No-3	(9B)	77,467.2	314.1	149.1	379.2	463.6	92.6	115.2	11.1	38.9	1.0	300.8	79.6	106.0	2,051.2	79,518.4	
		No-4	(9C)	74,477.5	9.2	195.3	13.9	0.0	248.1	47.4	95.0	0.6	41.3	176.7	83.6	0.0	911.1	75,388.6	
	潤滑油冷却塔	No-1	(7F)	172,187.0	484.7	556.8	452.3	463.8	502.5	607.3	676.4	711.6	716.2	251.9	0.2	0.1	5,423.8	177,610.8	
		No-2	(9F)	110,560.6	323.3	344.3	393.1	463.6	340.7	162.6	106.1	39.4	42.2	313.2	0.1	0.1	2,528.7	113,089.3	
	冷却水ポンプ	No-1	(7D)	191,389.7	484.7	556.8	452.3	463.8	502.6	607.3	676.4	711.6	716.2	324.3	576.9	682.6	6,755.5	198,145.2	
		No-2	(7E)	32,462.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	32,462.1	
No-3		(9D)	147,324.5	323.3	344.3	393.1	463.6	340.7	162.6	106.1	39.4	42.2	475.7	163.1	102.7	2,956.8	150,281.3		

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計	
第1送風機棟 A系 最初沈殿池設備 (C-C-D1)	汚泥掻寄機	A-1-1	(2E)	25,245.9	0.0	41.2	719.4	743.8	744.0	719.6	743.2	720.0	738.4	733.8	649.3	17.9	6,570.6	31,816.5	
		A-1-2	(2F)	39,652.5	0.0	41.2	719.4	743.7	744.0	719.6	743.2	720.0	738.4	733.8	649.3	17.9	6,570.5	46,223.0	
		A-2	(2G)	143,601.9	719.9	744.0	719.4	743.8	744.0	719.6	743.2	720.0	738.4	733.8	694.1	732.7	8,752.9	152,354.8	
		A-3	(2A)	90,431.3	719.9	704.5	7.3	39.2	15.9	6.3	0.0	2.6	0.0	0.0	0.8	0.0	1,496.5	91,927.8	
		A-4	(6B)	50,080.8	13.6	5.4	1.3	31.6	8.0	2.6	4.0	3.8	10.2	2.6	5.7	8.8	97.6	50,178.4	
		A-5	(6C)	99,985.8	13.7	5.6	10.8	34.7	11.9	4.6	6.0	3.9	1.7	2.3	0.9	1.1	97.2	100,083.0	
		A-6	(6D)	72,258.8	719.9	744.0	719.4	743.7	744.0	719.6	743.2	720.0	738.4	734.8	693.0	742.8	8,762.8	81,021.6	
	汚泥引抜ポンプ	A-1	(3E)	9,655.5	0.0	6.6	124.2	126.3	130.2	127.1	131.0	126.6	126.6	125.7	111.4	0.0	1,135.7	10,791.2	
		A-2	(3F)	68,567.9	375.6	101.0	240.0	22.5	235.9	71.2	257.3	37.7	228.5	45.7	235.5	31.4	1,882.3	70,450.2	
		A-3	(3G)	74,751.6	22.3	290.0	16.4	244.0	35.1	187.5	17.7	220.1	47.1	216.6	35.3	414.2	1,746.3	76,497.9	
	スカム移送ポンプ	A-1	(4E)	1,758.0	0.8	0.5	1.2	0.0	0.0	0.5	0.1	1.6	0.6	1.3	0.0	1.2	7.8	1,765.8	
		A-2	(4F)	1,606.4	0.0	0.0	0.0	0.0	0.7	0.0	1.0	0.4	0.4	0.0	0.6	0.0	3.1	1,609.5	
	沈殿池管廊床排水P	A-1	(3B)	522.5	0.1	0.2	0.4	1.9	0.1	0.2	0.3	0.0	0.4	0.0	0.2	0.1	3.9	526.4	
		A-2	(9F)	73.1	0.0	0.0	0.1	0.1	0.1	0.2	0.1	0.0	0.0	0.0	0.1	0.4	1.1	74.2	
	送風機管廊床排水ポンプ	No-1	(3C)	122.4	0.0	0.0	0.1	0.1	0.1	0.1	0.2	0.0	0.1	0.1	0.1	0.1	1.0	123.4	
		No-2	(3D)	679.1	0.8	0.0	0.3	0.9	0.1	0.8	0.0	0.1	0.1	0.2	0.1	0.3	3.7	682.8	
		No-3	(9G)	157.9	0.1	0.2	0.2	0.5	0.3	0.2	0.1	0.1	0.1	0.3	0.2	0.0	2.3	160.2	
	第1送風機棟 B系 最初沈殿池設備 (C-C-D2)	汚泥掻寄機	B-1	(F2C)	108,293.2	13.6	5.4	15.8	41.2	16.6	690.9	743.1	720.0	738.3	314.9	13.7	8.8	3,322.3	111,615.5
			B-2	(F2D)	97,709.3	720.0	744.0	719.5	743.2	744.0	719.6	743.1	720.0	738.3	733.8	694.0	742.7	8,762.2	106,471.5
B-3			(F2E)	117,054.8	0.0	0.0	0.0	30.9	8.0	0.0	0.0	1.0	0.0	0.0	0.7	0.0	40.6	117,095.4	
B-4			(F2F)	67,145.5	720.0	744.0	719.5	743.2	744.0	719.6	743.1	720.0	738.3	733.8	649.1	8.8	7,983.4	75,128.9	
B-5			(F4E)	83,676.1	0.0	0.0	14.6	36.0	18.8	687.7	743.1	720.0	738.3	314.8	56.6	742.7	4,072.6	87,748.7	
B-6			(F4F)	102,975.4	720.0	744.0	719.5	743.1	744.0	42.4	0.0	3.8	1.6	419.0	650.9	1.0	4,789.3	107,764.7	
汚泥引抜ポンプ		B-1	(F2A)	84,494.6	25.5	294.5	27.2	351.1	51.8	369.7	34.6	434.4	48.4	413.8	33.5	432.5	2,517.0	87,011.6	
		B-2	(F2B)	84,314.0	353.4	443.1	346.2	33.7	328.9	123.7	485.2	71.1	469.3	98.0	454.5	30.7	3,237.8	87,551.8	
スカム移送ポンプ		B-1	(R2A)	988.3	1.4	0.4	0.9	0.0	0.0	0.4	0.0	1.3	0.0	1.7	0.0	0.9	7.0	995.3	
		B-2	(R2B)	1,141.8	0.0	0.0	0.0	0.0	0.9	0.0	1.6	0.3	1.4	0.5	0.7	0.0	5.4	1,147.2	
管廊床排水ポンプ		B-1	(R2E)	115.4	0.7	0.4	1.2	2.0	0.9	0.7	0.2	0.6	0.5	0.3	0.4	0.3	8.2	123.6	
		B-2	(R2F)	73.4	0.1	0.1	0.2	0.1	0.2	0.1	0.2	0.0	0.1	0.1	0.1	0.0	1.3	74.7	

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計	
第1送風機棟 A系 エアタン設備 (C-C-C2)	A-4エアレータ	A-4-1	(F2A)	148,150.9	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,150.9	
		A-4-2	(F2B)	148,482.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,482.9
		A-4-3	(F2C)	148,623.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,623.8
		A-4-4	(F2D)	147,807.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,807.7
		A-4-5	(F2E)	147,606.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,606.3
		A-4-6	(F2F)	148,092.1	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,092.1
		A-4-7	(F2G)	147,723.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,723.9
		A-4-8	(F2H)	147,175.2	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,175.2
	A-5エアレータ	A-5-1	(F3A)	155,223.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,223.6
		A-5-2	(F3B)	156,674.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,674.5
		A-5-3	(F3C)	156,748.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,748.3
		A-5-4	(F3D)	155,027.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,027.5
		A-5-5	(F3E)	156,772.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,772.9
		A-5-6	(F3F)	156,466.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,466.5
		A-5-7	(F3G)	156,599.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,599.3
		A-5-8	(F3H)	155,889.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,889.5
	A-6エアレータ	A-6-1	(R2A)	155,711.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,711.6
		A-6-2	(R2B)	156,258.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,258.8
		A-6-3	(R2C)	156,152.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,152.6
		A-6-4	(R2D)	154,393.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	154,393.9
		A-6-5	(R2E)	156,679.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,679.6
		A-6-6	(R2F)	155,738.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,738.7
		A-6-7	(R2G)	156,060.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,060.9
		A-6-8	(R2H)	155,251.4	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,251.4
第1送風機棟 B系 エアタン設備 (C-C-C3)	B-1エアレータ	B-1-1	(F2A)	185,157.4	720.0	744.0	720.0	744.0	744.0	716.7	743.0	720.0	744.0	734.1	696.0	741.3	8,767.1	193,924.5	
		B-1-2	(F2B)	185,395.1	720.0	744.0	720.0	744.0	744.0	717.7	743.0	720.0	744.0	734.2	696.0	741.7	8,768.6	194,163.7	
		B-1-3	(F2C)	185,065.6	720.0	744.0	720.0	744.0	744.0	717.5	743.0	720.0	744.0	734.1	696.0	743.3	8,769.9	193,835.5	
		B-1-4	(F2D)	182,579.0	720.0	744.0	720.0	744.0	744.0	717.6	743.0	720.0	744.0	734.1	696.0	743.3	8,770.0	191,349.0	

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計	
第1送風機棟 B系 エアタン設備 (C-C-C3)	B-1エアレータ	B-1-5	(F2E)	177,110.6	0.0	0.0	0.0	0.0	0.0	0.0	743.0	0.0	0.0	0.0	0.0	0.0	743.0	177,853.6	
		B-1-6	(F2F)	175,946.4	0.0	0.0	0.0	0.0	0.0	4.9	10.1	10.0	0.0	0.0	0.0	0.0	25.0	175,971.4	
		B-1-7	(F2G)	185,650.4	720.0	744.0	720.0	744.0	744.0	717.7	743.0	720.0	744.0	732.3	696.0	634.7	8,659.7	194,310.1	
		B-1-8	(F2H)	179,682.7	720.0	744.0	720.0	623.1	744.0	717.6	743.0	720.0	744.0	734.1	696.0	743.3	8,649.1	188,331.8	
	B-2エアレータ	B-2-1	(F3A)	184,035.2	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	734.2	696.0	743.3	8,772.5	192,807.7	
		B-2-2	(F3B)	179,053.9	720.0	744.0	720.0	744.0	744.0	720.0	668.7	720.0	744.0	733.4	696.0	743.3	8,697.4	187,751.3	
		B-2-3	(F3C)	184,262.9	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	734.0	696.0	743.3	8,772.3	193,035.2	
		B-2-4	(F3D)	182,312.8	717.9	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	734.1	696.0	743.3	8,770.3	191,083.1	
		B-2-5	(F3E)	179,163.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	179,163.6
		B-2-6	(F3F)	179,574.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	179,574.1
		B-2-7	(F3G)	184,202.9	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	734.2	696.0	742.5	8,771.7	192,974.6	
		B-2-8	(F3H)	182,965.1	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	734.2	696.0	743.3	8,772.5	191,737.6	
	B-3エアレータ	B-3-1	(R2A)	194,840.2	720.0	744.0	720.0	744.0	744.0	675.9	743.0	720.0	744.0	734.2	696.0	743.4	8,728.5	203,568.7	
		B-3-2	(R2B)	194,349.9	546.0	744.0	720.0	744.0	744.0	675.9	743.0	720.0	744.0	734.2	696.0	743.4	8,554.5	202,904.4	
		B-3-3	(R2C)	185,605.5	720.0	744.0	720.0	744.0	744.0	675.7	743.0	720.0	744.0	734.2	696.0	743.4	8,728.3	194,333.8	
		B-3-4	(R2D)	188,971.0	720.0	744.0	720.0	744.0	744.0	675.9	743.0	720.0	744.0	733.7	696.0	743.4	8,728.0	197,699.0	
		B-3-5	(R2E)	187,042.7	0.0	0.0	0.0	0.0	0.0	4.8	743.0	0.0	0.0	0.0	0.0	0.0	747.8	187,790.5	
		B-3-6	(R2F)	187,829.4	0.0	0.0	0.0	0.0	0.0	3.0	10.0	0.0	0.0	0.0	0.0	0.0	13.0	187,842.4	
		B-3-7	(R2G)	192,427.7	720.0	744.0	720.0	744.0	744.0	676.0	10.0	720.0	744.0	734.2	696.0	743.4	7,995.6	200,423.3	
		B-3-8	(R2H)	193,313.5	720.0	744.0	720.0	744.0	744.0	676.0	743.0	720.0	744.0	734.2	696.0	743.4	8,728.6	202,042.1	
	B-4エアレータ	B-4-1	(F4A)	172,613.7	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	734.2	696.0	743.3	8,772.5	181,386.2	
		B-4-2	(F4B)	170,969.0	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	734.2	696.0	743.3	8,772.5	179,741.5	
		B-4-3	(F4C)	172,753.1	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	734.2	696.0	743.3	8,772.5	181,525.6	
		B-4-4	(F4D)	171,967.5	703.5	739.4	720.0	737.6	744.0	720.0	740.4	720.0	744.0	725.5	696.0	716.6	8,707.0	180,674.5	
		B-4-5	(F4E)	170,952.4	0.0	0.0	0.0	0.0	0.0	0.0	10.1	0.0	0.0	0.0	0.0	0.0	10.1	170,962.5	
		B-4-6	(F4F)	172,141.8	720.0	744.0	713.7	721.1	744.0	720.0	743.0	720.0	744.0	734.2	696.0	743.3	8,743.3	180,885.1	
		B-4-7	(F4G)	166,539.0	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	734.2	696.0	743.3	8,772.5	175,311.5	
		B-4-8	(F4H)	172,059.1	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	734.2	696.0	743.3	8,772.5	180,831.6	

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計	
第1送風機棟 B系 エアタン設備 (C-C-C3)	B-5エアレータ	B-5-1	(F5A)	170,061.2	720.0	744.0	720.0	744.0	744.0	720.0	743.1	720.0	744.0	734.2	696.0	743.3	8,772.6	178,833.8	
		B-5-2	(F5B)	169,855.9	720.0	744.0	720.0	744.0	744.0	720.0	743.1	720.0	744.0	734.2	696.0	743.3	8,772.6	178,628.5	
		B-5-3	(F5C)	169,134.2	720.0	744.0	720.0	744.0	744.0	720.0	743.1	720.0	744.0	734.2	696.0	743.3	8,772.6	177,906.8	
		B-5-4	(F5D)	170,127.4	720.0	744.0	720.0	737.7	744.0	720.0	743.1	720.0	744.0	645.7	696.0	743.3	8,677.8	178,805.2	
		B-5-5	(F5E)	169,037.9	0.0	0.0	0.0	0.0	0.0	0.0	10.0	0.0	0.0	0.0	0.0	0.0	0.0	10.0	169,047.9
		B-5-6	(F5F)	166,266.1	720.0	744.0	720.0	721.2	744.0	720.0	743.1	720.0	744.0	734.1	696.0	743.3	8,749.7	175,015.8	
		B-5-7	(F5G)	169,513.4	720.0	744.0	720.0	744.0	744.0	720.0	743.1	720.0	744.0	734.1	696.0	743.3	8,772.5	178,285.9	
		B-5-8	(F5H)	167,993.2	720.0	744.0	720.0	744.0	744.0	720.0	743.1	720.0	744.0	734.1	696.0	743.3	8,772.5	176,765.7	
	B-6エアレータ	B-6-1	(R4A)	172,381.6	720.0	744.0	720.0	744.0	744.0	720.0	743.1	720.0	744.0	733.8	696.0	743.4	8,772.3	181,153.9	
		B-6-2	(R4B)	166,395.4	720.0	744.0	523.5	744.0	744.0	720.0	743.1	720.0	744.0	734.2	696.0	743.4	8,576.2	174,971.6	
		B-6-3	(R4C)	172,826.8	720.0	744.0	720.0	744.0	744.0	720.0	743.1	720.0	744.0	734.2	696.0	743.4	8,772.7	181,599.5	
		B-6-4	(R4D)	172,455.1	720.0	744.0	720.0	737.7	744.0	720.0	743.1	720.0	744.0	734.2	696.0	743.4	8,766.4	181,221.5	
		B-6-5	(R4E)	170,640.8	0.0	0.0	0.0	0.0	0.0	0.0	10.0	0.0	0.0	0.0	0.0	0.0	10.0	170,650.8	
		B-6-6	(R4F)	172,831.9	720.0	744.0	720.0	721.2	744.0	720.0	743.1	720.0	744.0	734.2	696.0	743.4	8,749.9	181,581.8	
		B-6-7	(R4G)	171,497.5	720.0	744.0	720.0	744.0	744.0	720.0	743.1	720.0	744.0	734.2	696.0	743.4	8,772.7	180,270.2	
B-6-8		(R4H)	171,909.5	720.0	744.0	720.0	744.0	744.0	720.0	743.1	720.0	744.0	734.2	696.0	743.4	8,772.7	180,682.2		
エアタン管廊床 排水ポンプ	B-1	(R3A)	237.9	0.4	0.3	0.9	2.1	1.1	0.7	0.2	0.5	0.5	0.1	0.4	0.2	7.4	245.3		
	B-2	(R3B)	155.2	0.5	0.3	0.9	2.2	1.0	0.6	0.2	0.4	0.3	0.2	0.2	0.1	6.9	162.1		
第1送風機棟 A系 最終沈殿池設備 (C-C-E1)	汚泥掻寄機	A-1-1	(2A)	242,370.7	719.0	743.1	719.2	742.4	742.1	717.3	742.6	720.0	738.6	733.1	694.7	731.1	8,743.2	251,113.9	
		A-1-2	(2B)	245,175.6	713.7	743.2	719.0	742.4	742.1	717.0	742.6	720.0	731.9	586.1	679.1	706.4	8,543.5	253,719.1	
		A-2	(2C)	241,206.8	718.9	743.3	719.0	742.3	742.1	717.0	742.6	720.0	738.7	733.0	694.4	730.9	8,742.2	249,949.0	
		A-3	(6B)	232,246.4	704.9	735.2	679.9	742.7	742.0	718.6	743.0	720.0	739.5	491.8	157.8	424.7	7,600.1	239,846.5	
		A-4	(7B)	169,327.6	717.8	743.8	719.3	742.8	742.9	718.6	743.0	720.0	739.8	732.2	694.9	743.0	8,758.1	178,085.7	
		A-5	(7C)	175,303.2	719.8	743.8	719.4	742.9	743.2	718.8	743.0	720.0	740.1	733.8	695.7	743.5	8,764.0	184,067.2	
		A-6	(7D)	176,697.7	719.7	743.8	719.4	742.8	744.0	718.8	743.0	720.0	740.1	733.9	694.2	743.5	8,763.2	185,460.9	

No. 7 (単位:時間)

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計	
第1送風機棟 A系 最終沈殿池設備 (C-C-E1)	返送汚泥ポンプ	A-1	(3A)	136,900.1	667.1	195.4	30.0	710.9	118.1	0.0	691.3	120.6	40.9	612.5	49.0	358.9	3,594.7	140,494.8	
		A-2	(3B)	165,707.3	45.6	568.4	57.8	54.4	644.1	719.2	55.4	621.6	72.2	21.4	482.9	0.5	3,343.5	169,050.8	
		A-3	(3C)	170,501.6	51.3	0.1	669.0	52.3	18.8	69.4	7.3	43.2	668.2	121.4	190.4	400.4	2,291.8	172,793.4	
		A-4	(9E)	167,108.6	720.0	744.0	719.8	743.0	744.0	719.2	743.4	720.0	740.4	656.6	695.9	743.2	8,689.5	175,798.1	
		A-5	(9F)	160,118.8	720.0	744.0	719.8	743.5	744.0	719.2	743.4	720.0	740.3	734.0	696.0	743.7	8,767.9	168,886.7	
	スカム分離機	A-1	(2D)	53,276.0	61.5	57.2	54.4	59.0	74.6	61.7	64.9	57.4	58.2	56.0	62.4	62.6	729.9	54,005.9	
	スカム移送ポンプ	A-1	(2E)	24,892.1	3.9	43.5	3.5	55.0	10.1	42.5	4.2	47.6	5.8	45.8	4.1	56.4	322.4	25,214.5	
		A-2	(2F)	25,025.5	56.2	12.6	49.1	3.4	63.0	18.0	59.1	7.2	50.9	8.4	57.1	4.3	389.3	25,414.8	
	余剰汚泥ポンプ	A-1	(4B)	40,896.5	11.8	124.7	11.6	125.3	19.0	0.0	46.7	105.7	13.0	100.8	7.7	103.3	669.6	41,566.1	
		A-2	(4C)	43,592.0	123.1	31.2	111.0	8.1	101.7	91.1	68.1	16.6	92.7	16.9	81.0	6.1	747.6	44,339.6	
		A-3	(9C)	15,839.8	74.9	92.8	79.6	78.2	75.5	59.2	65.1	59.4	60.7	60.9	56.7	65.8	828.8	16,668.6	
		A-4	(9D)	15,581.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	15,581.1	
	消泡水ポンプ	A-1	(5C)	103,629.8	182.3	188.8	94.6	163.6	183.4	175.8	193.9	57.4	0.0	0.0	1.4	0.0	1,241.2	104,871.0	
		A-2	(5D)	116,953.9	0.0	0.1	80.0	11.7	0.2	0.0	0.0	2.2	0.0	0.0	557.5	721.5	1,373.2	118,327.1	
	管廊床排水ポンプ	管理棟	(4E)	952.5	0.2	0.3	1.0	3.2	0.4	0.4	0.1	0.6	0.1	0.2	0.2	0.3	7.0	959.5	
		終沈A-1	(4F)	782.5	0.3	0.9	0.8	0.6	2.3	1.0	4.1	0.7	0.1	0.2	0.8	7.5	19.3	801.8	
		終沈A-2	(9B)	291.4	0.8	0.3	0.1	0.6	0.0	0.2	0.6	0.1	0.2	0.2	0.1	0.1	3.3	294.7	
		濃縮A-1	(4G)	184.7	0.3	0.0	0.5	0.9	0.4	0.2	0.1	0.0	0.0	0.2	0.2	0.2	3.0	187.7	
		濃縮A-2	(4H)	1,089.3	1.0	0.5	0.3	0.9	0.8	0.7	0.7	1.1	2.1	3.4	1.6	4.8	17.9	1,107.2	
	放流水消毒設備	A系次亜塩注入ポンプ	No-1		40,053.7	-	-	-	-	-	-	-	-	-	-	-	-	0.0	40,053.7
No-2				63,307.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	63,307.6
No-3				66,540.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	66,540.3
B系次亜塩注入ポンプ		No-4		51,686.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	51,686.8
		No-5		39,011.2	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	39,011.2
		No-6		44,626.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	44,626.5

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計
第1送風機棟 B系 最終沈殿池設備 (C-C-E2)	汚泥掻寄機	B-1	(F2B)	192,727.7	719.5	743.8	719.0	742.9	743.1	718.4	742.7	720.0	739.8	733.5	695.9	743.2	8,761.8	201,489.5
		B-2	(F2C)	194,673.4	719.5	743.8	719.0	742.8	744.0	718.4	742.7	720.0	739.9	733.7	696.0	743.3	8,763.1	203,436.5
		B-3	(F2D)	194,401.1	719.5	744.0	719.3	743.0	743.1	718.2	742.9	720.0	739.8	733.8	696.0	743.3	8,762.9	203,164.0
		B-4	(F4B)	170,977.2	719.5	744.0	719.1	742.9	744.0	718.9	742.9	720.0	739.7	733.6	696.0	741.4	8,762.0	179,739.2
		B-5	(F4C)	171,294.0	719.5	743.5	719.4	742.8	743.3	718.8	742.9	720.0	739.9	733.7	696.0	743.2	8,763.0	180,057.0
		B-6	(F4D)	171,233.1	719.5	743.5	719.4	742.7	744.0	719.0	742.9	720.0	739.9	733.8	696.0	743.3	8,764.0	179,997.1
	返送汚泥ポンプ	B-1	(F2E)	190,032.0	720.0	744.0	719.7	743.6	744.0	719.4	742.9	720.0	740.1	734.0	696.0	743.0	8,766.7	198,798.7
		B-2	(F2F)	183,987.9	720.0	743.7	719.7	743.6	744.0	719.4	743.2	720.0	740.1	733.6	694.9	743.2	8,765.4	192,753.3
		B-3	(F4E)	169,055.4	720.0	744.0	719.8	743.6	744.0	719.3	743.2	720.0	740.0	734.0	696.0	743.6	8,767.5	177,822.9
		B-4	(F4F)	165,914.3	720.0	743.9	719.8	743.6	744.0	719.4	743.2	720.0	740.0	733.0	696.0	743.6	8,766.5	174,680.8
	余剰汚泥ポンプ	B-1	(F3B)	23,373.9	10.4	148.1	13.1	191.9	28.7	0.0	64.8	131.2	15.3	123.1	10.2	152.3	889.1	24,263.0
		B-2	(F3C)	26,912.4	148.6	45.1	166.2	13.7	179.9	170.3	92.4	21.7	142.7	26.0	130.0	9.9	1,146.5	28,058.9
	消泡水ポンプ	B-1	(F3E)	70,480.9	177.5	182.3	164.5	156.0	176.7	159.4	185.2	188.4	183.9	175.7	170.0	182.9	2,102.5	72,583.4
		B-2	(F3F)	67,018.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	67,018.6
	スカム移送ポンプ	B-1	(R2A)	35,874.5	26.2	269.1	25.1	13.0	0.0	0.0	0.0	276.1	35.3	291.8	21.5	321.0	1,279.1	37,153.6
		B-2	(R2B)	40,140.4	317.0	85.3	273.9	220.8	137.9	295.5	349.7	51.2	334.3	61.3	317.1	26.5	2,470.5	42,610.9
	スカム分離機	B-1	(R2E)	70,508.0	321.9	314.6	280.4	246.8	132.2	269.8	312.5	299.9	347.2	327.9	315.5	325.9	3,494.6	74,002.6
	管廊床排水ポンプ	B-1	(R2G)	139.2	0.3	0.1	0.6	1.5	0.6	0.4	0.2	0.3	0.2	0.1	0.3	0.1	4.7	143.9
		B-2	(R2H)	311.9	0.2	0.1	0.4	0.5	0.2	0.2	0.1	0.1	0.1	0.2	0.1	0.1	2.3	314.2
	井水棟設備	深井戸揚水ポンプ	No.-1		78,524.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
No.-2				51,387.0	40.6	137.6	95.8	55.5	110.5	63.9	35.8	30.4	37.8	32.3	29.2	37.0	706.4	52,093.4
No.-3				44,137.8	26.7	69.4	376.5	628.6	647.6	619.0	32.7	27.9	34.5	30.3	27.6	28.8	2,549.6	46,687.4
送水ポンプ		No.-1		99,981.5	359.6	0.0	0.0	0.0	0.0	455.9	51.2	0.0	361.0	624.8	75.6	0.0	1,928.1	101,909.6
		No.-2		104,230.5	0.0	0.0	0.0	0.0	0.0	0.0	691.0	217.8	6.2	0.0	619.8	73.1	1,607.9	105,838.4
		No.-3		93,273.5	358.4	743.7	719.7	742.5	744.0	264.1	0.0	506.3	381.4	119.3	0.0	654.0	5,233.4	98,506.9
次亜塩注入ポンプ		No.-1		36,196.2	12.1	13.6	14.2	13.7	15.5	13.4	14.5	4.0	16.5	15.2	0.8	12.8	146.3	36,342.5
		No.-2		20,205.7	13.8	13.7	12.5	12.7	12.4	13.6	1.0	10.4	21.1	1.8	13.4	14.0	140.4	20,346.1
		No.-3		20,188.2	0.8	0.0	0.0	0.0	0.0	0.9	14.5	13.1	1.9	13.2	13.8	1.8	60.0	20,248.2

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計
井水棟設備	急速ろ過器逆洗ポンプ	No-1		850.5	0.0	0.0	0.0	0.0	0.1	0.4	0.2	0.6	0.0	0.8	0.0	0.5	2.6	853.1
		No-2		579.2	0.5	0.5	0.7	0.2	0.5	0.5	0.6	0.2	1.1	0.0	0.8	0.0	5.6	584.8
	急速ろ過器	No-1		47,361.0	13.0	13.5	14.2	13.5	15.6	13.4	14.6	14.6	20.0	15.2	14.3	13.7	175.6	47,536.6
		No-2		31,465.8	13.8	13.6	12.5	12.6	12.4	14.4	15.7	13.3	19.7	15.1	13.9	15.1	172.1	31,637.9
A・B 系重力濃縮設備 (F-C-P1)	し渣破碎機	A-1	(5D)	34,586.3	181.1	220.7	331.5	356.2	310.8	278.0	305.2	266.3	317.2	366.5	219.1	417.8	3,570.4	38,156.7
		A-2	(5C)	32,211.1	250.2	223.8	105.0	92.1	147.7	245.0	248.4	266.0	288.0	290.3	407.8	166.6	2,730.9	34,942.0
	濃縮汚泥掻寄機	A-1	(2C)	212,031.1	717.6	741.0	716.2	740.6	739.1	713.7	734.8	718.2	737.9	737.4	689.5	737.6	8,723.6	220,754.7
		A-2	(3C)	184,442.0	717.6	741.0	716.2	740.2	739.1	715.3	734.8	719.6	737.1	735.7	688.6	738.7	8,723.9	193,165.9
	濃縮汚泥引抜ポンプ	A-1	(2E)	30,659.1	80.0	193.7	21.6	192.7	18.5	177.1	23.9	201.8	13.7	258.0	133.6	195.7	1,510.3	32,169.4
		A-2	(2F)	32,854.3	183.0	34.1	208.2	7.1	187.9	13.0	228.8	36.1	270.6	28.2	277.0	190.5	1,664.5	34,518.8
	床排水ポンプ	A系	(2G)	3,214.4	16.7	17.2	17.6	17.4	16.2	16.0	18.6	16.7	18.7	17.4	15.8	10.9	199.2	3,413.6
	汚泥分離機	B-1	(3B)	16,071.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16,071.6
	し渣脱水機	B-1	(3H)	16,481.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16,481.5
	濃縮汚泥掻寄機	B-1	(4A)	133,119.5	511.0	740.5	708.5	740.6	739.9	715.8	738.8	719.8	738.6	739.1	690.8	739.7	8,523.1	141,642.6
		B-2	(4B)	104,219.3	715.8	740.5	708.5	740.6	739.9	715.8	738.1	718.9	737.9	738.1	689.4	738.6	8,722.1	112,941.4
	濃縮汚泥引抜ポンプ	B-1	(4D)	3.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.6
し渣破碎機	B-1	(5E)	58,184.3	500.8	489.1	440.2	453.9	526.4	478.7	439.2	420.1	461.2	477.2	450.9	470.9	5,608.6	63,792.9	
C系 重力濃縮設備 (F2-C-P1)	濃縮汚泥引抜ポンプ	C-1	(F1C)	2,472.9	11.4	78.3	5.2	76.9	8.8	72.6	5.3	66.5	2.1	69.1	2.9	74.8	473.9	2,946.8
		C-2	(F1D)	2,403.2	68.6	2.6	70.3	2.6	79.5	5.1	75.8	17.9	78.9	12.9	76.2	7.0	497.4	2,900.6
	床排水ポンプ	No. 1	(R1E)	470.5	7.5	3.8	1.0	1.6	10.9	5.0	5.1	6.4	4.7	7.3	6.5	3.6	63.4	533.9
		No. 2	(R1F)	512.8	7.6	3.9	1.0	1.4	14.9	5.2	5.2	6.5	4.9	7.6	6.7	3.7	68.6	581.4
				-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				-	-	-	-	-	-	-	-	-	-	-	-	-	-	
A系 ベルト濃縮設備	A系汚泥スクリーン		(2A)	81,845.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	81,845.5
	余剰汚泥供給ポンプ	No. 1	CRT	22,819.7	179.2	635.6	34.2	732.7	60.1	678.9	39.8	637.4	14.9	189.4	2.9	0.0	3,205.1	26,024.8
		No. 2	CRT	20,586.0	540.8	104.5	684.9	9.8	683.9	40.4	695.1	82.6	719.1	551.0	684.1	742.3	5,538.5	26,124.5
	濃縮汚泥移送ポンプ	No. 1	CRT	3,621.3	110.1	108.9	111.2	110.6	116.5	41.2	0.1	92.8	2.2	97.5	4.5	0.0	795.6	4,416.9
No. 2		CRT	2,266.9	0.2	0.0	0.0	0.3	0.0	75.8	120.9	21.6	123.3	16.4	97.1	108.5	564.1	2,831.0	

No. 10 (単位:時間)

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計
A系 ベルト濃縮設備	高分子凝集剤 定量供給機	No. 1	CRT	806.1	14.7	12.9	13.0	12.1	11.2	11.2	14.0	14.6	17.3	18.3	19.6	35.0	193.9	1,000.0
		No. 2	CRT	805.7	14.7	12.9	13.0	12.1	11.2	11.4	13.8	14.6	17.5	18.3	19.8	34.6	193.9	999.6
	高分子凝集剤 供給ポンプ	No. 1	CRT	22,142.0	179.3	635.6	259.9	742.5	743.9	719.3	58.4	637.4	14.9	653.0	17.9	0.0	4,662.1	26,804.1
		No. 2	CRT	21,970.2	540.7	104.5	459.1	0.0	0.0	0.0	676.4	82.6	719.1	87.4	669.1	742.3	4,081.2	26,051.4
	濃縮用空気圧縮機	No. 1	CRT	4,142.3	64.0	69.7	65.5	61.2	64.4	64.7	64.0	55.3	67.1	53.2	53.3	55.7	738.1	4,880.4
		No. 2	CRT	4,100.7	62.6	69.6	65.4	64.7	62.5	62.4	67.8	65.8	62.5	62.0	52.7	55.1	753.1	4,853.8
	補機室床排水ポンプ	A-1	(5B)	948.9	2.2	2.1	2.3	2.1	1.9	3.1	2.6	2.6	3.2	3.1	2.9	3.0	31.1	980.0
		A-2	(5C)	648.6	1.7	2.0	2.8	2.8	2.3	2.6	2.9	3.7	3.1	3.1	2.9	2.9	32.8	681.4
B系 加圧浮上 濃縮設備 (F-C-J1)	余剰汚泥供給ポンプ	B-1	(F5A)	94,993.4	720.0	744.0	47.5	700.1	744.0	719.3	546.7	0.0	376.7	215.1	635.8	2.2	5,451.4	100,444.8
		B-2	(F6A)	51,388.7	195.5	0.0	672.1	28.3	0.0	547.6	53.3	365.8	360.6	331.4	683.8	7.8	3,246.2	54,634.9
		B-3	(F7A)	86,081.8	525.2	744.0	719.6	733.2	744.0	171.7	498.3	357.9	21.3	50.0	0.0	0.0	4,565.2	90,647.0
	加圧水循環ポンプ	B-1	(R2C)	92,511.8	720.0	744.0	47.5	707.4	744.0	719.3	546.8	0.1	376.9	215.2	636.0	2.3	5,459.5	97,971.3
		B-2	(R3C)	52,562.3	195.5	0.0	672.2	28.1	0.0	547.7	53.1	365.7	360.6	331.5	683.8	7.9	3,246.1	55,808.4
		B-3	(R4C)	85,592.2	525.2	744.0	719.7	733.1	744.0	171.6	498.5	357.5	21.2	220.1	0.0	0.0	4,734.9	90,327.1
	濃縮用空気圧縮機	B-1	(F3G)	14,575.7	96.5	626.4	47.5	712.4	75.7	672.1	498.6	63.3	2.0	296.9	6.3	0.4	3,098.1	17,673.8
		B-2	(F3H)	17,619.0	624.5	118.2	671.8	23.1	668.4	47.2	239.5	0.0	626.9	122.5	648.3	2.3	3,792.7	21,411.7
	沈殿汚泥揺寄機	B-1	(F4D)	133,049.8	720.0	744.0	719.8	744.0	744.0	719.3	742.8	720.0	741.4	743.7	694.7	743.3	8,777.0	141,826.8
		B-2	(F4F)	108,646.6	720.0	744.0	719.8	744.0	744.0	719.3	742.8	720.0	741.3	743.7	694.7	743.4	8,777.0	117,423.6
	フロス移送ポンプ	B-1	(F3B)	8,747.5	15.5	95.1	7.4	111.1	11.9	82.0	5.8	81.3	3.7	85.1	21.1	0.7	520.7	9,268.2
		B-2	(F3C)	9,052.0	91.3	18.7	93.1	2.7	104.6	9.8	90.9	21.0	89.3	15.0	79.5	0.1	616.0	9,668.0
	A系汚泥スクリーン		(F3E)	7,890.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7,890.8
	沈殿汚泥引抜ポンプ		(F3F)	46.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	46.2
	補機室床排水ポンプ	B-1	(F2E)	687.2	2.6	16.7	1.3	19.1	1.9	17.8	1.3	374.9	13.6	1.5	0.0	7.5	458.2	1,145.4
		B-2	(F2F)	769.5	17.1	3.1	17.6	0.6	22.2	1.3	272.2	330.9	158.4	0.0	9.2	0.0	832.6	1,602.1
消化タンク設備 (L-C-Q1)	消化タンク攪拌機	A-1	(F3C)	209,989.9	720.0	744.0	720.0	729.3	740.2	718.8	743.9	720.0	744.0	743.0	687.0	744.0	8,754.2	218,744.1
		A-2	(F3D)	40,047.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	40,047.5
		A-3	(F3E)	165,394.0	719.5	742.1	720.0	728.7	744.0	718.3	743.9	720.0	736.0	742.3	685.2	744.0	8,744.0	174,138.0
		A-4	(F4G)	121,648.2	720.0	743.6	720.0	725.9	727.0	719.3	743.9	720.0	735.8	742.9	687.3	744.0	8,729.7	130,377.9

No. 11 (単位:時間)

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計	
消化タンク設備 (L-C-Q1)	消化管廊床排水ポンプ	No-1 (F2E)		170.7	0.2	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.6	0.0	1.8	172.5	
		No-2 (F2F)		178.8	11.8	19.3	0.0	0.0	56.5	4.8	0.1	0.0	0.0	0.0	0.0	0.0	0.0	92.5	271.3
	雑用水加圧ポンプ	No-1 (F3B)		496.8	0.0	8.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8.9	505.7
	循環汚泥ポンプ	A-1 (R3C)		150,240.3	718.5	117.5	673.0	728.0	742.1	717.8	742.8	720.0	735.7	742.9	687.5	741.4	8,067.2	158,307.5	
		A-2 (R3D)		2,978.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,978.2
		A-3 (R2C)		126,635.8	718.9	743.6	46.2	702.7	743.0	717.0	742.8	720.0	735.6	742.6	382.7	0.0	6,995.1	133,630.9	
		A-4 (R2D)		121,516.4	123.5	625.9	718.5	727.4	533.3	717.8	742.8	720.0	260.2	0.0	305.7	741.3	6,216.4	127,732.8	
A-5 (F3C)		94,708.0	596.2	742.9	718.8	25.2	209.3	0.0	0.0	0.0	474.9	742.3	688.7	741.5	4,939.8	99,647.8			
A系ボイラー設備 (L-C-R1)	重油移送ポンプ	No-1 (F3G)		12.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.3	13.0	
		No-2 (F3H)		12.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	12.5
	消化用空気圧縮機	No-1 (F2C)		3,940.8	6.6	27.5	1.9	29.3	2.8	24.9	2.0	23.8	15.7	27.6	1.0	53.1	216.2	4,157.0	
		No-2 (F2D)		4,000.9	37.4	6.2	28.4	0.8	26.7	1.8	33.7	2.9	18.1	0.0	80.5	4.6	241.1	4,242.0	
	床排水ポンプ		(F2E)	10,396.4	0.3	0.3	0.1	0.7	0.3	0.4	0.3	0.4	0.3	0.2	0.2	0.2	3.7	10,400.1	
	管廊床排水ポンプ		(F2F)	131.8	0.2	0.0	0.2	0.2	0.0	0.2	0.1	0.1	0.2	0.1	0.1	0.1	1.5	133.3	
	A-1 温水ボイラー制御盤	抽気時間		100.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	100.9
		オイル燃焼時間		1,166.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.2	1,167.1
		ガス燃焼時間		165,126.3	719.3	687.2	26.3	1.5	0.0	0.0	694.4	716.6	737.8	730.4	598.1	589.8	5,501.4	170,627.7	
	A-2 温水ボイラー制御盤	抽気時間		12.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4	1.0	0.0	0.0	1.4	14.1	
オイル燃焼時間			6.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.0	0.0	0.3	6.5		
ガス燃焼時間			54,562.7	515.3	288.6	699.9	674.6	543.1	696.4	308.4	356.0	506.8	512.5	423.2	261.0	5,785.8	60,348.5		
余剰ガス 燃焼装置	電気室電源盤内	燃焼時間		46,376.0	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	3.6	46,379.6	
	ボイラー設備盤 R22A内取付	ガス燃焼用送風機		47,953.8	0.5	1.0	0.6	0.8	0.5	0.5	0.6	0.5	0.6	0.7	0.6	0.5	7.4	47,961.2	
		ガス昇圧	No-1-1	23,378.3	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.2	0.2	0.2	0.2	0.2	2.5	23,380.8	
		ブロウ	No-1-2	23,548.7	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.2	0.2	2.5	23,551.2	
脱水機設備 (H-C-K1)	脱水用空気圧縮機	A-1 (2A)		47,030.8	436.8	19.0	17.5	388.1	38.1	331.4	27.4	27.7	391.4	408.6	14.1	428.8	2,528.9	49,559.7	
		A-2 (2B)		44,653.0	377.9	476.3	369.7	398.9	384.3	23.8	134.1	370.6	15.1	348.4	357.4	16.5	3,273.0	47,926.0	
		A-3 (10C)		41,865.4	59.3	458.3	387.3	10.7	346.4	355.3	293.4	398.3	406.6	60.2	343.3	445.2	3,564.3	45,429.7	
		B-1 (F5E)		797.2	6.7	7.2	316.4	13.9	7.5	7.8	8.7	8.5	9.5	9.8	12.6	8.3	416.9	1,214.1	
		B-2 (F5F)		948.6	6.7	7.2	316.4	13.9	7.5	7.8	8.7	8.5	9.5	9.8	12.6	8.3	416.9	1,365.5	

区分	機器名称	機器番号	26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計
脱水機設備 (H-C-K1)	補機室床排水ポンプ	A-1 (2E)	212.9	0.4	0.3	0.4	0.5	0.6	0.3	0.2	0.3	0.2	0.4	0.4	0.2	4.2	217.1
		A-2 (2F)	193.0	0.4	0.3	0.4	0.4	0.5	0.3	0.2	0.3	0.2	0.3	0.3	0.2	3.8	196.8
		A-3 (2G)	2,923.1	11.5	10.5	10.6	8.1	7.0	6.2	7.3	7.9	7.1	6.9	5.6	4.7	93.4	3,016.5
		B-1 (R5B)	51.7	0.1	1.3	0.1	1.6	0.1	0.8	0.1	0.5	0.0	0.8	0.0	0.5	5.9	57.6
		B-2 (R5C)	51.1	1.5	0.1	1.4	0.0	0.8	0.0	0.7	0.0	0.8	0.0	0.8	0.0	6.1	57.2
	ろ布洗淨ポンプ	A-1 (3C)	54,503.1	611.1	471.8	515.4	606.1	582.7	293.7	32.3	0.0	593.9	643.4	548.3	667.0	5,565.7	60,068.8
		A-2 (3D)	53,353.9	27.7	214.2	106.0	87.2	112.7	33.2	594.9	629.1	433.4	459.3	397.7	404.1	3,499.5	56,853.4
		A-3 (10F)	43,192.2	0.1	14.3	81.2	0.0	2.5	370.9	153.8	189.0	6.5	0.0	0.0	0.0	818.3	44,010.5
		B-1 (R4C)	5,574.2	0.0	1.7	0.0	1.8	0.1	2.2	0.0	6.2	7.6	74.6	0.0	145.2	239.4	5,813.6
		B-2 (R4D)	6,372.0	4.7	0.0	0.3	0.0	2.0	0.0	5.2	0.0	29.2	0.0	207.7	3.9	253.0	6,625.0
	ろ布駆動装置	A-1 (5B)	76,802.9	275.1	232.0	358.1	344.4	344.6	316.8	392.7	455.0	571.0	500.0	153.5	0.3	3,943.5	80,746.4
		A-2 (6B)	68,908.5	278.3	259.5	362.0	345.2	343.6	315.4	402.1	458.0	533.3	463.6	156.6	47.5	3,965.1	72,873.6
		A-3 (7C)	61,551.6	284.4	255.9	359.0	340.3	340.1	313.9	403.8	450.4	563.0	612.8	434.0	590.1	4,947.7	66,499.3
		A-4 (8C)	61,950.2	350.3	432.8	337.0	344.7	359.1	339.5	368.6	380.8	537.5	504.2	484.2	496.4	4,935.1	66,885.3
		A-5 (R2F)	46,943.5	353.1	433.9	337.9	347.1	347.6	344.5	359.3	118.0	0.0	196.4	496.4	650.9	3,985.1	50,928.6
		A-6 (F2D)	40,514.1	347.7	428.2	338.3	338.0	343.2	346.9	367.6	385.1	38.3	64.1	480.6	611.2	4,089.2	44,603.3
		B-1 (F4A)	11,831.6	4.7	1.7	0.0	1.8	2.0	2.2	5.2	11.5	36.8	74.6	207.7	149.2	497.4	12,329.0
	脱水汚泥供給ポンプ	A-1 (5E)	67,597.3	248.0	209.7	327.2	314.7	306.3	278.5	348.1	419.0	517.5	452.2	124.3	0.0	3,545.5	71,142.8
		A-2 (6E)	61,002.5	247.1	224.7	321.4	314.7	298.7	282.0	342.1	416.2	448.4	402.4	111.4	20.4	3,429.5	64,432.0
		A-3 (7D)	54,313.9	250.0	225.7	327.4	309.4	305.7	282.0	346.6	381.9	510.1	558.5	375.6	513.2	4,386.1	58,700.0
		A-4 (8D)	55,135.9	318.7	391.9	307.7	310.8	319.7	308.4	337.1	347.8	491.0	447.4	421.9	421.1	4,423.5	59,559.4
		A-5 (R3A)	41,467.6	319.8	392.0	306.2	313.3	314.6	308.3	321.7	105.1	0.0	168.0	401.7	541.4	3,492.1	44,959.7
		A-6 (R4A)	36,045.9	317.9	388.3	305.0	304.1	309.1	304.7	330.3	326.7	31.3	37.0	413.1	512.3	3,579.8	39,625.7
		B-1 (R7A)	10,263.0	3.9	0.9	0.0	0.7	1.8	0.8	4.4	5.4	32.3	66.1	184.8	133.4	434.5	10,697.5
	凝集剤注入ポンプ	A-1 (5F)	67,531.2	248.0	209.7	327.2	314.7	306.3	278.5	348.1	419.0	517.5	452.2	124.4	0.0	3,545.6	71,076.8
		A-2 (6F)	60,846.0	247.1	224.7	321.4	314.7	298.7	282.0	342.1	416.2	448.4	402.4	111.4	20.4	3,429.5	64,275.5
		A-3 (7E)	54,384.0	250.0	225.7	327.4	309.4	305.7	282.0	346.6	381.9	510.1	558.5	375.6	513.2	4,386.1	58,770.1
		A-4 (8E)	55,167.3	318.7	391.9	307.7	310.8	319.7	308.4	337.1	347.8	491.0	447.4	421.9	421.1	4,423.5	59,590.8

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計	
脱水機設備 (H-C-K1)	凝集剤注入ポンプ	A-5 (F3A)		41,496.3	319.8	392.0	306.2	313.3	314.6	308.3	321.7	105.1	0.0	168.0	401.6	541.4	3,492.0	44,988.3	
		A-6 (F4A)		36,081.1	317.9	388.3	305.0	304.1	309.1	304.0	330.3	326.7	31.3	36.4	410.6	512.3	3,576.0	39,657.1	
		B-1 (F7A)		10,280.8	3.9	0.9	0.0	0.7	1.8	0.8	4.4	5.4	32.3	66.1	184.8	133.4	434.5	10,715.3	
	高架水槽揚水ポンプ	A-1 (4A)		3,563.2	15.3	2.5	0.0	16.6	1.4	0.0	13.1	0.9	0.0	11.6	0.5	0.0	61.9	3,625.1	
		A-2 (5A)		3,518.0	0.0	15.3	1.1	0.0	16.2	1.3	0.0	14.7	0.6	0.0	11.1	2.0	62.3	3,580.3	
		A-3 (6A)		3,672.8	2.4	0.0	14.5	0.6	0.0	14.4	1.1	0.0	14.0	1.9	0.0	57.3	106.2	3,779.0	
	高圧ろ布洗ポンプ	B-1 (R5D)		8,295.5	34.2	32.9	0.0	42.4	0.0	0.0	0.0	35.9	0.0	0.3	0.0	5.1	150.8	8,446.3	
		B-2 (R6E)		8,086.1	19.8	0.0	30.1	0.0	71.1	24.0	31.5	0.0	0.0	0.0	19.2	0.0	195.7	8,281.8	
	ケーキ圧送ポンプ	B-1 (F2A)		3,056.5	1.2	0.2	0.0	0.3	0.0	0.3	1.3	1.3	9.5	25.6	63.4	45.2	148.3	3,204.8	
第2ポンプ棟 放流ポンプ設備 (E-C-O1)	放流ポンプ (高圧)	No.-1 (K-H-01)		793.9	0.3	0.1	0.1	25.8	0.1	6.9	0.2	0.1	0.3	0.1	0.2	0.1	34.3	828.2	
		No.-2 (K-H-02)		255.4	0.2	0.1	0.1	15.7	0.2	5.7	0.2	0.2	0.2	0.1	0.2	0.1	23.0	278.4	
		No.-3 (K-H-03)		125.4	0.1	0.3	0.1	8.9	0.2	0.1	0.1	0.2	0.1	0.1	0.2	0.0	10.4	135.8	
		No.-4 (K-H-04)		104.6	0.1	0.3	0.2	7.6	0.1	0.3	0.2	0.2	0.1	0.1	0.2	0.0	9.4	114.0	
	ポンプ室床排水ポンプ	No.-1 (2E)		15.0	0.0	0.0	0.1	0.1	0.2	0.0	0.1	0.0	0.1	0.1	0.1	0.1	0.1	0.9	15.9
		No.-2 (3E)		17.0	0.1	0.1	0.1	0.1	0.2	0.0	0.1	0.0	0.1	0.1	0.1	0.1	1.1	18.1	
	放流ポンプ 冷却水ポンプ	No.-1 (2F)		338.7	0.0	0.0	0.0	25.8	0.0	0.3	0.8	0.0	0.0	0.0	0.5	0.0	27.4	366.1	
		No.-2 (3F)		421.7	0.9	0.6	0.8	6.9	0.8	6.9	0.0	0.8	0.7	0.5	0.0	0.5	19.4	441.1	
		予備 (2G)		0.0	-	-	-	-	-	-	-	-	-	-	-	0	0.0	0.0	
		予備 (3G)		0.0	-	-	-	-	-	-	-	-	-	-	-	0	0.0	0.0	
放流水計測室 (E-C-H1)	放流ポンプ (既設)	No.-1 (4A)		449.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	449.6	
		No.-2 (4B)		551.3	0.0	0.0	0.0	0.8	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.9	552.2	
		No.-3 (4C)		238.8	0.0	0.0	0.0	0.8	0.0	0.6	0.0	0.0	0.0	0.0	0.0	0.0	1.4	240.2	
A系 急速ろ過設備 (M-C-S1)	汚泥処理送水ポンプ	No.-1 (R6A)		32,171.7	431.3	110.7	1.6	278.2	454.0	170.8	14.6	74.5	561.3	99.4	25.2	107.5	2,329.1	34,500.8	
		No.-2 (R6B)		25,425.6	174.9	435.6	477.8	9.1	193.6	375.1	39.9	5.2	312.0	569.8	52.4	11.3	2,656.7	28,082.3	
		No.-3 (R6C)		26,007.4	7.6	128.1	244.2	44.8	3.2	166.4	533.1	487.7	14.7	312.9	574.5	540.2	3,057.4	29,064.8	
		No.-4 (R3A)		9,740.0	1.0	1.4	12.9	549.2	71.0	2.7	316.4	392.5	143.4	15.2	298.8	477.4	2,281.9	12,021.9	
	逆洗排水ポンプ	A-1 (R4D)		29,199.2	341.7	85.5	137.2	339.5	48.2	87.8	347.5	133.3	155.0	301.3	183.9	138.7	2,299.6	31,498.8	
		A-2 (R5D)		26,233.4	155.9	316.2	34.5	139.7	331.1	126.1	133.8	233.0	0.0	139.9	241.3	35.2	1,886.7	28,120.1	
		A-3 (R6D)		25,124.9	8.5	114.9	334.1	15.4	121.7	272.9	24.3	135.7	365.8	81.0	65.2	353.4	1,892.9	27,017.8	

区分	機器名称	機器番号	26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計
A系 急速ろ過設備 (M-C-S1)	ポンプ室床排水ポンプ	No-1 (R3B)	12.2	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.0	0.0	0.2	0.1	0.0	0.7	12.9
		No-2 (R3C)	7.2	0.0	0.0	0.1	0.1	0.1	0.1	0.2	0.0	0.0	0.0	0.1	0.0	0.7	7.9
	急ろ管廊床排水ポンプ	A-1 (R3D)	7.0	0.0	0.0	0.0	0.1	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.4	7.4
		A-2 (R3E)	108.5	0.5	0.4	0.3	0.8	0.5	0.5	0.3	0.2	0.3	0.4	0.3	0.3	4.8	113.3
		A-3 (R11B)	11.7	0.0	0.1	0.1	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	12.2
		A-4 (R11C)	9.6	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.5	10.1
	バルブピット床排水ポンプ	A-1 (R3F)	674.0	12.5	15.1	36.1	6.9	5.0	4.6	2.7	1.6	8.5	3.3	3.3	3.1	102.7	776.7
	連絡管廊床排水ポンプ	No-1 (R3G)	1,311.6	5.6	5.4	5.2	5.6	5.9	5.9	6.3	6.5	9.4	6.4	5.8	6.0	74.0	1,385.6
		No-2 (R3H)	17.3	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	17.4
	空洗プロワ	A-1 (F5B)	2,121.2	1.8	21.3	2.5	24.8	3.5	16.7	1.8	18.6	2.6	22.9	1.8	24.5	142.8	2,264.0
		A-2 (F6B)	2,050.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,050.3
	揚水ポンプ	No-3 (M-H-M4)	8,308.3	142.6	143.4	137.5	139.6	133.7	128.8	169.1	163.0	164.9	150.4	0.0	135.7	1,608.7	9,917.0
		No-4 (M-H-M3)	37.0	0.0	0.1	0.3	0.0	0.0	0.2	0.0	0.1	0.2	0.0	0.1	0.2	1.2	38.2
		No-5 (M-H-M2)	43,548.7	300.4	279.8	308.8	293.4	335.4	270.7	263.7	275.6	272.0	277.9	285.0	282.6	3,445.3	46,994.0
No-6 (M-H-M1)		46,024.2	274.3	294.0	273.7	299.8	269.7	309.0	291.3	276.7	287.4	286.1	359.8	301.6	3,523.4	49,547.6	
C系 最初沈殿池設備 (C2-C-D1)	汚泥掻寄機	C-1 (F3C)	16,940.8	720.0	3.7	0.0	29.2	8.1	0.0	718.2	418.5	166.8	122.1	1.8	0.0	2,188.4	19,129.2
		C-2 (F3D)	126,629.8	0.0	743.3	720.0	743.5	744.0	719.3	724.8	308.8	567.0	613.7	693.0	743.8	7,321.2	133,951.0
		C-3 (F3E)	42,419.0	17.3	5.5	16.6	38.8	15.1	7.5	14.9	1.3	166.8	121.9	1.5	0.0	407.2	42,826.2
		C-4 (F4C)	26,560.9	17.3	2.9	16.6	41.4	12.6	10.2	14.9	13.2	1.5	2.4	0.0	3.4	136.4	26,697.3
		C-5 (F4D)	83,944.3	720.0	5.6	14.2	34.7	18.3	2.4	718.4	720.0	733.0	735.6	693.0	743.8	5,139.0	89,083.3
		C-6 (F4E)	36,883.2	16.9	744.0	720.0	743.5	744.0	719.3	24.7	5.3	0.0	2.2	0.0	0.0	3,719.9	40,603.1
	汚泥引抜ポンプ	C-1 (F2C)	42,913.9	33.7	365.8	33.8	416.1	59.8	331.8	29.9	348.8	40.8	390.1	29.9	433.2	2,513.7	45,427.6
		C-2 (F2D)	45,846.5	460.3	116.8	400.3	30.8	460.4	140.8	403.0	64.7	414.4	80.8	414.7	31.6	3,018.6	48,865.1
	スカム移送ポンプ	C-1 (R4A)	3,164.7	0.1	0.9	1.0	1.3	0.0	0.0	0.0	3.9	0.0	0.9	0.0	1.2	9.3	3,174.0
		C-2 (R4B)	3,286.2	1.2	0.0	0.0	0.0	1.0	1.0	0.9	0.7	2.2	0.0	1.4	0.8	9.2	3,295.4
	C系 最終沈殿池設備 (C2-C-E1)	汚泥掻寄機	C-1 (F3C)	134,942.5	719.3	744.0	719.5	742.9	744.0	718.7	742.9	720.0	737.8	738.5	694.4	744.0	8,766.0
C-2 (F3D)			142,706.2	719.3	744.0	693.3	742.8	744.0	718.7	742.9	720.0	737.8	738.6	694.5	744.0	8,739.9	151,446.1
C-3 (F3E)			134,795.8	719.3	744.0	719.6	743.0	744.0	718.8	742.9	720.0	737.8	738.8	694.5	743.7	8,766.4	143,562.2
C-4 (F4C)			115,178.1	719.3	744.0	719.6	742.9	744.0	718.8	742.9	720.0	737.8	738.6	694.5	743.9	8,766.3	123,944.4
C-5 (F4D)			116,027.1	719.5	744.0	719.6	742.9	744.0	718.7	742.9	720.0	737.8	739.0	694.4	744.0	8,766.8	124,793.9
C-6 (F4E)			116,004.0	719.3	737.2	719.6	739.1	716.3	718.8	713.1	712.7	694.9	594.9	476.4	599.6	8,141.9	124,145.9

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計
C系 最終沈殿池設備 (C2-C-E1)	返送汚泥ポンプ	C-1	(F5A)	91,955.1	720.0	176.7	92.4	722.6	101.4	0.0	693.7	110.3	84.1	170.9	0.0	277.5	3,149.6	95,104.7
		C-2	(F6A)	88,946.5	720.0	744.0	56.1	195.3	643.0	719.3	49.4	620.8	73.9	491.1	695.1	53.3	5,061.3	94,007.8
		C-3	(F7A)	87,586.5	7.0	523.6	664.0	59.5	61.3	61.8	7.2	72.0	664.6	411.8	279.2	714.2	3,526.2	91,112.7
		C-4	(R5A)	76,772.8	720.0	176.7	90.1	722.6	150.3	29.2	200.5	116.7	83.8	293.1	282.7	294.1	3,159.8	79,932.6
		C-5	(R6A)	64,440.2	720.0	744.0	56.9	195.3	322.3	66.4	0.1	375.2	0.0	0.0	0.7	3.3	2,484.2	66,924.4
		C-6	(R7A)	73,029.0	6.9	523.5	665.0	59.5	332.9	685.4	549.3	310.4	738.5	739.7	694.7	744.0	6,049.8	79,078.8
	余剰汚泥ポンプ	C-1	(F3A)	33,608.3	24.8	263.0	24.8	321.2	49.1	0.0	129.9	263.6	30.4	245.8	19.4	306.6	1,678.6	35,286.9
		C-2	(F3B)	34,830.1	321.4	81.7	273.9	21.9	321.9	333.7	185.3	42.5	261.0	47.8	271.0	21.1	2,183.2	37,013.3
	スカム移送ポンプ	C-1	(F2B)	28,547.7	39.1	442.7	41.7	398.5	79.8	82.9	34.4	417.5	52.1	446.3	38.6	464.5	2,538.1	31,085.8
		C-2	(F2C)	28,280.1	480.9	132.8	414.5	22.4	446.8	378.3	493.7	74.4	482.4	91.7	466.2	39.8	3,523.9	31,804.0
	スカム分離機	C-1	(F2F)	59,491.6	513.5	568.1	449.9	417.6	518.5	453.9	518.5	489.3	527.1	530.6	498.5	498.3	5,983.8	65,475.4
	消泡水ポンプ	C系	(R4C)	51,334.8	172.3	171.2	158.6	155.7	172.3	156.1	202.5	617.2	735.8	717.2	251.2	183.3	3,693.4	55,028.2
		C/D系	(R4D)	34,555.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	34,555.9
		D系	(R4E)	15,394.3	170.9	169.8	159.2	156.5	173.8	152.8	181.7	183.3	182.3	175.8	169.0	180.0	2,055.1	17,449.4
C系 エアタン設備 (C2-C-C1)	C-1エアレータ	C-1-1	(F3B)	129,057.0	720.0	744.0	720.0	744.0	744.0	720.0	741.2	720.0	738.6	739.9	689.2	744.0	8,764.9	137,821.9
		C-1-2	(F3C)	129,497.5	720.0	744.0	720.0	744.0	744.0	720.0	741.8	720.0	738.6	739.9	689.2	744.0	8,765.5	138,263.0
		C-1-3	(F3D)	114,271.4	720.0	744.0	720.0	744.0	744.0	720.0	740.7	720.0	738.6	739.9	689.2	744.0	8,764.4	123,035.8
		C-1-4	(F3E)	117,577.2	720.0	744.0	720.0	744.0	744.0	720.0	741.5	720.0	738.6	739.9	689.2	741.4	8,762.6	126,339.8
		C-1-5	(F3F)	117,883.2	720.0	744.0	720.0	556.7	582.2	577.5	736.5	720.0	738.6	739.9	124.8	0.0	6,960.2	124,843.4
		C-1-6	(F3G)	104,075.8	720.0	744.0	720.0	744.0	744.0	717.1	743.1	720.0	738.6	739.9	689.2	744.0	8,763.9	112,839.7
		C-1-7	(F3H)	117,836.0	720.0	744.0	720.0	738.1	744.0	717.2	743.1	720.0	738.6	738.6	689.1	744.0	8,756.7	126,592.7
	C-2エアレータ	C-2-1	(F4B)	135,386.3	720.0	744.0	720.0	744.0	744.0	716.6	743.1	720.0	737.5	739.9	688.6	744.0	8,761.7	144,148.0
		C-2-2	(F4C)	132,583.2	477.4	744.0	720.0	744.0	744.0	717.5	743.1	720.0	737.5	739.9	688.6	744.0	8,520.0	141,103.2
		C-2-3	(F4D)	132,150.2	720.0	743.7	720.0	737.7	744.0	716.9	743.1	720.0	737.5	739.9	688.6	744.0	8,755.4	140,905.6
		C-2-4	(F4E)	129,845.6	720.0	735.1	720.0	744.0	744.0	713.3	743.1	720.0	737.5	698.7	681.1	733.2	8,690.0	138,535.6
		C-2-5	(F4F)	135,026.2	387.6	0.0	0.0	0.0	0.0	259.1	736.5	720.0	737.5	739.9	124.7	0.0	3,705.3	138,731.5
		C-2-6	(F4G)	135,044.5	720.0	739.1	720.0	744.0	744.0	717.1	743.1	720.0	737.5	739.9	688.6	744.0	8,757.3	143,801.8
		C-2-7	(F4H)	135,173.4	720.0	739.5	720.0	738.2	744.0	717.2	743.1	720.0	737.5	739.9	688.6	744.0	8,752.0	143,925.4

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計
C系 エアタン設備 (C2-C-C1)	C-3エアレータ	C-3-1	(R2B)	134,370.2	720.0	744.0	706.5	744.0	744.0	717.3	743.0	720.0	737.5	739.9	689.3	744.0	8,749.5	143,119.7
		C-3-2	(R2C)	134,106.1	482.5	744.0	720.0	744.0	744.0	717.0	742.8	720.0	737.5	739.8	689.3	744.0	8,524.9	142,631.0
		C-3-3	(R2D)	135,004.8	720.0	744.0	720.0	737.8	744.0	717.4	742.9	720.0	737.5	738.6	689.3	744.0	8,755.5	143,760.3
		C-3-4	(R2E)	135,110.5	720.0	744.0	720.0	744.0	744.0	717.5	743.0	720.0	737.5	739.9	689.3	744.0	8,763.2	143,873.7
		C-3-5	(R2F)	135,062.4	387.6	68.2	720.0	556.6	582.6	578.6	736.5	720.0	737.5	739.7	124.7	0.0	5,952.0	141,014.4
		C-3-6	(R2G)	131,792.1	720.0	738.7	720.0	744.0	744.0	717.7	743.0	720.0	737.5	739.9	689.3	744.0	8,758.1	140,550.2
		C-3-7	(R2H)	134,750.6	720.0	411.3	720.0	738.2	744.0	717.5	743.0	720.0	737.5	739.9	689.3	744.0	8,424.7	143,175.3
	C-4エアレータ	C-4-1	(R3B)	115,807.8	720.0	744.0	720.0	740.3	744.0	720.0	743.0	720.0	737.6	739.9	690.0	744.0	8,762.8	124,570.6
		C-4-2	(R3C)	115,706.5	720.0	744.0	720.0	742.5	744.0	720.0	742.4	720.0	737.6	739.9	690.0	744.0	8,764.4	124,470.9
		C-4-3	(R3D)	115,838.7	720.0	744.0	720.0	733.5	744.0	720.0	743.0	720.0	737.6	739.9	690.0	744.0	8,756.0	124,594.7
		C-4-4	(R3E)	115,801.2	720.0	744.0	720.0	743.0	744.0	720.0	743.0	720.0	737.6	739.9	690.0	740.2	8,761.7	124,562.9
		C-4-5	(R3F)	114,167.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	114,167.3
		C-4-6	(R3G)	115,834.5	720.0	744.0	720.0	741.9	744.0	720.0	743.0	720.0	737.5	739.9	689.8	744.0	8,764.1	124,598.6
		C-4-7	(R3H)	115,810.7	720.0	744.0	720.0	736.8	744.0	720.0	743.0	720.0	737.5	739.9	690.0	744.0	8,759.2	124,569.9
	C-5エアレータ	C-5-1	(F8B)	116,231.7	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	737.4	737.8	688.0	742.1	8,760.3	124,992.0
		C-5-2	(F8C)	116,238.8	710.2	744.0	720.0	744.0	744.0	720.0	644.7	703.0	737.4	596.7	443.5	740.4	8,247.9	124,486.7
		C-5-3	(F8D)	116,571.3	720.0	744.0	720.0	737.8	744.0	720.0	743.1	720.0	737.4	739.8	244.4	733.6	8,304.1	124,875.4
		C-5-4	(F8E)	116,246.8	720.0	737.3	720.0	739.4	744.0	720.0	743.1	680.6	737.4	707.3	683.6	737.8	8,670.5	124,917.3
		C-5-5	(F8F)	111,678.2	720.0	744.0	720.0	556.9	583.1	579.1	736.5	720.0	737.4	739.9	455.9	3.4	7,296.2	118,974.4
		C-5-6	(F8G)	116,564.4	720.0	744.0	720.0	744.0	744.0	720.0	743.1	720.0	737.4	739.9	289.9	743.0	8,365.3	124,929.7
		C-5-7	(F8H)	116,248.2	720.0	744.0	720.0	738.2	744.0	720.0	743.1	720.0	737.4	739.9	683.7	742.8	8,753.1	125,001.3
	C-6エアレータ	C-6-1	(R8B)	114,624.1	672.1	514.2	720.0	744.0	744.0	720.0	350.7	591.0	737.5	187.1	284.7	701.0	6,966.3	121,590.4
		C-6-2	(R8C)	115,602.1	720.0	744.0	720.0	744.0	744.0	720.0	743.1	720.0	737.5	739.8	243.4	735.6	8,311.4	123,913.5
		C-6-3	(R8D)	115,889.6	720.0	744.0	720.0	737.6	744.0	720.0	731.5	659.2	737.5	739.4	685.8	743.5	8,682.5	124,572.1
		C-6-4	(R8E)	114,999.5	5.3	132.9	165.0	744.0	744.0	720.0	743.1	720.0	737.5	739.9	689.4	744.0	6,885.1	121,884.6
		C-6-5	(R8F)	106,967.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	106,967.7
		C-6-6	(R8G)	115,595.3	720.0	744.0	720.0	744.0	744.0	720.0	743.1	720.0	737.5	739.8	689.4	744.0	8,765.8	124,361.1
		C-6-7	(R8H)	115,075.2	720.0	744.0	720.0	738.2	744.0	720.0	743.1	720.0	737.5	739.8	689.4	740.7	8,756.7	123,831.9

No. 17 (単位:時間)

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計	
C系 エアタン設備 (C2-C-C1)	送風機	No.7	(C2-H-C1)	62,153.2	719.7	684.2	719.1	742.2	744.0	719.7	742.5	720.0	735.0	738.8	675.9	739.9	8,681.0	70,834.2	
	冷却水ポンプ	No.1	(F3G)	31,314.6	5.8	384.0	71.3	691.2	99.8	668.2	48.6	627.0	70.5	399.7	52.9	691.2	3,810.2	35,124.8	
		No.2	(F3H)	31,687.3	714.3	301.9	648.1	51.2	645.0	51.3	694.2	96.9	665.2	339.4	624.4	49.0	4,880.9	36,568.2	
第1ポンプ棟	シャワー水	No.1	(7A)	379.4	0.0	3.2	0.2	3.9	0.0	0.0	0.0	1.0	0.0	0.0	0.0	0.0	8.3	387.7	
		No.2	(7B)	1,017.7	0.0	0.6	0.0	0.0	4.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4.9	1022.6	
B系 消化タンク設備	消化タンク攪拌機	B-1		77,158.7	461.3	433.3	388.2	384.2	373.6	375.2	419.4	428.7	348.1	0.0	246.4	743.7	4,602.1	81,760.8	
		B-2		2,740.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	145.1	742.3	692.9	743.7	2,324.0	5,064.2
	管廊床排水ポンプ			17.6	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.1	0.1	0.0	0.4	18.0	
	エレベーター棟床排水ポンプ			34.9	0.1	0.2	0.0	0.1	0.2	0.0	0.1	0.1	0.6	0.0	0.1	0.1	1.6	36.5	
	雑用水加圧ポンプ			80,667.9	461.7	433.8	388.6	384.7	374.0	375.7	419.8	429.0	493.3	742.3	693.7	743.3	5,939.9	86,607.8	
	循環汚泥ポンプ	B-1		40,616.3	720.0	117.4	666.6	25.7	0.0	0.0	0.0	0.0	0.1	36.2	0.0	118.0	0.0	1,684.0	42,300.3
		B-2		240.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	141.8	743.0	685.8	743.0	2,313.6	2,553.9
		B-4		43,460.2	0.0	626.3	52.7	702.4	743.8	718.6	742.7	718.8	530.9	0.0	141.4	743.5	5,721.1	49,181.3	
	消化用空気圧縮機	No.1		1,675.6	3.7	23.0	1.7	26.3	2.6	24.3	2.0	23.3	1.0	18.2	0.6	112.9	239.6	1,915.2	
No.2			2,402.8	22.5	4.3	24.3	0.8	24.9	1.6	24.8	2.5	25.6	2.9	19.1	0.6	153.9	2,556.7		
B系 ボイラー設備	管廊床排水ポンプ			76.2	0.2	0.2	0.2	0.7	0.2	0.1	0.4	1.0	2.0	0.3	1.1	0.8	7.2	83.4	
	B系 温水ボイラー制御盤	オイル燃焼時間		2.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.3	2.4	
		ガス燃焼時間		52142.8	461.5	282.2	255.7	266.9	220.9	263.4	348.4	413.3	511.6	499.2	568.7	630.7	4722.5	56865.3	
汚泥乾燥設備 (N-C-T)	空気圧縮機	No.1	(F3A)	30339.8	39.1	0.0	2.0	0.8	2.2	505.7	116.2	0.0	0.3	497.3	55.4	510.4	1729.4	32069.2	
		No.2	(F3B)	31978.5	337.0	558.7	574.9	649.7	667.4	64.3	502.6	646.2	697.1	90.2	619.8	207.2	5615.1	37593.6	
	砂ろ過水ポンプ	No.1	(R3B)	38002.7	0.0	0.0	309.3	660.1	667.6	676.0	678.8	720.0	674.9	743.7	184.3	0.0	5314.7	43317.4	
		No.2	(R3C)	38764.5	668.1	738.3	373.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	286.3	712.1	2778.7	41543.2	
	砂ろ過水送水ポンプ	No.1	(R3F)	28885.4	0.0	0.0	226.1	482.5	50.1	1.7	262.2	186.1	220.1	503.4	333.3	461.4	2726.9	31612.3	
		No.2	(R3G)	28075.0	497.8	546.7	278.1	0.0	450.3	473.1	200.0	321.0	246.4	0.0	0.0	50.8	3064.2	31139.2	
脱臭ファン		(R4G)	11474.3	81.6	34.1	61.4	112.6	97.5	65.8	86.0	26.3	105.5	30.9	240.5	64.9	1007.1	12481.4		
汚泥乾燥設備 (N-C-U1)	1系排ガスファン		(R1A)	75265.7	671.2	738.8	682.7	660.1	684.7	665.3	678.7	720.0	674.9	743.7	472.0	713.1	8105.2	83370.9	
	1系スクラバ循環ポンプ	No.1	(R2B)	37338.6	0.0	0.0	308.8	660.1	652.2	675.9	678.7	720.0	43.3	0.0	371.9	713.2	4824.1	42162.7	
		No.2	(R2C)	39771.8	668.6	738.8	373.9	0.0	31.2	0.0	0.0	0.0	631.4	743.7	98.9	0.0	3286.5	43058.3	

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計	
汚泥乾燥設備 (N-C-U1)	1系熱風炉用ブロワ	No. 1 (R2E)		41463.0	720.0	744.0	409.8	0.0	0.0	0.0	0.0	0.0	666.9	743.7	99.0	0.0	3383.4	44846.4	
		No. 2 (R2F)		44648.3	0.0	0.0	310.1	744.0	743.9	718.5	744.0	720.0	74.7	0.0	596.1	744.0	5395.3	50043.6	
	1系冷却塔循環ポンプ	No. 1-1 (R1E)		42688.8	70.2	744.0	379.8	0.0	647.8	594.7	0.0	455.9	401.9	236.9	694.9	739.4	4965.5	47654.3	
		No. 1-2 (R1F)		41411.9	646.7	0.0	334.3	744.0	90.5	118.1	744.0	260.0	333.9	499.2	0.0	0.1	3770.8	45182.7	
		No. 2-1 (R1G)		41407.2	670.7	0.0	308.0	740.5	113.0	0.0	490.3	284.0	309.1	506.5	0.0	670.2	4092.3	45499.5	
		No. 2-2 (R1H)		42873.3	46.0	741.1	404.4	0.0	624.2	666.5	0.0	432.2	425.9	212.8	694.6	68.8	4316.5	47189.8	
	脱水汚泥移送ポンプ	No. 1 CRT		12531.8	141.6	145.5	143.5	133.2	137.7	140.2	140.2	143.9	68.9	70.0	128.1	173.4	1566.2	14098.0	
		No. 2 CRT		14093.8	116.4	139.4	122.6	124.9	107.8	114.8	120.8	142.2	194.7	231.0	74.1	128.4	1617.1	15710.9	
D系 最初沈殿池設備 (C2-C-D2)	汚泥掻寄機	D-1 (F2C)		5091.2	17.2	2.9	16.5	41.0	15.4	11.0	9.2	3.9	167.4	121.4	0.0	0.0	405.9	5497.1	
		D-2 (F2D)		52772.2	0.0	0.0	0.0	30.5	8.1	0.0	0.0	309.8	567.6	615.3	691.1	743.8	2966.2	55738.4	
		D-3 (F2E)		22151.3	720.0	744.0	717.2	742.6	744.0	719.4	744.0	416.9	169.8	121.3	3.0	0.0	5842.2	27993.5	
		D-4 (F3C)		8896.8	16.8	8.8	18.8	38.6	12.8	10.9	0.0	6.1	0.0	2.2	1.7	3.3	120.0	9016.8	
		D-5 (F3D)		54035.4	720.0	744.0	717.2	742.6	744.0	719.4	744.0	720.0	734.3	736.6	691.1	743.8	8757.0	62792.4	
		D-6 (F3E)		8019.7	16.7	5.7	16.1	34.5	18.1	4.4	0.0	6.1	1.3	0.0	0.0	0.0	102.9	8122.6	
	汚泥引抜ポンプ	D-1 (R2H)		15630.5	29.2	324.8	25.4	369.1	53.5	283.6	26.7	489.9	52.5	414.0	230.2	562.6	2861.5	18492.0	
		D-2 (R3H)		17774.9	399.4	161.4	359.0	28.8	376.0	101.6	371.6	59.0	466.0	85.1	246.8	33.6	2688.3	20463.2	
	D系 エアタン設備 (C2-C-C2)	D-1エアレータ	D-1-1 (F2A)		60913.9	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	737.4	739.5	695.7	744.0	8772.6	69686.5
			D-1-2 (F2B)		60941.1	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	737.4	739.5	695.7	744.0	8772.6	69713.7
D-1-3 (F2C)				60517.7	720.0	744.0	720.0	736.3	744.0	720.0	744.0	720.0	737.4	739.5	695.4	744.0	8764.6	69282.3	
D-2エアレータ		D-2-1 (F2D)		60939.3	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	737.4	734.0	694.7	741.7	8763.8	69703.1	
		D-2-2 (F2E)		60944.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	737.4	739.5	695.7	744.0	8772.6	69716.6	
		D-2-3 (F2F)		60932.3	720.0	744.0	720.0	736.3	744.0	720.0	744.0	720.0	737.3	738.7	643.3	743.6	8711.2	69643.5	
D-3エアレータ		D-3-1 (F3A)		60940.7	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	737.4	729.3	675.6	743.6	8741.9	69682.6	
		D-3-2 (F3B)		60939.5	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	737.4	739.5	695.4	744.0	8772.3	69711.8	
		D-3-3 (F3C)		60915.7	720.0	744.0	720.0	736.3	744.0	720.0	744.0	720.0	737.4	739.5	695.7	744.0	8764.9	69680.6	
D-4エアレータ		D-4-1 (F3D)		52746.5	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	737.4	739.5	695.4	744.0	8772.3	61518.8	
		D-4-2 (F3E)		60235.4	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	737.4	738.7	695.4	744.0	8771.5	69006.9	
		D-4-3 (F3F)		60429.2	720.0	744.0	720.0	736.3	744.0	720.0	744.0	720.0	737.4	739.2	695.7	744.0	8764.6	69193.8	

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計
D系 エアタン設備 (C2-C-C2)	D-5エアレータ	D-5-1 (F4A)		60242.1	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	737.3	739.5	695.4	744.0	8772.2	69014.3
		D-5-2 (F4B)		60195.2	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	737.4	739.5	695.7	744.0	8772.6	68967.8
		D-5-3 (F4C)		60621.2	720.0	744.0	720.0	736.3	744.0	720.0	744.0	720.0	737.3	736.4	690.9	739.8	8752.7	69373.9
	D-6エアレータ	D-6-1 (F4D)		60431.9	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	737.4	739.5	695.7	744.0	8772.6	69204.5
		D-6-2 (F4E)		59929.1	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	737.4	739.5	695.7	744.0	8772.6	68701.7
		D-6-3 (F4F)		54837.7	720.0	744.0	720.0	736.3	744.0	720.0	744.0	720.0	737.4	739.5	695.7	744.0	8764.9	63602.6
D系 最終沈殿池設備 (C2-C-E2)	汚泥掻寄機	D-1 (R1A)		61113.6	719.8	744.0	719.4	743.2	744.0	718.7	744.0	720.0	737.0	738.1	694.6	743.9	8766.7	69880.3
		D-2 (R1B)		61226.5	719.8	744.0	719.3	743.1	744.0	718.7	744.0	720.0	737.3	739.2	694.9	744.0	8768.3	69994.8
		D-3 (R2A)		61229.2	720.0	744.0	719.5	742.2	744.0	718.7	744.0	720.0	735.5	705.1	693.1	743.8	8729.9	69959.1
		D-4 (R2B)		60582.3	720.0	744.0	719.3	743.2	743.8	718.6	744.0	720.0	737.1	738.8	694.5	743.8	8767.1	69349.4
		D-5 (R2C)		60578.7	720.0	744.0	719.5	743.1	744.0	717.5	744.0	720.0	737.3	737.1	694.6	744.0	8765.1	69343.8
		D-6 (R2D)		60584.4	720.0	744.0	719.4	743.1	744.0	718.7	744.0	720.0	737.2	737.1	694.5	743.9	8765.9	69350.3
	返送汚泥ポンプ	D-1 (F3A)		43085.4	720.0	176.6	87.3	722.9	101.0	0.0	645.1	99.1	27.4	618.5	49.2	40.7	3287.8	46373.2
		D-2 (F4A)		39919.0	720.0	744.0	55.9	195.6	643.3	719.4	100.1	622.8	72.6	22.1	646.1	53.2	4595.1	44514.1
		D-3 (F5A)		39724.4	7.2	523.5	669.1	59.5	47.4	33.9	6.7	39.3	664.9	120.9	26.8	694.7	2893.9	42618.3
		D-4 (R3A)		42046.9	720.0	176.6	86.2	722.8	101.0	0.0	693.8	98.9	27.3	618.6	49.2	40.6	3335.0	45381.9
		D-5 (R4A)		39461.6	720.0	744.0	57.0	195.6	643.3	719.4	51.3	623.1	72.8	22.1	646.1	53.1	4547.8	44009.4
		D-6 (R5A)		39465.1	6.9	523.5	669.2	77.4	47.4	33.8	7.2	42.4	664.6	120.9	26.8	694.7	2914.8	42379.9
	余剰汚泥ポンプ	D-1 (F2E)		12976.4	0.0	195.0	17.0	236.4	34.6	0.0	96.7	184.4	21.0	187.1	14.8	228.5	1215.5	14191.9
		D-2 (F2F)		13456.6	266.3	62.1	210.2	16.7	222.4	226.3	127.8	29.5	199.6	36.0	207.3	15.7	1619.9	15076.5
	沈砂設備 (J-C-N1A) <設備更新>	床排水ポンプ	No. 1 (F3E)		2.6	0.0	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.2	0.0	0.0	0.0	1.0
No. 2 (F3F)				5.9	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.0	0.0	0.1	0.1	0.0	0.7	6.6
No. 3 (F3G)				2.7	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.0	0.0	0.1	0.1	0.0	0.7	3.4
加圧水ポンプ		No. 1 (F2C)		422.0	0.9	14.2	0.7	21.1	4.2	18.5	0.9	19.0	0.9	17.1	1.1	32.6	131.2	553.2
		No. 2 (F2D)		489.9	18.7	4.8	18.5	1.9	17.6	1.5	21.6	3.2	21.8	2.7	17.9	0.7	130.9	620.8
揚砂ポンプ		No. 2 (F3C)		128.3	1.8	0.3	1.0	6.2	2.1	2.1	3.8	3.3	5.2	2.8	2.0	3.4	34.0	162.3
	No. 3 (F3D)		119.2	1.3	0.5	0.8	1.5	2.6	1.5	2.3	3.0	2.6	2.5	1.3	3.2	23.1	142.3	

No. 20 (単位:時間)

区分	機器名称	機器番号		26年度末	27年4月	5月	6月	7月	8月	9月	10月	11月	12月	28年1月	2月	3月	年計	累計	
A系エアタン設備	反応槽攪拌装置	4-1	(F2F)	19287.9	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	733.0	696.0	743.0	8771.0	28058.9	
		4-2	(F2G)	19286.9	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	733.0	696.0	743.0	8771.0	28057.9	
		4-3	(F2H)	19289.0	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	732.0	695.0	742.0	8768.0	28057.0	
		5-1	(F2C)	20465.0	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	732.0	695.0	742.0	8768.0	29233.0	
		5-2	(F2D)	20464.0	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	731.0	694.0	741.0	8765.0	29229.0	
		5-3	(F2E)	20465.7	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	732.0	695.0	742.0	8768.0	29233.7	
		6-1	(R2D)	20462.6	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	732.0	695.0	742.0	8768.0	29230.6	
		6-2	(R2E)	20446.7	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	732.0	695.0	742.0	8768.0	29214.7	
		6-3	(R2F)	20464.4	720.0	744.0	720.0	744.0	744.0	720.0	743.0	720.0	744.0	732.0	695.0	742.0	8768.0	29232.4	
	凝集剤注入ポンプ	A-1	(R1C)		5636.2	112.0	328.0	171.1	0.0	327.1	199.4	0.0	0.0	0.0	0.0	226.0	492.0	1855.6	7491.8
		A-2	(R1D)		6046.2	97.0	0.0	288.2	448.4	175.3	390.1	517.2	597.0	472.0	666.0	306.0	0.0	3957.2	10003.4