

4 機 械 関 係

(1) 機械設備稼動状況

浄化センター (その1)

(単位：時間)

設備	機 器 名	No	26年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	27年度計	27年度まで累計
沈砂池設備	揚 砂 ポ ン プ	No.1-1	70.9	0.0	0.1	0.2	2.5	0.5	3.6	2.2	1.2	0.7	0.0	1.0	0.5	12.5	83.4
		No.1-2	82.6	0.0	0.1	0.1	0.7	0.3	0.7	0.6	0.0	0.0	0.0	0.8	0.5	3.8	86.4
	細 目 除 塵 機	No.1	1,016.6	1.6	0.3	0.9	0.6	0.6	0.8	3.0	2.0	1.0	0.3	0.8	0.7	12.6	1,029.2
		No.1	961.0	2.0	1.2	1.9	1.4	2.7	2.8	3.1	2.0	1.8	1.2	2.0	2.8	24.9	985.9
		No.2	976.5	1.9	1.3	1.9	1.8	2.7	2.8	3.1	2.0	1.7	1.2	2.0	2.7	25.1	1,001.6
	し 渣 搬 出 コ ン ベ ア	No.3	1,009.5	2.1	1.4	2.1	2.1	2.7	1.9	3.2	2.4	1.8	1.0	2.6	2.2	25.5	1,035.0
		No.1	114,882.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	114,882.1
		No.1	22.8	0.0	0.1	0.0	0.0	0.1	0.1	0.1	0.2	0.1	0.1	0.0	0.1	0.9	23.7
し 渣 ・ 沈 砂 洗 浄 機	No.1	1,119.7	2.3	1.4	2.2	5.1	2.6	8.4	6.1	3.3	2.0	1.3	2.9	3.9	41.5	1,161.2	
沈砂搬出コンベア	No.1	197.3	2.1	1.0	2.1	5.1	2.6	8.0	4.6	2.8	1.8	1.0	2.6	2.5	36.2	233.5	
最初沈殿池	生 汚 泥 引 抜 ポ ン プ	No.1	10,698.4	106.2	1.5	106.4	1.6	138.5	1.7	147.6	8.3	212.4	22.9	81.3	35.2	863.6	11,562.0
		No.2	10,749.0	1.2	101.6	3.6	136.1	9.8	106.3	1.5	200.9	4.4	155.9	1.8	59.1	782.2	11,531.2
	床 排 水 ポ ン プ	No.1	223.2	6.2	6.3	5.9	5.0	3.3	4.8	3.9	2.1	—	—	—	—	37.5	260.7
		No.1	—	—	—	—	—	—	—	—	2.0	5.8	6.7	8.8	6.6	29.9	29.9
	1 系 初 沈 汚 泥 掻 寄 機	No.1-1	150,068.4	717.5	740.6	718.2	741.6	558.7	718.4	513.8	440.1	432.6	431.8	593.4	734.2	7,340.9	157,409.3
		No.1-2	109,364.5	503.3	519.4	503.6	517.2	454.7	718.4	515.8	477.3	432.6	431.8	593.4	736.2	6,403.7	115,768.2
	2 系 汚 泥 掻 寄 機	No.2	53,408.8	717.6	741.8	718.1	741.8	498.6	566.8	497.0	413.0	402.8	402.6	583.6	736.2	7,019.9	60,428.7
	3 系 汚 泥 掻 寄 機	No.3	69,830.2	718.7	742.3	719.6	714.1	532.8	589.3	523.4	477.9	434.3	433.6	7.2	657.0	6,550.2	76,380.4
	池 排 水 ポ ン プ	No.1	65.2	0.0	0.0	0.0	1.8	0.0	0.0	0.0	0.0	0.0	0.0	1.9	0.7	4.4	69.6
	初沈スカム排水ポンプ	No.1	3,782.9	40.7	0.7	39.6	0.7	40.0	0.9	38.1	1.9	39.6	4.6	21.8	17.3	245.9	4,028.8
No.2		4,127.0	2.0	40.5	0.7	40.0	3.3	21.4	0.3	37.5	0.7	38.9	6.8	21.1	213.2	4,340.2	
汚泥処理設備	濃 縮 汚 泥 掻 寄 機	No.1	96,594.1	716.8	741.0	716.9	741.2	741.7	716.0	741.5	718.6	742.5	741.6	686.5	738.6	8,742.9	105,337.0
		No.2	50,736.9	717.0	741.0	716.7	741.3	741.5	715.6	741.4	718.8	742.3	741.8	274.7	579.1	8,171.2	58,908.1
	脱 水 ろ 液 移 送 ポ ン プ	No.1	34,518.3	456.9	109.2	485.4	20.0	464.2	48.3	428.4	460.5	329.4	338.3	385.5	378.1	3,904.2	38,422.5
		No.2	43,684.1	84.3	477.7	109.7	507.6	80.6	440.2	46.8	48.3	235.6	195.9	39.9	129.5	2,396.1	46,080.2
	汚 泥 貯 留 槽 攪 拌 機	No.1	108,546.9	338.5	340.1	337.4	350.1	337.1	335.3	349.3	317.8	350.7	320.9	324.2	352.3	4,053.7	112,600.6
	汚 泥 供 給 ポ ン プ	No.1	2,346.4	10.0	3.7	0.4	15.7	28.0	5.3	31.2	4.6	73.5	4.0	23.7	6.9	207.0	2,553.4
		No.2	2,066.0	3.4	13.5	0.0	25.9	9.2	7.0	29.6	179.2	9.2	116.3	4.0	99.8	497.1	2,563.1
		No.3	11,414.3	175.5	3.9	222.8	4.1	160.6	3.9	162.1	4.5	136.6	11.3	167.4	0.4	1,053.1	12,467.4
		No.4	12,333.0	16.2	201.1	4.1	170.7	15.7	198.5	0.2	16.9	0.1	71.8	4.1	113.2	812.6	13,145.6
	濃 縮 汚 泥 移 送 ポ ン プ	No.1	7,511.9	29.8	27.6	28.0	1.2	29.2	1.3	45.8	2.3	51.9	43.9	31.9	33.8	326.7	7,838.6
		No.2	6,235.7	30.0	27.1	14.1	34.3	2.4	32.8	2.4	39.6	13.2	43.9	31.6	32.7	304.1	6,539.8
	給 水 ポ ン プ	No.1	778.3	9.0	0.2	9.6	0.0	8.6	0.0	10.4	0.1	10.2	0.8	10.1	0.2	59.2	837.5
		No.2	868.4	0.0	10.4	0.0	9.8	0.4	8.9	0.4	13.0	0.4	10.9	0.0	11.8	66.0	934.4
	脱 臭 フ ァ ン	No.1	184,823.4	719.4	743.2	719.1	743.7	742.2	719.5	743.5	719.4	743.3	742.7	694.9	742.7	8,773.6	193,597.0
	ろ 布 洗 浄 ポ ン プ	No.3	15,826.2	244.0	5.5	279.6	4.3	218.8	3.7	206.3	6.9	172.7	34.6	215.8	0.5	1,392.7	17,218.9
		No.4	16,418.9	5.9	262.1	4.1	218.5	15.6	250.1	0.1	26.7	0.0	75.6	4.2	146.5	1,009.4	17,428.3
床 排 水 ポ ン プ	No.1	44.0	38.7	0.5	16.6	0.8	18.5	0.7	34.0	1.3	36.3	5.4	35.8	0.9	189.5	44.0	
	No.2	54.2	1.7	22.0	0.3	23.0	1.5	16.0	0.8	16.8	1.0	23.9	1.0	30.8	138.8	54.2	

浄化センター（その2）

（単位：時間）

設備	機器名	No	26年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	27年度計	27年度まで累計
汚泥処理設備	空気圧縮機	No.1	3,393.7	32.8	42.3	46.5	50.3	50.9	48.5	50.7	60.1	54.2	50.0	43.8	45.9	576.0	3,969.7
		No.2	3,723.9	33.0	42.1	46.7	51.0	51.9	49.0	50.9	37.8	45.7	50.5	43.7	46.0	548.3	4,272.2
	溶解槽攪拌機	No.1	841.3	2.1	2.6	0.0	5.1	4.9	4.5	7.3	34.8	9.4	19.9	7.0	13.9	111.5	952.8
		No.2	26,975.3	21.5	28.5	19.2	16.1	14.1	21.4	15.3	1.6	13.0	12.1	26.7	16.6	206.1	27,181.4
	薬品定量供給機	No.1	148.3	0.6	0.5	0.0	1.4	1.1	0.6	2.2	5.7	2.5	3.7	1.7	3.3	23.3	171.6
	薬品供給機	No.1	816.5	4.8	5.4	5.5	4.2	4.1	4.1	3.7	0.5	2.9	2.2	4.5	2.7	44.6	861.1
	薬品供給ポンプ	No.1	2,435.3	10.0	3.7	0.5	15.8	34.1	5.3	31.3	4.6	68.2	6.8	19.6	56.6	256.5	2,691.8
		No.2	2,002.9	3.4	13.6	0.0	25.9	3.3	7.2	29.7	179.9	14.8	114.0	8.1	50.6	450.5	2,453.4
		No.3	11,557.1	183.3	3.2	222.8	4.1	161.4	3.0	162.0	4.4	136.6	15.2	167.3	4.3	1,067.6	12,624.7
		No.4	12,244.5	8.3	202.0	4.2	171.0	14.9	199.3	0.3	17.0	0.1	68.0	4.2	109.2	798.5	13,043.0
脱 水 機	No.1	4,412.4	13.4	17.2	0.4	41.6	37.2	12.3	60.8	183.8	82.7	120.3	27.7	106.7	704.1	5,116.5	
	No.2	23,753.3	191.7	205.0	226.9	174.8	176.3	202.4	162.3	21.4	136.7	83.1	171.5	113.6	1,865.7	25,619.0	
送 風	送 風 機	No.1-1	77,004.1	2.6	0.0	0.2	8.3	75.5	0.4	0.5	0.6	0.6	0.6	0.6	3.0	92.9	77,097.0
		No.1-2	71,944.8	2.6	0.0	0.2	8.3	0.0	0.3	0.5	0.7	0.5	0.5	0.6	3.0	17.2	71,962.0
		No.2-1	74,859.1	713.9	743.5	717.6	731.7	742.1	718.2	742.8	716.8	741.3	735.3	528.6	12.0	7,843.8	82,702.9
		No.2-2	25,346.7	2.7	0.5	0.7	3.8	1.7	0.5	0.6	1.1	0.9	7.6	158.3	723.2	901.6	26,248.3
エアタン	水 中 攪 拌 機	No.1-1	50,164.8	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	696.0	744.0	8,784.0	58,948.8
		No.1-2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
		No.2-1	52,583.7	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	696.0	744.0	8,784.0	61,367.7
		No.2-2	72.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	72.0
	散 気 装 置	No.3-1	70,102.4	719.3	745.1	719.2	740.1	744.0	718.5	746.1	714.6	744.0	744.1	685.4	743.6	8,764.0	78,866.4
		No.3-2	69,879.3	719.3	745.1	719.2	740.1	744.0	718.5	746.3	714.6	744.0	744.2	685.4	743.6	8,764.3	78,643.6
最終沈殿池	1系返送汚泥ポンプ	No.1	27,833.9	708.9	9.9	704.8	10.7	685.6	10.2	733.6	35.6	732.2	81.5	678.4	13.9	4,405.3	32,239.2
		No.2	28,465.6	11.1	733.9	13.4	733.2	58.3	708.9	9.9	682.0	10.2	662.1	9.9	723.6	4,356.5	32,822.1
	2系返送汚泥ポンプ	No.1	34,874.4	708.1	9.9	706.1	10.8	685.5	10.2	733.5	35.6	732.0	81.5	678.1	14.0	4,405.3	39,279.7
		No.2	35,138.4	11.2	733.9	12.1	725.2	58.4	708.9	10.0	682.3	10.2	662.1	9.9	723.5	4,347.7	39,486.1
	余 剰 汚 泥 ポ ン プ	No.1	15,036.1	57.7	73.4	67.3	84.7	88.1	68.6	66.8	54.5	73.2	72.7	67.7	55.8	830.5	15,866.6
		No.2	1,590.5	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.2	1,591.7
		No.3	3,331.8	36.3	41.0	36.9	41.0	45.8	47.4	29.2	35.9	38.1	39.7	38.5	37.3	467.1	3,798.9
	1系終沈汚泥掻寄機	No.1-1	170,673.8	711.8	735.4	711.2	736.9	733.2	713.8	737.1	710.7	736.1	736.4	689.3	735.1	8,687.0	179,360.8
		No.1-2	174,917.8	711.8	735.5	711.6	736.8	733.2	713.9	737.1	712.2	736.3	736.4	689.2	735.1	8,689.1	183,606.9
	2系終沈汚泥掻寄機	No.2	146,462.5	711.2	735.2	711.6	737.1	733.2	713.2	736.5	712.1	735.0	735.9	688.9	734.9	8,684.8	155,147.3
	3系終沈汚泥掻寄機	No.3	69,706.1	715.2	739.1	714.9	740.3	736.9	716.4	739.7	715.7	739.6	738.9	692.3	739.5	8,728.5	78,434.6
	A・T床排水ポンプ	No.1	2,447.4	34.0	16.0	14.9	13.6	12.9	13.4	12.0	12.7	13.1	13.1	11.5	10.7	177.9	2,625.3
	終沈床排水ポンプ	No.1	2,117.3	0.8	0.1	1.1	0.2	0.7	0.3	0.5	0.1	1.1	0.2	1.0	0.1	6.2	2,123.5
		No.2	1,815.3	0.2	1.0	0.3	1.0	0.2	1.7	0.1	0.7	0.1	1.6	0.1	0.7	7.7	1,823.0
	終沈スカム排水ポンプ	No.1	10,906.6	65.8	0.6	49.8	0.6	50.6	0.9	51.5	3.4	63.4	7.4	51.3	7.1	352.4	11,259.0
No.2		9,365.5	1.0	48.2	1.0	45.0	3.4	46.6	0.4	46.4	0.7	57.1	14.4	86.3	350.5	9,716.0	
池 排 水 ポ ン プ	No.1	64.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	64.7	

浄化センター（その3）

（単位：時間）

設備	機器名	No	26年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	27年度計	27年度まで累計
用水設備	原水ポンプ	No.1	35,840.2	77.4	0.1	5.5	0.1	4.4	0.1	5.4	0.2	3.7	0.6	4.5	4.5	106.5	35,946.7
		No.2	32,422.3	0.2	9.5	0.2	5.8	0.7	4.7	0.2	4.0	0.2	4.3	0.0	15.9	45.7	32,468.0
		No.3	7,446.9	302.6	383.2	404.2	346.1	318.6	360.1	292.2	112.5	233.3	181.1	318.7	244.4	3,497.0	10,943.9
	消泡水ポンプ	No.1	1,955.5	10.5	0.0	10.6	0.0	5.1	0.5	25.2	0.1	7.1	0.2	6.5	0.1	65.9	2,021.4
		No.2	1,679.1	0.1	5.4	0.0	8.7	0.1	16.4	0.1	9.2	0.1	2.7	0.1	10.1	53.0	1,732.1
	逆洗排水ポンプ	No.1	4,166.9	35.6	0.0	8.6	0.5	4.2	0.1	0.2	0.0	0.2	3.7	0.0	0.1	53.2	4,220.1
		No.2	4,425.3	0.1	4.2	0.0	4.7	0.4	4.6	0.0	0.4	0.1	0.1	0.0	7.9	22.5	4,447.8
	濾過水移送ポンプ	No.1	6,954.7	83.4	1.5	91.2	1.6	72.2	1.6	65.0	2.3	54.9	4.8	73.0	0.4	451.9	7,406.6
		No.2	7,402.6	0.8	89.6	1.7	77.4	5.8	83.6	1.7	17.5	0.4	36.6	1.4	62.8	379.3	7,781.9
	空気圧縮機	No.1	12,754.3	30.2	0.2	3.3	0.0	1.3	0.0	2.5	0.1	3.3	0.4	3.9	0.2	45.4	12,799.7
		No.2	12,932.4	0.1	8.2	0.1	3.7	0.1	3.3	0.1	6.0	0.1	8.6	0.1	181.6	212.0	13,144.4
	用水床排水ポンプ	No.1	383.4	39.0	0.6	39.8	0.6	33.4	0.7	32.9	1.7	31.2	4.1	29.7	0.7	214.4	597.8
		No.2	412.6	0.9	48.5	0.9	46.1	3.7	37.0	0.8	31.3	0.6	35.7	0.7	39.2	245.4	658.0
	ろ過器	No.2	7,446.9	302.6	383.2	404.2	346.1	318.6	360.1	292.2	112.5	233.3	181.1	318.7	244.4	3,497.0	10,943.9
	次亜塩素酸ソーダ注入ポンプ	No.1	68,434.3	497.8	70.8	674.5	736.0	730.0	718.7	742.2	718.0	741.8	731.7	687.7	736.5	7,785.7	76,220.0
No.2		86,966.9	0.9	8.7	13.3	0.1	0.0	0.0	0.0	0.0	0.0	6.9	0.3	0.1	30.3	86,997.2	
No.3		9,166.2	217.9	664.5	28.7	6.4	13.2	0.1	0.7	0.1	0.3	4.8	0.1	0.1	936.9	10,103.1	
機械濃縮設備	余剰汚泥貯留槽攪拌機	No.1	96,430.3	717.4	741.6	709.4	743.3	743.6	710.2	742.9	697.1	736.1	741.5	686.4	714.6	8,684.1	105,114.4
		No.1	28,280.1	435.6	11.7	413.4	6.8	491.1	12.9	416.9	26.4	388.1	47.2	371.8	14.0	2,635.9	30,916.0
	汚泥供給ポンプ	No.3	28,380.4	7.5	488.3	11.1	498.4	48.8	475.8	12.4	363.7	11.1	353.9	7.9	309.4	2,588.3	30,968.7
		No.1	56,658.4	443.1	500.0	424.6	505.2	539.9	488.7	429.3	390.2	399.2	401.1	379.7	323.5	5,224.5	61,882.9
	凝集剤供給機	No.1	519.5	6.2	4.6	3.2	4.1	10.7	6.1	5.5	5.4	5.9	6.3	6.0	5.3	69.3	588.8
		No.2	532.3	6.3	4.8	2.7	4.4	10.7	6.7	5.7	5.4	6.0	6.3	6.3	5.1	70.4	602.7
	凝集剤注入ポンプ	No.1	28,488.7	436.7	11.8	415.5	6.9	493.2	12.9	419.0	26.6	388.9	47.3	376.9	14.1	2,649.8	31,138.5
		No.2	28,557.2	7.5	490.4	11.2	500.7	49.1	477.8	12.5	364.9	11.1	354.3	4.1	312.2	2,595.8	31,153.0
	濃縮汚泥貯留槽攪拌機	No.1	22,720.8	3.9	11.0	16.6	5.2	7.5	12.9	10.7	0.0	0.0	8.4	9.1	5.6	90.9	22,811.7
	濃縮汚泥移送ポンプ	No.1	1,488.4	17.9	0.6	20.8	0.6	20.8	0.7	20.3	0.9	21.6	1.5	20.8	0.4	126.9	1,615.3
		No.2	1,454.3	0.3	23.5	0.6	21.7	2.0	21.8	0.6	16.2	0.4	19.3	0.5	17.9	124.8	1,579.1
	凝集剤溶解槽攪拌機	No.1	5,039.2	26.7	20.5	14.1	16.0	49.7	28.1	24.1	22.9	25.4	26.8	26.6	22.8	303.7	5,342.9
		No.2	5,100.2	26.4	20.3	11.4	17.2	49.1	26.5	25.1	21.3	26.3	25.1	26.3	22.5	297.5	5,397.7
	空気圧縮機	No.1	15,473.0	190.0	10.0	190.0	10.0	200.0	10.0	200.0	10.0	200.0	20.0	180.0	10.0	1,230.0	16,703.0
		No.2	16,980.0	10.0	230.0	10.0	220.0	20.0	220.0	10.0	190.0	10.0	190.0	0.0	200.0	1,310.0	18,290.0
	起泡用水ポンプ	No.1	26,842.1	424.1	23.8	405.6	15.7	481.4	23.9	414.0	30.5	383.4	346.2	363.4	23.3	2,935.3	29,777.4
		No.3	30,197.0	17.3	477.8	23.0	489.5	59.2	469.6	19.7	357.2	18.3	1.3	16.2	307.1	2,256.2	32,453.2
	起泡助剤希釈槽攪拌機	No.1	344.0	2.6	1.3	2.6	2.5	2.5	2.6	2.5	2.3	2.6	1.3	2.5	1.4	26.7	370.7
	起泡助剤注入ポンプ	No.1	28,622.9	424.1	23.8	405.7	15.7	481.3	45.4	414.0	30.5	383.4	52.3	363.4	23.3	2,662.9	31,285.8
		No.3	28,442.6	17.3	477.8	23.0	489.5	59.2	448.8	19.7	357.2	18.2	346.2	16.2	307.4	2,580.5	31,023.1
脱気槽攪拌機	No.1	57,405.2	442.9	503.3	430.2	506.8	542.1	495.2	435.4	389.2	403.4	400.0	381.1	332.2	5,261.8	62,667.0	
床排水ポンプ	No.1	741.3	2.0	0.1	1.8	0.2	2.4	0.1	2.1	0.1	2.0	0.2	2.9	0.1	14.0	755.3	
	No.2	741.7	0.1	2.2	0.1	2.3	0.2	2.4	0.1	1.9	0.0	1.9	0.1	1.9	13.2	754.9	

中継ポンプ場（その1）

（単位：時間）

設備	機器名	No	26年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	27年度計	27年度まで累計	
獅子崎	細目除塵機	No.1		12.0	12.4	12.0	12.4	12.4	12.0	12.4	12.0	12.4	12.4	3.2	12.4	138.0		
	破砕機	No.1		28.0	28.9	28.0	28.9	28.9	28.0	28.9	28.0	28.9	28.9	7.5	28.9	321.8		
	汚水ポンプ	No.1	56,512.4	2.7	0.0	0.1	0.1	0.1	0.1	0.2	0.1	0.0	0.1	0.1	2.3	0.1	5.9	56,518.3
		No.2	55,548.7	0.4	0.0	0.1	4.8	0.1	0.2	0.1	0.0	0.1	0.1	0.1	0.1	0.1	6.1	55,554.8
		No.3	5,293.6	0.1	0.0	0.1	0.1	0.1	0.3	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.3	5,294.9
		No.4	54,810.7	720.5	719.0	741.6	764.3	734.9	717.7	723.2	737.1	717.2	719.7	731.6	719.2	8,746.0	63,556.7	
		No.5	将来設備															
	水中ミキサー	No.1	87,131.8	724.7	719.4	744.0	772.2	735.6	719.5	723.8	739.7	719.8	720.3	743.5	720.4	8,782.9	95,914.7	
No.2		131,905.4	724.7	719.4	744.0	772.2	735.6	719.7	723.8	739.7	719.8	720.3	743.5	699.4	8,762.1	140,667.5		
脱臭ファン	No.1	84,746.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	696.0	744.0	8,784.0	93,530.0		
鶴賀	細目除塵機	No.1		12.0	12.4	12.0	12.4	12.4	12.0	12.4	12.0	12.4	12.4	11.6	12.4	146.4		
	破砕機	No.1		28.0	28.9	28.0	28.9	28.9	28.0	28.9	28.0	28.9	28.9	27.0	28.9	341.3		
	汚水ポンプ	No.1	65,422.8	14.2	2.1	14.8	2.3	31.0	395.6	495.1	435.3	366.2	417.5	317.8	1.0	2,492.9	67,915.7	
		No.2	65,782.0	0.5	17.6	20.6	16.9	10.9	404.8	477.3	443.4	356.2	418.7	314.1	19.0	2,500.0	68,282.0	
		No.3	3,835.0	0.0	0.1	0.2	0.1	0.3	308.6	224.7	288.7	350.6	297.1	301.9	2.1	1,774.4	5,609.4	
		No.4	49,429.6	723.0	720.5	743.9	771.7	735.1	0.1	0.0	0.0	0.0	0.0	109.2	696.9	4,500.4	53,930.0	
		No.5	将来設備															
	水中ミキサー	No.1	159,859.0	705.0	701.9	727.3	750.7	702.3	719.6	722.1	740.8	719.6	719.7	735.5	723.6	8,668.1	168,527.1	
No.2		59,034.5	723.5	720.5	743.9	748.1	735.1	719.9	722.1	741.1	719.9	720.4	672.6	724.3	8,691.4	67,725.9		
脱臭ファン	No.1		720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	696.0	744.0	8,784.0			
須津	破砕機	No.1-1	118,830.3	680.1	687.7	716.1	739.0	185.3	23.4	687.9	716.1	697.7	689.2	616.0	681.5	7,120.0	125,950.3	
		No.1-2	119,817.7	680.1	687.7	716.1	739.0	185.3	23.4	687.9	716.1	697.7	689.3	616.0	681.5	7,120.1	126,937.8	
	汚水ポンプ	No.1	63,605.8	679.2	1.2	715.3	2.0	180.0	0.5	686.2	0.2	677.2	136.3	612.7	0.5	3,691.3	67,297.1	
		No.2	61,646.4	0.6	687.2	2.8	737.2	10.1	22.0	0.1	714.0	4.0	545.5	0.8	676.7	3,401.0	65,047.4	
		No.3	将来設備															
		No.4	319.2	0.9	0.0	0.0	0.6	482.2	621.5	1.6	2.0	7.5	7.7	85.8	4.5	1,214.3	1,533.5	
	水中ミキサー		9,184.3	718.7	719.8	749.3	762.2	191.5	24.4	720.9	742.2	719.8	713.5	642.9	719.2	7,424.4	16,608.7	
			9,181.4	215.9	0.0	0.0	337.1	744.7	718.6	720.9	742.2	719.8	714.2	743.1	719.2	6,375.7	15,557.1	
	脱臭ファン	No.1	112,708.3	718.3	719.5	748.7	763.3	738.4	718.4	720.4	741.6	718.1	713.9	737.0	718.5	8,756.1	121,464.4	
	床排水ポンプ	No.1	29.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	29.1	
		No.2	16.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.2	16.9	
	シール水ポンプ	No.1	22,101.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	22,101.0	
No.2		15,866.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	15,866.1		

中継ポンプ場（その2）

（単位：時間）

設備	機器名	No	26年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	27年度計	27年度まで累計
堂谷	破 砕 機	No.1-1	97,415.4	596.6	588.1	608.6	652.2	631.8	614.1	591.4	626.1	614.0	541.0	635.8	610.6	7,310.3	104,725.7
		No.1-2	97,415.4	596.6	588.1	608.6	652.2	631.8	614.1	591.4	626.1	614.0	541.0	635.8	610.6	7,310.3	104,725.7
	汚 水 ポ ン プ	No.1	49,414.3	596.6	106.8	608.6	130.0	631.8	128.8	591.4	115.9	614.0	207.8	635.8	129.0	4,496.5	53,910.8
		No.2	54,201.1	102.6	588.1	107.6	652.2	136.3	614.1	109.4	626.1	124.4	541.0	139.0	610.6	4,351.4	58,552.5
		No.3	将来設備														
		No.4	241.8	4.4	4.2	4.4	2.6	0.0	0.9	3.2	4.0	4.0	4.2	5.0	5.1	42.0	283.8
		No.5	将来設備														
	水 中 ミ キ サ ー	No.1	148,232.5	718.3	719.9	743.1	773.5	736.9	719.9	719.3	742.4	697.7	720.2	742.4	719.0	8,752.6	156,985.1
		No.2	64,824.5	718.3	256.7	743.1	526.9	0.0	120.7	719.0	742.4	715.5	720.2	742.4	719.0	6,724.2	71,548.7
	脱 臭 フ ァ ン	No.1	45,664.1	258.2	256.7	262.0	268.5	252.1	250.5	252.0	262.4	255.9	259.1	263.5	253.9	3,094.8	48,758.9
	床 排 水 ポ ン プ	No.1	4.1	0.0	0.0	0.1	0.0	2.2	0.0	0.0	0.0	0.1	0.0	0.0	0.0	2.4	6.5
		No.2	3.6	0.0	0.0	0.0	7.2	0.0	0.1	0.0	0.0	0.1	0.0	0.0	0.0	7.4	11.0
	シ ー ル 水 ポ ン プ	No.1	12,108.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	12,108.7
		No.2	12,579.8	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.0	0.0	0.4	12,580.2
四辻	破 砕 機	No.1-1	86,544.8	522.3	603.1	544.4	666.8	623.5	657.2	520.5	585.7	561.1	543.6	597.2	634.4	7,059.8	93,604.6
		No.1-2	83,409.4	522.3	603.1	544.4	666.8	623.5	657.2	520.5	585.7	561.1	543.6	597.2	634.4	7,059.8	90,469.2
	汚 水 ポ ン プ	No.1	48,314.2	522.3	93.9	544.4	114.3	623.5	208.0	520.5	132.7	561.1	191.9	597.2	120.0	4,229.8	52,544.0
		No.2	50,924.7	23.7	603.1	30.1	666.8	137.4	657.2	26.4	585.7	43.3	543.6	91.0	634.4	4,042.7	54,967.4
		No.3	119.7	3.7	3.3	3.2	3.5	3.9	1.5	1.0	3.4	3.7	3.0	3.7	3.1	37.0	156.7
		No.4	将来設備														
	水 中 ミ キ サ ー	No.1	154,824.6	718.5	720.4	718.4	767.8	743.3	719.8	696.2	744.8	720.0	721.5	740.5	719.7	8,730.9	163,555.5
		No.2	24,711.4	718.5	720.3	743.7	767.8	743.3	263.1	213.7	744.8	720.0	719.6	740.5	719.7	7,815.0	32,526.4
	脱 臭 フ ァ ン	No.1	40,965.0	145.9	145.2	150.0	155.0	148.0	144.8	146.3	150.2	146.8	147.8	151.2	146.8	1,778.0	42,743.0
	床 排 水 ポ ン プ	No.1	3.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.0	0.0	0.2	3.2
		No.2	4.8	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.1	0.0	0.0	0.3	5.1
	シ ー ル 水 ポ ン プ	No.1	10,758.4	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1	10,758.5
		No.2	11,718.9	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1	11,719.0