

# 4 機 械 関 係

## (1) 機械設備稼動状況

浄化センター（その1）

（単位：時間）

設備	機 器 名	No	28年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	29年度計	29年度まで累計
沈砂池設備	揚 砂 ポ ン プ	No.1-1	90.6	0.6	0.7	0.5	1.0	0.3	0.2	0.6	0.4	0.5	0.4	0.2	0.3	5.7	96.3
		No.1-2	92.7	0.5	0.5	0.6	1.1	0.2	0.3	0.4	0.3	0.5	0.3	0.1	0.3	5.1	97.8
	細 目 除 塵 機	No.1	1,035.8	2.1	2.4	1.7	2.3	2.1	2.0	1.8	2.2	2.1	1.7	2.0	2.5	24.9	1,060.7
		No.1	1,000.5	1.7	1.1	1.5	1.7	0.8	1.1	1.8	2.5	1.4	1.1	0.9	1.5	17.1	1,017.6
		No.2	1,017.2	1.5	1.1	1.5	1.7	1.4	1.1	1.8	2.5	1.4	1.1	0.9	1.4	17.4	1,034.6
	し 渣 搬 出 コ ン ベ ア	No.3	1,060.7	2.8	2.5	1.5	2.4	1.3	2.9	2.4	2.9	1.8	2.0	1.3	2.3	26.1	1,086.8
		No.1	121,010.2	715.8	740.5	712.4	690.9	732.7	715.4	736.6	719.3	742.4	743.1	658.4	738.1	8,645.6	129,655.8
	床 排 水 ポ ン プ	No.1	24.9	0.1	0.1	0.1	0.1	0.1	0.1	0.3	0.1	0.1	0.1	0.1	0.1	1.4	26.3
し 渣 ・ 沈 砂 洗 浄 機	No.1	1,189.6	3.3	2.7	2.0	3.7	1.4	2.9	3.1	2.7	2.1	1.9	1.6	2.2	29.6	1,219.2	
沈砂搬出コンベア	No.1	260.7	3.7	3.1	1.6	3.5	1.3	1.8	3.3	2.6	2.1	2.0	1.4	2.1	28.5	289.2	
最初沈殿池	生汚泥引抜ポンプ	No.1	12,367.8	93.3	1.2	56.3	4.1	153.5	18.5	87.5	1.6	130.3	14.5	126.7	6.0	693.5	13,061.3
		No.2	12,381.7	9.0	62.8	2.9	79.8	1.4	127.7	6.7	107.6	1.1	127.4	1.5	120.5	648.4	13,030.1
	床排水ポンプ	No.1	92.8	6.5	8.8	4.0	3.8	3.9	3.8	21.5	8.0	8.4	8.3	14.7	7.2	98.9	191.7
	1系初沈汚泥掻寄機	No.1-1	162,019.6	356.4	619.0	715.7	742.0	742.3	706.7	613.6	590.9	441.7	429.6	389.3	488.3	6,835.5	168,855.1
		No.1-2	120,402.7	356.4	618.7	715.2	741.8	742.3	706.7	691.1	532.3	441.7	429.6	389.3	507.4	6,872.5	127,275.2
	2系汚泥掻寄機	No.2	64,555.8	357.2	619.8	715.6	742.0	742.3	706.7	613.2	589.4	399.3	385.8	350.0	496.2	6,717.5	71,273.3
	3系汚泥掻寄機	No.3	81,029.8	360.2	624.0	717.9	743.2	743.8	707.4	613.7	590.9	443.8	432.2	390.9	509.5	6,877.5	87,907.3
	池排水ポンプ	No.1	71.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	0.0	0.0	1.0	72.3
	初沈スカム排水ポンプ	No.1	4,175.5	37.4	4.9	48.5	5.9	53.0	1.2	49.2	1.4	43.8	0.1	0.1	1.5	247.0	4,422.5
		No.2	4,700.7	2.8	40.9	1.5	46.0	1.4	53.1	2.3	47.4	6.2	51.7	50.2	18.7	322.2	5,022.9
汚泥処理設備	濃縮汚泥掻寄機	No.1	113,666.9	716.5	619.9	717.6	741.4	740.7	717.6	738.1	716.6	740.6	741.9	670.0	741.6	8,602.5	122,269.4
		No.2	67,624.6	718.0	741.0	717.7	742.1	741.1	717.9	733.6	716.6	741.4	742.3	671.2	741.2	8,724.1	76,348.7
	脱水ろ液移送ポンプ	No.1	40,876.4	369.9	348.2	449.2	362.6	535.8	437.0	479.2	413.7	448.6	176.5	400.1	230.9	4,651.7	45,528.1
		No.2	48,590.0	77.7	451.3	418.1	463.9	109.1	459.2	309.1	533.0	19.0	370.4	11.4	483.0	3,705.2	52,295.2
	汚泥貯留槽攪拌機	No.1	116,725.2	348.1	397.4	377.8	391.2	371.6	345.2	358.6	354.2	362.0	356.0	322.7	383.9	4,368.7	121,093.9
	汚泥供給ポンプ	No.1	3,154.2	0.3	4.1	17.2	18.7	70.4	0.8	13.9	17.2	206.6	21.0	146.8	40.8	557.8	3,712.0
		No.2	3,018.4	41.4	15.5	11.4	2.1	13.4	4.3	29.2	2.5	4.8	130.4	37.2	68.8	361.0	3,379.4
		No.3	13,180.0	154.8	17.0	115.1	0.0	0.2	0.0	86.6	184.7	8.7	53.4	0.0	1.5	622.0	13,802.0
		No.4	13,730.0	8.2	228.6	102.3	230.7	123.9	179.6	66.3	0.0	0.0	11.3	8.6	124.1	1,083.6	14,813.6
	濃縮汚泥移送ポンプ	No.1	8,141.9	37.2	10.2	48.3	29.6	37.3	5.1	31.2	3.0	41.4	25.2	42.3	24.9	335.7	8,477.6
		No.2	6,792.1	3.1	36.6	24.0	30.9	5.3	34.1	3.4	41.9	1.6	39.9	25.9	38.1	284.8	7,076.9
	給 水 ポ ン プ	No.1	895.5	8.4	0.2	9.5	0.5	11.3	0.0	8.4	0.1	13.0	1.0	12.1	0.1	64.6	960.1
		No.2	997.7	0.5	9.8	0.0	10.4	0.0	7.5	0.0	8.2	0.0	10.8	0.0	10.7	57.9	1,055.6
	脱 臭 フ ァ ン	No.1	202,335.0	719.3	743.6	719.0	743.2	743.3	719.4	736.0	719.6	742.2	743.8	665.9	743.4	8,738.7	211,073.7
	ろ 布 洗 浄 ポ ン プ	No.3	18,195.2	210.8	4.0	266.7	30.6	154.1	0.0	194.4	5.6	16.8	8.0	16.3	0.1	907.4	19,102.6
		No.4	18,161.9	10.7	300.7	5.2	253.6	3.2	227.5	5.8	227.3	1.5	78.1	0.1	167.1	1,280.8	19,442.7
	床 排 水 ポ ン プ	No.1	440.8	47.0	0.9	27.2	4.7	37.9	0.7	34.0	0.7	28.7	3.4	25.9	0.5	211.6	652.4
No.2		332.2	4.3	23.1	1.5	18.8	2.8	32.4	11.0	30.3	5.9	22.5	0.5	24.7	177.8	510.0	

浄化センター（その2）

（単位：時間）

設備	機器名	No	28年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	29年度計	29年度まで累計
汚泥処理設備	空気圧縮機	No.1	4,764.0	80.2	0.1	0.0	16.3	0.1	0.1	0.1	0.0	69.3	0.1	0.0	4.0	170.3	4,934.3
		No.2	5,070.8	81.6	179.0	174.9	179.3	194.2	189.5	187.3	180.3	178.4	198.8	174.4	167.7	2,085.4	7,156.2
	溶解槽攪拌機	No.1	1,035.4	5.1	1.2	3.6	3.6	10.1	1.5	8.2	2.9	19.2	15.2	23.7	8.4	102.7	1,138.1
		No.2	27,315.4	13.5	23.6	36.9	18.4	11.4	14.1	8.1	17.7	1.3	5.7	0.1	11.1	161.9	27,477.3
	薬品定量供給機	No.1	202.6	1.0	0.4	0.5	0.7	2.3	0.2	1.1	0.6	5.6	3.9	4.9	2.2	23.4	226.0
	薬品供給機	No.1	890.9	3.2	4.5	4.2	4.5	2.8	3.3	3.1	3.6	0.0	1.7	0.0	2.8	33.7	924.6
	薬品供給ポンプ	No.1	3,147.7	0.3	4.1	24.8	18.8	80.0	0.8	31.4	2.5	206.6	21.0	180.3	48.9	619.5	3,767.2
		No.2	3,057.9	41.5	15.7	3.9	2.2	4.2	4.4	11.8	17.2	5.2	130.9	4.5	61.2	302.7	3,360.6
		No.3	13,332.2	154.8	3.0	212.7	34.0	120.9	0.1	146.9	4.2	0.0	0.0	5.1	0.0	681.7	14,013.9
		No.4	13,632.4	8.2	242.7	4.7	196.7	3.4	179.5	5.9	180.4	8.6	64.7	3.5	125.6	1,023.9	14,656.3
脱水機	No.1	6,172.6	41.7	19.6	28.6	20.8	83.8	5.1	43.1	19.7	211.4	151.4	184.0	109.6	918.8	7,091.4	
	No.2	26,916.0	163.0	245.6	217.4	230.7	124.1	179.6	152.9	184.7	8.7	64.7	8.6	125.6	1,705.6	28,621.6	
送風	送風機	No.1-1	77,176.5	0.6	0.0	0.3	2.8	25.6	26.0	21.8	0.0	0.2	0.0	0.5	2.3	80.1	77,256.6
		No.1-2	71,972.4	0.6	0.0	0.3	2.8	0.0	25.0	21.9	0.0	0.2	0.0	0.3	2.3	53.4	72,025.8
		No.2-1	86,488.3	620.0	1.7	26.2	7.8	1.1	283.4	705.8	704.7	742.5	508.2	665.4	427.4	4,694.2	91,182.5
		No.2-2	31,187.3	96.3	742.3	693.5	733.3	742.8	410.3	9.8	13.8	0.5	233.6	5.5	313.4	3,995.1	35,182.4
エアタン	水中攪拌機	No.1-1	67,708.8	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	328.8	8,344.8	76,053.6
		No.1-2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
		No.2-1	70,127.7	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,760.0	78,887.7
		No.2-2	72.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	72.0
	散気装置	No.3-1	87,600.9	716.8	742.8	719.0	743.4	743.4	718.9	737.9	717.6	748.9	740.0	672.0	745.7	8,746.4	96,347.3
		No.3-2	87,378.4	716.8	742.8	719.0	743.0	743.4	718.9	737.9	717.6	748.9	740.0	672.0	745.7	8,746.0	96,124.4
最終沈殿池	1系返送汚泥ポンプ	No.1	36,462.3	658.6	10.1	709.1	62.8	734.2	10.9	701.8	10.2	732.7	82.2	661.3	10.3	4,384.2	40,846.5
		No.2	37,333.6	58.3	733.9	10.8	681.0	9.7	709.0	35.2	708.6	10.5	659.7	10.5	733.6	4,360.8	41,694.4
	2系返送汚泥ポンプ	No.1	43,504.5	658.6	10.0	708.4	62.9	734.1	11.0	701.7	10.2	732.7	82.4	661.2	10.3	4,383.5	47,888.0
		No.2	43,993.9	58.3	733.9	11.4	678.4	9.8	709.0	35.2	708.5	10.4	659.5	10.4	733.6	4,358.4	48,352.3
	余剰汚泥ポンプ	No.1	16,532.1	35.7	56.3	64.9	64.1	60.6	70.5	66.3	55.2	56.6	60.5	59.9	75.3	725.9	17,258.0
		No.2	1,593.0	0.1	0.1	0.1	0.1	0.5	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.6	1,594.6
		No.3	4,184.6	39.1	47.5	41.5	36.6	43.1	35.1	34.0	27.2	34.2	43.5	27.4	49.1	458.3	4,642.9
	1系終沈汚泥掻寄機	No.1-1	188,018.1	710.2	736.0	712.8	737.8	737.4	713.7	733.2	714.6	736.9	736.8	666.5	530.9	8,466.8	196,484.9
		No.1-2	192,238.5	705.9	736.1	713.4	737.8	738.1	713.7	733.5	714.6	736.9	736.6	666.8	530.8	8,464.2	200,702.7
	2系終沈汚泥掻寄機	No.2	163,802.6	710.5	737.0	713.2	738.2	737.8	713.5	733.1	714.3	736.7	736.5	666.8	737.0	8,674.6	172,477.2
	3系終沈汚泥掻寄機	No.3	87,127.4	716.5	740.2	715.9	740.3	740.9	716.9	736.7	716.9	738.9	739.3	669.1	737.7	8,709.3	95,836.7
	A・T床排水ポンプ	No.1	2,769.0	11.0	10.9	10.8	9.8	10.4	10.3	9.1	1.0	1.7	2.1	1.8	1.4	80.3	2,849.3
	終沈床排水ポンプ	No.1	2,133.0	0.9	0.1	1.0	0.3	2.8	0.1	5.9	0.4	10.6	1.3	10.1	8.4	41.9	2,174.9
		No.2	1,835.2	0.2	0.5	0.1	2.3	0.1	3.3	0.1	8.5	0.3	10.1	0.2	41.8	67.5	1,902.7
終沈スカム排水ポンプ	No.1	11,725.6	81.7	0.9	68.9	5.8	49.6	0.7	48.5	4.2	58.4	7.1	51.6	1.2	378.6	12,104.2	
	No.2	10,138.6	4.8	62.2	1.0	45.8	0.8	43.1	2.3	44.9	0.6	38.9	0.7	20.7	265.8	10,404.4	
池排水ポンプ	No.1	64.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.2	5.2	69.9	

浄化センター（その3）

（単位：時間）

設備	機器名	No	28年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	29年度計	29年度まで累計
用水設備	原水ポンプ	No.1	36,232.4	3.3	0.3	3.8	0.1	22.9	0.0	3.9	0.1	3.1	0.2	6.5	0.1	44.3	36,276.7
		No.2	32,671.6	0.4	105.2	0.0	5.4	0.3	3.2	0.1	3.1	0.1	13.4	2.4	3.5	137.1	32,808.7
		No.3	12,507.0	248.7	214.2	239.1	252.3	231.0	252.3	238.3	299.8	113.1	153.6	95.4	265.7	2,603.5	15,110.5
	消泡水ポンプ	No.1	2,048.6	16.1	1.6	5.1	2.1	2.5	0.0	10.0	0.1	2.9	0.4	2.6	0.0	43.4	2,092.0
		No.2	1,763.9	0.1	15.5	0.0	5.4	2.3	4.1	0.0	10.2	0.1	3.4	0.0	8.0	49.1	1,813.0
	逆洗排水ポンプ	No.1	4,335.1	24.8	0.1	7.9	0.1	20.7	0.1	4.1	0.0	4.4	5.2	8.4	0.0	75.8	4,410.9
		No.2	4,539.2	0.3	68.3	0.0	4.4	0.1	4.6	0.1	12.8	0.1	12.7	0.0	27.0	130.4	4,669.6
	濾過水移送ポンプ	No.1	7,696.9	80.9	1.6	88.5	9.6	69.5	0.9	73.0	1.6	20.3	2.0	17.3	0.1	365.3	8,062.2
		No.2	8,080.2	5.1	114.6	3.1	88.6	2.0	87.2	3.1	87.8	0.3	37.3	0.2	72.5	501.8	8,582.0
	空気圧縮機	No.1	12,991.5	8.1	0.2	8.8	0.6	8.1	0.2	7.3	0.1	8.8	1.5	14.1	0.2	58.0	13,049.5
		No.2	13,414.5	0.2	43.1	0.1	5.9	0.1	5.4	0.3	9.2	0.2	20.1	0.2	22.4	107.2	13,521.7
	用水床排水ポンプ	No.1	742.3	20.0	0.4	16.6	1.6	12.8	0.3	23.0	0.6	34.6	4.3	32.0	0.4	146.6	888.9
		No.2	834.8	2.2	24.1	0.4	15.2	0.4	13.1	0.9	35.1	0.6	36.9	0.5	26.2	155.6	990.4
	ろ過器	No.2	12,507.0	248.7	214.2	239.1	252.3	231.0	252.3	238.3	299.8	113.1	153.6	95.4	265.7	2,603.5	15,110.5
次亜塩素酸ソーダ注入ポンプ	No.1	84,931.7	715.5	738.5	718.6	743.4	741.1	717.9	736.0	717.9	742.9	741.6	667.0	736.9	8,717.3	93,649.0	
	No.2	87,009.4	0.2	5.0	0.5	0.4	2.4	1.5	0.1	0.3	0.2	0.2	0.4	0.2	11.4	87,020.8	
	No.3	10,111.0	0.2	0.3	0.5	0.3	0.3	0.5	0.2	0.2	0.1	0.1	0.2	0.1	3.0	10,114.0	
機械濃縮設備	※余剰汚泥貯留槽攪拌機	No.1	107,343.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	107,343.4
	汚泥供給ポンプ	No.1	32,799.5	233.1	34.7	394.8	31.0	359.8	5.3	339.1	5.9	327.6	38.2	275.3	4.0	2,048.8	34,848.3
		No.3	32,990.9	22.7	331.2	0.8	330.5	8.4	373.8	22.2	295.8	5.3	338.0	5.4	492.9	2,227.0	35,217.9
	浮上濃縮機	No.1	65,788.2	255.8	365.9	395.7	361.5	368.1	379.0	361.3	301.5	333.0	376.2	280.6	496.9	4,275.5	70,063.7
	凝集剤供給機	No.1	653.4	4.2	5.7	6.0	6.5	8.1	7.0	5.4	4.5	5.0	5.5	4.0	7.2	69.1	722.5
		No.2	668.8	4.2	5.4	6.0	6.0	8.1	7.5	5.4	4.5	5.1	5.4	4.2	7.8	69.6	738.4
	凝集剤注入ポンプ	No.1	33,069.6	234.9	34.9	396.0	31.1	361.7	5.3	340.6	6.2	329.7	38.4	277.2	4.1	2,060.1	35,129.7
		No.2	33,145.5	22.7	332.1	0.8	331.7	8.4	375.0	22.3	296.0	5.5	339.7	5.5	493.9	2,233.6	35,379.1
	濃縮汚泥貯留槽攪拌機	No.1	22,860.9	3.6	5.6	5.5	7.9	7.7	2.3	6.3	2.5	2.5	4.8	13.5	3.4	65.6	22,926.5
	濃縮汚泥移送ポンプ	No.1	1,714.9	14.1	4.3	17.4	9.6	10.4	12.5	11.1	9.5	10.1	10.5	7.9	11.2	128.6	1,843.5
		No.2	1,683.1	1.0	16.8	3.7	10.1	9.7	10.5	10.2	8.4	9.0	9.4	8.6	9.5	106.9	1,790.0
	凝集剤溶解槽攪拌機	No.1	5,624.5	17.8	23.9	26.7	26.9	34.3	31.9	22.9	19.1	21.7	22.9	17.8	33.1	299.0	5,923.5
		No.2	5,674.4	17.6	24.2	25.2	25.4	33.9	30.3	23.9	18.8	20.0	23.0	17.5	31.8	291.6	5,966.0
	空気圧縮機	No.1	18,183.0	160.0	80.0	290.0	20.0	200.0	0.0	230.0	10.0	180.0	30.0	160.0	0.0	1,360.0	19,543.0
		No.2	19,260.0	20.0	190.0	10.0	250.0	20.0	310.0	20.0	300.0	0.0	240.0	10.0	250.0	1,620.0	20,880.0
	起泡水ポンプ	No.1	31,681.6	207.7	32.2	397.9	130.4	364.1	14.3	335.1	10.9	325.6	41.7	270.2	101.0	2,231.1	33,912.7
		No.3	34,496.9	49.6	331.9	0.9	230.3	3.4	365.8	30.9	290.2	11.4	332.6	11.9	391.6	2,050.5	36,547.4
	起泡助剤希釈槽攪拌機	No.1	393.9	0.0	1.3	2.6	1.3	1.2	2.6	1.3	1.3	1.3	1.2	1.3	1.4	16.8	410.7
	起泡助剤注入ポンプ	No.1	33,176.4	229.3	32.2	397.9	36.2	352.1	14.6	335.1	10.9	325.6	41.7	270.7	10.8	2,057.1	35,233.5
		No.3	33,047.5	28.0	331.9	0.9	324.4	15.3	366.1	30.9	290.2	11.4	332.7	12.0	482.8	2,226.6	35,274.1
脱気槽攪拌機	No.1	66,882.1	257.2	365.6	400.5	362.2	369.0	381.7	367.6	302.6	338.7	376.0	283.8	494.2	4,299.1	71,181.2	
床排水ポンプ	No.1	768.9	1.6	2.3	3.2	0.3	3.4	0.1	2.1	0.2	1.8	0.2	1.6	0.1	16.9	785.8	
	No.2	770.6	0.1	2.9	0.1	4.8	0.1	2.0	0.2	1.7	0.1	1.7	0.1	3.1	16.9	787.5	

中継ポンプ場（その1）

（単位：時間）

設備	機器名	No	28年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	29年度計	29年度まで累計	
獅子崎	細目除塵機	No.1		15.0	12.4	15.0	15.5	15.5	15.0	15.5	15.0	15.5	15.5	11.2	15.5	176.6		
	破砕機	No.1		35.0	28.9	35.0	36.1	36.1	35.0	36.1	35.0	36.1	36.1	26.1	36.1	411.6		
	汚水ポンプ	No.1	56,525.2	0.1	0.1	0.1	2.8	0.3	20.9	0.1	0.1	0.1	0.1	8.3	4.2	1.2	38.3	56,563.5
		No.2	55,556.3	0.0	0.1	0.1	0.2	0.3	34.4	0.1	1.2	0.1	0.1	7.8	4.1	1.2	49.6	55,605.9
		No.3	5,295.8	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.2	5,297.0
		No.4	72,294.3	663.1	794.1	721.4	736.3	719.1	722.2	736.0	713.8	719.9	782.5	666.9	699.2	8,674.5	80,968.8	
		No.5	将来設備															
	水中ミキサー	No.1	104,687.6	667.4	794.6	722.0	739.6	719.9	721.9	742.8	716.4	720.5	791.8	671.6	715.9	8,724.4	113,412.0	
		No.2	149,440.2	667.4	582.1	599.3	739.6	719.4	720.4	742.7	717.5	717.8	791.8	669.9	716.4	8,384.3	157,824.5	
	脱臭ファン	No.1	102,290.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,760.0	111,050.0	
鶴賀	細目除塵機	No.1		20.1	12.4	20.1	20.8	20.8	20.1	20.8	20.1	20.8	20.8	11.2	20.8	228.8		
	破砕機	No.1		46.8	28.9	46.8	48.5	48.5	46.8	48.5	46.8	48.5	48.5	26.1	48.5	533.2		
	汚水ポンプ	No.1	67,984.6	15.5	0.5	28.2	1.7	6.0	0.5	11.1	2.2	14.4	0.5	12.2	1.0	93.8	68,078.4	
		No.2	68,363.8	1.1	14.6	1.0	13.4	34.4	67.0	3.7	12.6	2.1	17.9	0.4	6.2	174.4	68,538.2	
		No.3	5,631.3	1.1	1.5	1.6	2.3	1.0	4.1	5.0	8.8	5.7	3.7	1.5	2.1	38.4	5,669.7	
		No.4	62,486.8	646.8	775.0	686.4	723.9	712.2	701.9	723.1	693.2	697.9	768.7	656.4	700.0	8,485.5	70,972.3	
		No.5	将来設備															
	水中ミキサー	No.1	177,297.1	669.3	792.6	718.5	741.5	719.5	365.9	0.0	0.0	—	—	—	—	4,007.3	181,304.4	
		No.2	—	—	—	—	—	—	—	—	—	409.9	791.8	670.8	720.1	2,592.6	2,592.6	
			76,496.6	669.9	793.6	718.9	742.0	366.5	0.0	0.0	0.0	0.0	617.9	671.1	720.0	5,299.9	81,796.5	
脱臭ファン	No.1		720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,760.0			
須津	破砕機	No.1-1	134,424.6	643.1	761.1	694.3	727.4	712.3	669.1	728.8	704.7	701.7	765.0	654.5	696.1	8,458.1	142,882.7	
		No.1-2	135,365.5	643.1	761.1	694.3	727.3	710.6	581.7	728.8	704.7	701.7	765.0	654.5	696.1	8,368.9	143,734.4	
	汚水ポンプ	No.1	69,834.3	641.1	16.1	688.8	1.3	689.1	32.8	719.7	6.6	695.1	141.6	648.0	648.7	4,928.9	74,763.2	
		No.2	71,029.7	24.5	754.9	384.7	715.8	15.2	667.8	40.9	697.5	6.9	620.8	0.2	17.6	3,946.8	74,976.5	
		No.3	将来設備															
		No.4	1,577.9	1.8	5.0	5.6	11.8	23.1	31.1	9.5	6.9	6.4	6.5	6.3	30.0	144.0	1,721.9	
	水中ミキサー		25,386.7	671.0	791.2	719.8	742.9	720.1	716.9	744.4	718.6	720.3	790.9	671.5	719.8	8,727.4	34,114.1	
			24,337.4	671.0	791.2	719.8	742.7	720.1	719.3	744.4	718.6	720.3	791.2	671.5	719.8	8,729.9	33,067.3	
	脱臭ファン	No.1	130,201.2	671.2	790.4	718.9	741.3	714.1	719.2	742.9	718.2	720.0	789.3	665.4	719.4	8,710.3	138,911.5	
	床排水ポンプ	No.1	29.2	0.0	1.3	1.8	0.2	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.0	3.5	32.7	
No.2		17.1	0.0	1.1	0.0	0.2	0.0	0.0	0.0	0.1	0.1	0.1	0.0	0.1	1.7	18.8		
シール水ポンプ	No.1	22,101.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	22,101.4		
	No.2	15,866.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	15,866.5		

中継ポンプ場（その2）

（単位：時間）

設備	機器名	No	28年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	29年度計	29年度まで累計	
堂谷	破 碎 機	No.1-1	112,196.9	570.3	669.1	598.3	629.9	612.7	585.5	611.7	611.7	602.6	585.0	565.2	597.6	7,239.6	119,436.5	
		No.1-2	112,296.9	570.3	669.1	598.3	629.9	612.7	585.5	611.7	611.7	602.6	585.0	565.2	597.6	7,239.6	119,536.5	
	汚 水 ポ ン プ	No.1	58,381.4	570.3	143.7	598.3	135.1	612.7	156.0	611.7	119.7	602.6	76.1	565.2	96.8	4,288.2	62,669.6	
		No.2	63,158.2	110.6	669.1	114.6	629.9	149.9	585.5	119.1	611.7	82.7	585.0	71.8	597.6	4,327.5	67,485.7	
		No.3	将来設備															
		No.4	348.6	3.8	5.8	7.3	7.4	8.5	13.9	8.5	0.9	1.0	1.9	0.1	0.1	59.2	407.8	
		No.5	将来設備															
	水 中 ミ キ サ ー	No.1	156,756.0	671.9	790.8	719.7	743.5	715.3	719.0	741.6	717.5	717.7	791.4	671.1	719.3	8,718.8	165,474.8	
		No.2	80,227.0	671.9	790.8	719.7	741.7	715.3	694.4	745.5	717.4	711.5	791.2	671.1	719.3	8,689.8	88,916.8	
	脱 臭 フ ァ ン	No.1	51,878.5	238.2	278.2	252.0	260.6	252.3	253.6	268.8	270.4	253.3	286.9	239.2	253.9	3,107.4	54,985.9	
	床 排 水 ポ ン プ	No.1	6.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.2	6.7
		No.2	11.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	0.2	11.3
	シ ー ル 水 ポ ン プ	No.1	12,108.7	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.0	0.1	0.0	0.0	0.3	12,109.0
		No.2	12,580.2	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	12,580.3
四辻	破 碎 機	No.1-1	100,993.2	558.1	724.5	593.6	645.8	607.0	641.3	624.2	664.1	593.2	735.0	555.5	670.7	7,613.0	108,606.2	
		No.1-2	97,857.8	558.1	724.5	593.6	645.8	607.0	641.3	624.2	664.1	593.2	735.0	555.5	670.7	7,613.0	105,470.8	
	汚 水 ポ ン プ	No.1	56,790.3	558.1	200.0	593.6	130.2	607.0	171.9	624.2	217.4	593.2	158.5	555.5	122.0	4,531.6	61,321.9	
		No.2	59,386.8	96.2	724.5	111.9	645.8	128.6	641.3	130.9	664.1	77.3	735.0	47.3	670.7	4,673.6	64,060.4	
		No.3	196.3	2.5	3.7	4.2	3.9	4.5	3.4	4.0	3.6	4.2	2.6	3.8	4.1	44.5	240.8	
		No.4	将来設備															
	水 中 ミ キ サ ー	No.1	172,330.5	671.9	791.3	719.4	745.0	720.3	717.8	738.5	721.3	720.2	792.2	671.4	719.8	8,729.1	181,059.6	
		No.2	41,305.4	671.9	791.3	719.4	745.0	720.3	717.8	739.2	721.3	720.2	792.2	671.4	719.8	8,729.8	50,035.2	
	脱 臭 フ ァ ン	No.1	44,514.8	136.6	159.6	144.2	148.5	143.0	142.7	148.7	145.4	145.9	306.1	135.8	146.1	1,902.6	46,417.4	
	床 排 水 ポ ン プ	No.1	3.3	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	3.4	
		No.2	5.3	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	5.5	
	シ ー ル 水 ポ ン プ	No.1	10,758.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10,758.5	
		No.2	11,719.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	11,719.0	