

4 機械関係

(1) 機械設備稼働状況

No. 1 (単位:時間)

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計	
自家発棟	非常用自家発電機	No.4		185.2	0.2	0.1	0.2	0.1	0.2	0.2	0.2	0.1	0.2	0.1	1.8	1.7	5.1	190.3	
		No.3		57.1	0.1	0.2	0.1	0.2	0.2	0.1	0.2	0.2	0.1	0.2	1.7	1.7	5.0	62.1	
第1ポンプ棟	主ポンプ	1号	(J-H-N6)	2,488.3	22.4	25.1	34.5	48.6	12.4	37.6	33.6	3.7	5.1	34.9	38.8	0.1	296.8	2,785.1	
		2号	(J-H-N3)	2,348.5	43.1	19.8	42.7	81.4	8.8	86.2	13.3	0.5	7.1	35.6	39.3	7.2	385.0	2,733.5	
		3号	(J-H-N5)	125,658.5	622.3	671.7	615.4	589.1	693.1	500.1	488.4	499.1	443.9	393.2	484.1	577.8	6,578.2	132,236.7	
		4号	(J-H-N2)	90,372.7	245.1	360.2	370.2	425.0	289.6	434.7	487.6	478.5	604.1	502.5	363.8	438.5	4,999.8	95,372.5	
		5号	インバータ盤	133,523.0	314.0	259.3	208.4	190.1	298.9	202.8	256.5	278.0	237.6	247.8	163.8	278.3	2,935.5	136,458.5	
第1ポンプ棟 し渣設備 (J-C-N1)	し渣スキップホイスト		(2G)	1,873.5	-	-	-	-	-	-	-	-	-	-	-	-	0.0	1,873.5	
	細目自動除塵機	No.1	(3A)	12,979.6	27.4	29.6	28.0	30.2	30.5	29.6	30.4	29.8	30.7	61.8	6.5	20.1	354.6	13,334.2	
		No.2	(3B)	19,778.9	29.6	29.6	28.1	30.3	30.8	29.5	30.5	29.9	30.5	40.4	21.8	25.9	356.9	20,135.8	
		No.3	(3C)	20,534.1	29.9	29.5	28.5	30.5	31.1	30.5	22.0	0.3	2.0	26.5	25.4	24.2	280.4	20,814.5	
	し渣破碎機		(3D)	422.1	-	-	-	-	-	-	-	-	-	-	-	-	0.0	422.1	
	し渣脱水機		(3E)	22,851.5	-	-	-	-	-	-	-	-	-	-	-	-	0.0	22,851.5	
	粗目自動除塵機	No.1	(4A)	569.6	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	569.8
		No.2	(7C)	484.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	484.9
		No.3	(7E)	526.7	1.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.2	527.9
	し渣搬出機	No.1	(4D)	1,461.8	1.7	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.4	5.0	40.8	55.6	79.3	182.9	1,644.7
		No.2	(4E)	1,654.4	2.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.6	5.2	48.1	61.1	85.6	202.7	1,857.1
		No.3	(4F)	26,391.0	101.2	101.0	97.1	104.7	106.0	102.8	96.8	73.4	75.6	172.5	73.8	89.8	1,194.7	27,585.7	
		No.4	(4G)	23,540.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	23,540.6
	し渣洗浄攪拌機		(5D)	24,909.0	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	24,909.0
	予備		(6A)	0.0	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	0.0
沈砂池室床排水ポンプ	No.1	(6B)	3.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.7	
	No.2	(6C)	6.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.3	7.2	
	No.3	(6D)	3.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.3	4.1	

No. 2 (単位:時間)

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計	
第1ポンプ棟 沈砂設備 (J-C-N2)	高架水槽揚水ポンプ	No.1	(6E)	4,937.9	19.9	19.6	20.4	23.6	19.6	23.8	20.7	16.6	19.3	40.4	17.6	17.7	259.2	5,197.1	
		No.2	(6F)	4,955.1	19.3	19.1	19.8	23.1	19.1	23.1	20.4	16.3	18.7	39.3	17.7	17.3	253.2	5,208.3	
	沈砂池揚砂ポンプ	No.1	(2A)	1,694.1	3.1	2.5	2.5	3.5	2.0	0.0	2.6	2.4	3.0	5.1	1.2	0.9	28.8	1,722.9	
		No.2	(2B)	191.4	2.1	1.5	1.2	2.0	1.5	2.3	2.3	2.3	2.6	3.6	2.0	2.7	26.1	217.5	
		No.3	(2C)	163.8	1.4	2.0	1.3	1.3	0.9	2.6	1.5	0.0	2.5	3.6	1.5	2.5	21.1	184.9	
	沈砂洗浄攪拌機		(3A)	5,533.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	5,533.8
	沈砂搬出機		(3D)	6,319.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	6,319.7
沈砂スキップホイスト		(3E)	228.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	228.7	
第1ポンプ棟	主ポンプ室 床排水ポンプ	No.1	(2E)	7,538.8	34.8	34.1	40.2	52.3	35.9	54.5	43.3	32.0	41.8	45.8	40.7	33.8	489.2	8,028.0	
		No.2	(2F)	6,120.1	23.0	23.2	26.6	34.0	24.4	35.9	28.9	21.6	28.6	31.3	27.2	23.3	328.0	6,448.1	
	主ポンプ冷却水ポンプ	No.1	(2G)	126,910.2	166.2	447.0	303.1	643.6	408.9	319.1	265.7	370.4	456.3	213.5	442.4	298.5	4,334.7	131,244.9	
		No.2	(2H)	119,064.5	552.6	283.1	404.9	137.4	334.8	400.7	483.6	348.8	287.4	529.5	220.9	442.9	4,426.6	123,491.1	
	分配槽床排水ポンプ	No.1	(4D)	8.8	0.1	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	9.1
		No.2	(4E)	6.9	0.1	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.4	7.3
第1送風機棟 送風機設備 (C-C-C)	送風機3相420V	No.1	(2B)	79,876.1	222.6	321.1	292.1	204.3	401.5	433.3	231.1	139.4	113.8	56.2	83.1	111.7	2,610.2	82,486.3	
		No.2	(3B)	70,299.1	201.5	246.5	296.8	293.4	374.6	404.6	293.7	167.5	65.4	78.0	79.2	97.0	2,598.2	72,897.3	
		No.3	(4A)	116,160.0	181.5	116.8	132.0	449.5	260.9	145.1	200.5	67.7	82.3	118.9	121.5	83.2	1,959.9	118,119.9	
	送風機3相6600V	No.4	(C-H-C1)	112,932.5	45.0	69.1	53.7	25.8	44.0	201.1	416.7	629.7	661.0	604.4	551.5	531.4	3,833.4	116,765.9	
		No.5	(C-H-C2)	93,461.4	535.1	552.3	559.3	600.7	547.3	481.6	182.2	1.0	12.0	2.9	1.7	169.0	3,645.1	97,106.5	
		No.6	(C-H-C3)	65,881.4	3.5	30.1	2.6	8.3	6.8	9.5	3.3	0.5	3.1	0.5	0.5	0.1	68.8	65,950.2	
	潤滑油ポンプ	No.1	(7B)	122,518.6	82.0	413.8	508.1	203.2	53.6	412.5	534.8	263.8	50.4	478.6	97.8	165.1	3,263.7	125,782.3	
		No.2	(7C)	112,807.7	470.4	167.8	118.5	517.5	646.4	257.9	187.8	456.2	689.0	266.1	571.8	481.7	4,831.1	117,638.8	
		No.3	(9B)	82,382.6	79.3	540.8	109.1	537.0	46.3	390.8	206.6	0.0	0.0	1.6	3.2	172.7	2,087.4	84,470.0	
		No.4	(9C)	78,195.9	473.1	47.7	469.5	85.3	536.0	95.2	1.0	3.0	14.2	0.4	3.4	2.6	1,731.4	79,927.3	
	潤滑油冷却塔	No.1	(7F)	181,219.7	470.6	581.2	626.1	718.6	699.3	670.3	722.5	719.9	739.4	25.0	0.0	502.2	6,475.1	187,694.8	
		No.2	(9F)	116,874.8	480.0	581.7	578.5	622.0	582.3	485.9	207.5	2.9	14.2	0.0	0.0	175.3	3,730.3	120,605.1	
	冷却水ポンプ	No.1	(7D)	205,369.0	552.3	581.1	626.1	718.6	699.3	670.3	722.5	719.9	739.3	744.0	669.6	646.6	8,089.6	213,458.6	
		No.2	(7E)	32,797.4	79.3	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	79.4	32,876.8	
		No.3	(9D)	155,618.4	479.7	581.7	578.4	622.1	582.3	485.9	207.5	2.9	14.2	1.9	6.5	175.3	3,738.4	159,356.8	

No. 3 (単位:時間)

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計	
第1送風機棟 A系 最初沈殿池設備 (C-C-D1)	汚泥掻寄機	A-1-1	(2E)	32,191.2	0.8	0.8	116.3	744.0	25.6	4.8	1.3	0.0	0.1	1.6	0.5	0.9	896.7	33,087.9	
		A-1-2	(2F)	46,598.5	0.7	0.8	116.3	744.0	25.6	4.6	0.9	0.0	0.0	1.6	0.5	0.9	895.9	47,494.4	
		A-2	(2G)	161,091.5	719.9	743.9	605.6	0.8	717.7	719.6	737.8	719.8	743.6	744.0	671.4	743.1	7,867.2	168,958.7	
		A-3	(2A)	92,595.3	0.0	0.0	0.0	3.0	0.0	2.6	0.0	1.3	93.4	223.8	0.0	62.9	387.0	92,982.3	
		A-4	(6B)	50,199.5	0.7	2.1	115.7	744.0	25.6	5.6	1.3	1.4	0.0	1.7	0.2	0.9	899.2	51,098.7	
		A-5	(6C)	108,818.0	719.9	743.9	605.1	0.8	718.9	719.8	736.6	719.8	743.6	744.0	671.3	743.1	7,866.8	116,684.8	
	汚泥引抜ポンプ	A-1	(3E)	10,851.2	0.0	0.0	35.9	221.8	3.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	261.2	11,112.4
		A-2	(3F)	73,558.9	530.5	1.0	307.7	11.0	449.7	105.2	449.9	109.8	412.7	61.9	396.2	118.4	2,954.0	76,512.9	
		A-3	(3G)	80,433.3	571.0	358.5	60.9	209.0	35.9	375.3	77.0	358.7	31.6	416.7	11.4	319.7	2,825.7	83,259.0	
	スカム移送ポンプ	A-1	(4E)	1,772.0	0.9	0.0	0.1	0.1	0.0	0.5	0.3	1.6	0.0	2.4	1.3	1.6	8.8	1,780.8	
		A-2	(4F)	1,613.3	0.0	0.8	1.6	0.0	0.0	0.0	3.1	0.1	1.6	0.0	0.0	0.0	7.2	1,620.5	
	沈殿池管廊床排水P	A-1	(3B)	529.2	0.0	0.6	0.1	4.4	2.1	47.7	12.6	0.1	0.0	34.6	0.0	0.4	102.6	631.8	
		A-2	(9F)	76.4	0.1	0.3	0.0	0.0	0.1	0.1	0.1	0.0	0.0	1.1	0.1	0.0	1.9	78.3	
	送風機管廊床排水ポンプ	No-1	(3C)	123.6	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	123.7
		No-2	(3D)	685.3	0.5	0.9	0.5	1.5	0.4	1.2	0.8	0.0	0.0	6.4	0.6	0.6	13.4	698.7	
No-3		(9G)	163.2	0.3	0.3	0.2	0.8	0.1	0.3	0.2	0.0	0.0	0.5	0.0	0.0	2.7	165.9		
第1送風機棟 B系 最初沈殿池設備 (C-C-D2)	汚泥掻寄機	B-1	(F2C)	111,994.3	0.5	0.8	1.3	1.2	0.0	4.4	0.0	0.0	0.9	0.0	0.0	1.5	10.6	112,004.9	
		B-2	(F2D)	115,208.3	719.8	743.0	719.1	744.0	743.6	719.8	737.8	719.8	743.6	741.4	671.4	743.1	8,746.4	123,954.7	
		B-3	(F2E)	117,654.7	1.2	1.2	2.9	2.2	0.0	2.9	1.1	407.3	93.3	223.5	0.0	63.6	799.2	118,453.9	
		B-4	(F2F)	75,796.1	1.2	1.9	1.3	2.2	0.0	4.2	1.1	0.0	0.9	1.7	2.7	1.5	18.7	75,814.8	
		B-5	(F4E)	96,483.9	719.8	742.9	719.2	744.0	743.7	719.8	737.8	719.7	743.7	744.0	671.4	742.9	8,748.9	105,232.8	
		B-6	(F4F)	107,784.1	0.0	0.0	1.4	1.2	0.0	2.8	0.0	0.1	92.3	223.6	0.1	63.5	385.0	108,169.1	
	汚泥引抜ポンプ	B-1	(F2A)	90,246.9	527.4	393.3	143.9	468.9	40.2	382.1	76.8	387.4	35.4	423.1	11.8	434.1	3,324.4	93,571.3	
		B-2	(F2B)	90,023.1	440.5	0.4	297.5	23.8	476.7	111.4	452.7	112.2	419.3	55.2	417.9	19.5	2,827.1	92,850.2	
	スカム移送ポンプ	B-1	(R2A)	1,001.5	0.0	0.5	0.0	0.0	0.0	0.8	1.9	1.5	0.5	0.5	0.6	0.8	7.1	1,008.6	
		B-2	(R2B)	1,151.5	0.0	0.0	0.8	0.0	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.0	1.1	1,152.6	
	管廊床排水ポンプ	B-1	(R2E)	136.4	1.2	1.5	19.6	3.3	0.1	0.9	0.2	0.1	0.1	0.2	0.1	0.2	27.5	163.9	
		B-2	(R2F)	75.1	0.1	0.0	0.1	0.1	0.0	0.1	0.0	0.0	0.0	0.2	0.1	0.0	0.7	75.8	

No. 4 (単位:時間)

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計	
第1送風機棟 A系 エアタン設備 (C-C-C2)	A-4エアレータ	A-4-1	(F2A)	148,150.9	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,150.9	
		A-4-2	(F2B)	148,482.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,482.9
		A-4-3	(F2C)	148,623.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,623.8
		A-4-4	(F2D)	147,807.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,807.7
		A-4-5	(F2E)	147,606.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,606.3
		A-4-6	(F2F)	148,092.1	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,092.1
		A-4-7	(F2G)	147,723.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,723.9
		A-4-8	(F2H)	147,175.2	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,175.2
	A-5エアレータ	A-5-1	(F3A)	155,223.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,223.6
		A-5-2	(F3B)	156,674.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,674.5
		A-5-3	(F3C)	156,748.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,748.3
		A-5-4	(F3D)	155,027.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,027.5
		A-5-5	(F3E)	156,772.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,772.9
		A-5-6	(F3F)	156,466.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,466.5
		A-5-7	(F3G)	156,599.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,599.3
		A-5-8	(F3H)	155,889.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,889.5
	A-6エアレータ	A-6-1	(R2A)	155,711.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,711.6
		A-6-2	(R2B)	156,258.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,258.8
		A-6-3	(R2C)	156,152.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,152.6
		A-6-4	(R2D)	154,393.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	154,393.9
		A-6-5	(R2E)	156,679.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,679.6
		A-6-6	(R2F)	155,738.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,738.7
		A-6-7	(R2G)	156,060.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,060.9
		A-6-8	(R2H)	155,251.4	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,251.4
第1送風機棟 B系 エアタン設備 (C-C-C3)	B-1エアレータ	B-1-1	(F2A)	193,924.5	720.0	743.6	720.0	743.4	744.0	719.0	744.0	719.6	744.0	744.0	671.0	743.4	8,756.0	202,680.5	
		B-1-2	(F2B)	194,163.7	720.0	743.6	720.0	743.6	744.0	719.0	743.5	719.6	744.0	744.0	671.0	743.4	8,755.7	202,919.4	
		B-1-3	(F2C)	193,835.5	720.0	743.6	720.0	743.6	744.0	719.0	744.0	719.6	744.0	744.0	671.0	743.3	8,756.1	202,591.6	
		B-1-4	(F2D)	191,349.0	720.0	743.6	720.0	641.9	744.0	719.1	744.0	719.6	744.0	744.0	671.0	743.4	8,654.6	200,003.6	

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計	
第1送風機棟 B系 エアタン設備 (C-C-C3)	B-1エアレータ	B-1-5 (F2E)		177,853.6	720.0	743.6	720.0	743.6	740.4	719.1	738.3	719.6	744.0	744.0	671.0	743.4	8,747.0	186,600.6	
		B-1-6 (F2F)		175,971.4	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	258.0	744.0	671.0	54.0	1,727.1	177,698.5
		B-1-7 (F2G)		194,310.1	720.0	743.6	720.0	641.5	744.0	719.1	744.0	719.6	744.0	744.0	744.0	671.0	743.4	8,654.2	202,964.3
		B-1-8 (F2H)		188,331.8	720.0	743.6	720.0	743.6	744.0	719.1	744.0	719.6	744.0	744.0	744.0	670.9	743.4	8,756.2	197,088.0
	B-2エアレータ	B-2-1 (F3A)		192,807.7	720.0	743.6	720.0	743.6	744.0	719.0	744.0	719.6	744.0	744.0	744.0	671.0	743.4	8,756.2	201,563.9
		B-2-2 (F3B)		187,751.3	720.0	743.6	720.0	596.0	744.0	719.1	743.4	719.6	744.0	744.0	671.0	743.4	8,608.1	196,359.4	
		B-2-3 (F3C)		193,035.2	720.0	743.6	720.0	743.6	744.0	719.1	744.0	719.6	744.0	744.0	670.7	743.5	8,756.1	201,791.3	
		B-2-4 (F3D)		191,083.1	720.0	743.6	720.0	743.6	744.0	719.1	744.0	719.6	744.0	744.0	670.8	743.5	8,756.2	199,839.3	
		B-2-5 (F3E)		179,163.6	720.0	743.6	720.0	743.6	740.4	719.0	738.4	719.6	744.0	744.0	670.9	743.4	8,746.9	187,910.5	
		B-2-6 (F3F)		179,574.1	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	258.0	744.0	671.0	54.0	1,727.1	181,301.2
		B-2-7 (F3G)		192,974.6	720.0	743.6	720.0	743.6	744.0	719.1	744.0	719.6	744.0	744.0	670.9	743.5	8,756.3	201,730.9	
		B-2-8 (F3H)		191,737.6	720.0	743.6	720.0	743.6	744.0	719.1	744.0	719.6	744.0	744.0	670.9	743.5	8,756.3	200,493.9	
	B-3エアレータ	B-3-1 (R2A)		203,568.7	720.0	743.6	720.0	743.5	744.0	719.0	744.0	719.6	744.0	743.6	671.0	743.3	8,755.6	212,324.3	
		B-3-2 (R2B)		202,904.4	720.0	743.6	720.0	743.5	744.0	719.0	743.4	719.7	744.0	743.7	670.9	743.4	8,755.2	211,659.6	
		B-3-3 (R2C)		194,333.8	720.0	743.6	720.0	743.5	744.0	714.7	739.6	711.2	744.0	743.7	670.9	743.3	8,738.5	203,072.3	
		B-3-4 (R2D)		197,699.0	720.0	743.6	720.0	743.5	744.0	719.0	744.0	719.6	744.0	743.7	670.9	743.3	8,755.6	206,454.6	
		B-3-5 (R2E)		187,790.5	720.0	743.6	720.0	743.5	740.4	719.0	738.4	719.6	744.0	743.6	670.9	743.3	8,746.3	196,536.8	
		B-3-6 (R2F)		187,842.4	0.0	0.0	0.1	0.0	0.0	0.0	0.0	2.7	0.0	0.0	0.0	0.0	2.8	187,845.2	
		B-3-7 (R2G)		200,423.3	720.0	743.6	720.0	743.5	744.0	719.0	744.0	719.6	744.0	743.7	670.7	743.5	8,755.6	209,178.9	
		B-3-8 (R2H)		202,042.1	720.0	743.6	720.0	743.5	744.0	719.0	744.0	719.6	744.0	743.7	670.8	743.4	8,755.6	210,797.7	
	B-4エアレータ	B-4-1 (F4A)		181,386.2	720.0	743.6	720.0	743.6	744.0	719.1	744.0	719.9	675.3	744.0	671.0	743.4	8,687.9	190,074.1	
		B-4-2 (F4B)		179,741.5	720.0	743.6	720.0	743.6	744.0	719.1	743.4	719.6	675.3	744.0	672.0	743.4	8,688.0	188,429.5	
		B-4-3 (F4C)		181,525.6	720.0	743.6	720.0	743.6	744.0	719.1	744.0	719.6	675.3	744.0	670.9	743.4	8,687.5	190,213.1	
		B-4-4 (F4D)		180,674.5	720.0	743.6	720.0	741.6	744.0	719.0	735.2	720.0	614.0	734.9	647.6	731.7	8,571.6	189,246.1	
		B-4-5 (F4E)		170,962.5	720.0	743.6	720.0	743.6	740.4	719.0	738.3	715.9	675.3	744.0	670.0	0.0	7,930.1	178,892.6	
		B-4-6 (F4F)		180,885.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.0	0.5	180,885.6
		B-4-7 (F4G)		175,311.5	720.0	743.6	720.0	743.6	744.0	719.1	734.9	719.5	675.1	744.0	670.2	0.0	7,934.0	183,245.5	
		B-4-8 (F4H)		180,831.6	720.0	743.6	720.0	743.6	744.0	719.1	744.0	719.6	675.3	744.0	671.0	743.3	8,687.5	189,519.1	

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計	
第1送風機棟 B系 エアタン設備 (C-C-C3)	B-5エアレータ	B-5-1	(F5A)	178,833.8	720.0	743.6	720.0	743.6	744.0	719.1	744.0	719.9	717.4	743.7	671.0	743.4	8,729.7	187,563.5	
		B-5-2	(F5B)	178,628.5	720.0	743.6	720.0	743.6	744.0	719.1	743.3	719.3	717.3	743.7	671.0	742.6	8,727.5	187,356.0	
		B-5-3	(F5C)	177,906.8	720.0	743.6	720.0	743.6	744.0	719.1	744.0	719.5	717.4	743.4	671.0	743.4	8,729.0	186,635.8	
		B-5-4	(F5D)	178,805.2	720.0	743.6	720.0	743.6	744.0	719.1	744.0	717.8	717.3	743.7	666.8	742.6	8,722.5	187,527.7	
		B-5-5	(F5E)	169,047.9	720.0	743.6	720.0	743.6	740.4	719.0	738.3	719.6	717.4	743.6	671.0	743.4	8,719.9	177,767.8	
		B-5-6	(F5F)	175,015.8	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.3	175,016.1
		B-5-7	(F5G)	178,285.9	720.0	743.6	720.0	743.6	744.0	719.1	744.0	719.5	717.4	743.6	671.0	743.4	8,729.2	187,015.1	
		B-5-8	(F5H)	176,765.7	720.0	743.6	720.0	743.6	744.0	719.1	744.0	719.5	717.4	743.6	671.0	743.4	8,729.2	185,494.9	
	B-6エアレータ	B-6-1	(R4A)	181,153.9	720.0	743.6	720.0	743.5	744.0	719.1	744.0	719.6	527.0	10.1	374.5	743.2	7,508.6	188,662.5	
		B-6-2	(R4B)	174,971.6	720.0	743.6	720.0	743.5	744.0	719.1	743.4	719.6	527.1	10.0	374.5	743.3	7,508.1	182,479.7	
		B-6-3	(R4C)	181,599.5	720.0	743.6	720.0	743.5	744.0	719.1	744.0	719.6	527.1	10.1	374.4	743.3	7,508.7	189,108.2	
		B-6-4	(R4D)	181,221.5	720.0	743.6	720.0	743.5	744.0	719.1	744.0	719.6	527.0	10.1	374.5	743.2	7,508.6	188,730.1	
		B-6-5	(R4E)	170,650.8	720.0	743.6	720.0	743.5	740.4	719.1	738.3	719.6	526.8	10.1	373.8	743.2	7,498.4	178,149.2	
		B-6-6	(R4F)	181,581.8	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	41.0	10.1	23.7	0.0	74.9	181,656.7
		B-6-7	(R4G)	180,270.2	720.0	743.6	720.0	743.5	744.0	719.1	744.0	719.6	527.1	10.0	374.5	743.3	7,508.7	187,778.9	
B-6-8		(R4H)	180,682.2	720.0	743.6	720.0	743.5	744.0	719.1	744.0	719.6	527.1	10.0	374.5	743.3	7,508.7	188,190.9		
エアタン管廊床 排水ポンプ	B-1	(R3A)	245.3	0.4	0.2	0.6	0.5	0.6	0.5	1.3	0.2	0.1	0.1	0.1	0.3	4.9	250.2		
	B-2	(R3B)	162.1	0.4	0.2	0.6	0.5	0.6	0.5	1.2	0.1	0.0	0.1	0.0	0.2	4.4	166.5		
第1送風機棟 A系 最終沈殿池設備 (C-C-E1)	汚泥掻寄機	A-1-1	(2A)	251,113.9	720.0	742.5	719.0	742.2	742.7	716.4	742.1	717.4	742.7	741.0	669.6	741.5	8,737.1	259,851.0	
		A-1-2	(2B)	253,719.1	719.8	742.4	719.1	742.2	742.7	716.3	742.1	716.5	733.5	603.7	570.2	703.5	8,452.0	262,171.1	
		A-2	(2C)	249,949.0	720.0	742.7	720.0	743.2	743.6	717.8	743.2	717.1	742.6	741.2	669.5	741.3	8,742.2	258,691.2	
		A-3	(6B)	239,846.5	720.0	742.5	720.0	743.0	742.8	717.5	742.0	720.0	742.6	740.5	669.6	741.7	8,742.2	248,588.7	
		A-4	(7B)	178,085.7	720.0	742.9	719.0	742.8	742.6	715.2	742.1	314.6	310.3	741.5	669.5	741.6	7,902.1	185,987.8	
		A-5	(7C)	184,067.2	720.0	743.3	720.0	743.3	743.7	717.8	743.2	717.0	742.2	740.7	669.6	741.5	8,742.3	192,809.5	
		A-6	(7D)	185,460.9	720.0	743.2	720.0	742.9	742.8	717.9	742.6	712.7	742.2	739.9	669.6	741.8	8,735.6	194,196.5	

No. 7 (単位:時間)

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計	
第1送風機棟 A系 最終沈殿池設備 (C-C-E1)	返送汚泥ポンプ	A-1	(3A)	140,494.8	619.9	231.9	364.3	324.2	428.8	524.9	720.8	209.4	539.2	578.9	65.4	425.9	5,033.6	145,528.4	
		A-2	(3B)	169,050.8	247.8	633.8	193.3	0.3	8.0	7.5	377.6	665.0	142.5	404.2	659.7	163.8	3,503.5	172,554.3	
		A-3	(3C)	172,793.4	361.9	364.3	644.7	743.6	744.0	719.0	175.0	407.1	719.1	219.0	406.6	696.9	6,201.2	178,994.6	
		A-4	(9E)	175,798.1	720.0	742.3	720.0	743.7	744.0	719.0	744.0	719.5	744.0	743.2	670.8	744.0	8,754.5	184,552.6	
		A-5	(9F)	168,886.7	720.0	688.8	720.0	743.8	744.0	719.0	744.0	719.6	744.0	743.2	670.7	743.5	8,700.6	177,587.3	
	スカム分離機	A-1	(2D)	54,005.9	61.0	62.8	116.0	185.1	212.1	210.8	166.6	181.5	183.0	210.9	195.5	203.5	1,988.8	55,994.7	
	スカム移送ポンプ	A-1	(2E)	25,214.5	25.5	44.2	13.7	157.7	205.1	204.2	29.0	123.4	22.6	173.5	9.9	161.2	1,170.0	26,384.5	
		A-2	(2F)	25,414.8	30.3	14.1	95.6	20.5	0.0	0.0	130.6	50.3	154.2	30.1	178.0	35.6	739.3	26,154.1	
	余剰汚泥ポンプ	A-1	(4B)	41,566.1	58.7	0.0	0.0	0.0	0.0	0.0	0.0	125.6	25.7	90.5	6.9	89.8	397.2	41,963.3	
		A-2	(4C)	44,339.6	97.2	128.4	85.7	99.1	93.2	115.9	132.2	35.4	112.2	52.7	88.4	18.2	1,058.6	45,398.2	
		A-3	(9C)	16,668.6	19.0	0.0	0.0	0.0	0.0	86.3	134.2	95.9	11.3	55.5	4.6	80.8	487.6	17,156.2	
		A-4	(9D)	15,581.1	31.7	62.2	67.0	59.5	105.9	26.6	0.1	2.9	53.5	30.2	84.7	18.1	542.4	16,123.5	
	消泡水ポンプ	A-1	(5C)	104,871.0	239.1	248.1	346.3	354.0	355.6	346.4	250.9	359.4	325.0	348.4	24.7	291.3	3,489.2	108,360.2	
		A-2	(5D)	118,327.1	398.3	107.6	0.0	8.5	0.1	0.1	73.9	0.0	0.0	0.0	309.1	73.2	970.8	119,297.9	
	管廊床排水ポンプ	管理棟	(4E)	959.5	0.3	0.1	0.9	0.3	0.3	0.2	2.6	0.0	0.1	0.1	6.3	0.5	11.7	971.2	
		終沈A-1	(4F)	801.8	1.9	1.3	1.8	0.9	2.6	0.4	0.5	0.4	1.3	1.1	0.6	0.4	13.2	815.0	
		終沈A-2	(9B)	294.7	2.0	1.5	2.2	1.1	1.9	2.1	3.0	2.0	0.5	0.2	0.4	0.4	17.3	312.0	
		濃縮A-1	(4G)	143.9	0.3	0.2	0.5	0.3	0.6	0.3	1.2	0.1	0.6	0.2	0.3	0.3	4.9	148.8	
		濃縮A-2	(4H)	314.2	0.1	0.2	0.1	0.2	0.2	0.2	0.6	0.0	0.3	0.3	0.4	0.1	2.7	316.9	
	放流水消毒設備	A系次亜塩注入ポンプ	No.-1		40,053.7	-	-	-	-	-	-	-	-	-	-	-	-	0.0	40,053.7
No.-2				63,307.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	63,307.6
No.-3				66,540.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	66,540.3
B系次亜塩注入ポンプ		No.-4		51,686.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	51,686.8
		No.-5		39,011.2	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	39,011.2
		No.-6		44,626.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	44,626.5

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計
第1送風機棟 B系 最終沈殿池設備 (C-C-E2)	汚泥掻寄機	B-1	(F2B)	201,489.5	720.0	743.0	719.2	742.7	743.1	716.9	742.1	717.8	742.3	741.8	669.1	741.5	8,739.5	210,229.0
		B-2	(F2C)	203,436.5	720.0	743.2	720.0	743.2	743.8	717.8	742.9	718.2	742.5	740.6	669.0	741.3	8,742.5	212,179.0
		B-3	(F2D)	203,164.0	720.0	743.3	720.0	742.9	743.0	717.9	742.7	718.7	742.6	740.5	668.9	741.7	8,742.2	211,906.2
		B-4	(F4B)	179,739.2	720.0	743.2	719.3	743.7	742.3	715.5	742.2	717.9	438.9	0.0	354.7	728.3	7,366.0	187,105.2
		B-5	(F4C)	180,057.0	720.0	743.0	720.0	743.1	744.0	717.5	743.1	718.0	728.8	739.4	667.6	740.9	8,725.4	188,782.4
		B-6	(F4D)	179,997.1	720.0	743.2	720.0	742.7	743.3	712.5	492.3	720.0	613.1	550.1	444.9	679.0	7,881.1	187,878.2
	返送汚泥ポンプ	B-1	(F2E)	198,798.7	720.0	743.8	720.0	743.5	744.0	719.0	744.0	719.6	744.0	743.3	629.3	740.2	8,710.7	207,509.4
		B-2	(F2F)	192,753.3	720.0	743.8	720.0	743.5	744.0	719.0	744.0	719.6	544.6	0.0	469.6	742.6	7,610.7	200,364.0
		B-3	(F4E)	177,822.9	720.0	743.7	720.0	743.5	744.0	718.7	744.0	719.4	736.8	743.3	527.4	743.3	8,604.1	186,427.0
		B-4	(F4F)	174,680.8	720.0	733.4	720.0	743.4	744.0	718.2	744.0	571.5	515.5	140.3	447.2	743.2	7,540.7	182,221.5
	余剰汚泥ポンプ	B-1	(F3B)	24,263.0	32.8	117.7	34.2	140.7	186.0	180.0	26.9	124.8	26.6	89.4	4.0	86.3	1,049.4	25,312.4
		B-2	(F3C)	28,058.9	128.4	48.0	127.1	24.6	0.0	0.0	159.5	41.1	128.0	16.5	82.9	17.3	773.4	28,832.3
	消泡水ポンプ	B-1	(F3E)	72,583.4	518.0	356.6	348.5	363.3	353.8	346.9	319.8	357.2	369.8	367.6	331.3	362.3	4,395.1	76,978.5
		B-2	(F3F)	67,018.6	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	67,018.7
	スカム移送ポンプ	B-1	(R2A)	37,153.6	149.4	205.3	44.2	292.5	308.2	346.1	53.4	214.8	41.6	231.8	13.3	297.4	2,198.0	39,351.6
		B-2	(R2B)	42,610.9	282.5	114.4	233.8	38.2	0.0	0.0	237.3	80.0	278.4	33.6	271.1	56.7	1,626.0	44,236.9
	スカム分離機	B-1	(R2E)	74,002.6	392.3	289.0	257.9	296.2	281.8	310.0	262.7	248.1	276.8	232.8	247.8	317.4	3,412.8	77,415.4
	管廊床排水ポンプ	B-1	(R2G)	245.3	0.4	0.2	0.6	0.5	0.6	0.5	1.3	0.2	0.1	0.1	0.1	0.3	4.9	250.2
		B-2	(R2H)	162.1	0.4	0.2	0.6	0.5	0.6	0.5	1.2	0.1	0.0	0.1	0.0	0.2	4.4	166.5
	井水棟設備	深井戸揚水ポンプ	No.-1		78,524.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
No.-2				52,093.4	29.3	132.4	220.6	103.2	286.5	203.1	33.5	46.9	28.1	21.8	20.1	29.6	1,155.1	53,248.5
No.-3				46,687.4	26.5	113.1	297.2	271.0	160.7	459.4	450.1	23.7	21.8	16.7	17.8	26.2	1,884.2	48,571.6
送水ポンプ		No.-1		101,909.6	720.0	219.2	0.0	0.0	600.4	718.8	743.6	720.0	24.6	0.0	0.0	3.6	3,750.2	105,659.8
		No.-2		105,838.4	0.0	523.7	720.0	290.9	0.1	0.0	0.0	0.0	719.6	744.0	76.3	1.1	3,075.7	108,914.1
		No.-3		98,506.9	0.0	0.0	0.0	450.9	144.0	0.0	0.0	0.0	0.0	0.0	595.7	743.9	1,934.5	100,441.4
次亜塩注入ポンプ		No.-1		36,342.5	13.0	13.9	14.2	4.4	10.8	12.8	14.0	12.1	12.5	13.2	2.0	0.0	122.9	36,465.4
		No.-2		20,346.1	13.4	3.3	0.0	7.7	14.0	13.7	13.6	13.6	0.9	0.0	13.1	18.5	111.8	20,457.9
		No.-3		20,248.2	0.0	9.9	12.7	13.3	3.3	0.0	0.0	0.0	12.8	14.8	8.8	15.2	90.8	20,339.0

No. 9 (単位:時間)

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計
井水棟設備	急速ろ過器逆洗ポンプ	No.1		853.1	0.9	0.2	0.0	0.1	0.2	0.0	0.0	0.0	0.7	0.5	0.0	0.0	2.6	855.7
		No.2		584.8	0.0	0.3	0.4	0.1	0.4	0.7	0.7	0.5	0.0	0.0	0.5	0.7	4.3	589.1
	急速ろ過器	No.1		47,536.6	13.1	14.0	14.2	12.2	13.1	13.0	14.0	12.2	12.6	13.3	15.2	18.6	165.5	47,702.1
		No.2		31,637.9	13.5	13.3	12.7	13.5	15.1	12.9	13.7	13.6	13.7	15.0	8.9	15.3	161.2	31,799.1
A・B系重力濃縮設備 (F-C-P1)	し渣破砕機	A-1	(5D)	38,156.7	119.4	469.8	645.9	294.1	482.3	395.0	369.4	361.3	287.9	260.0	492.0	697.6	4,874.7	43,031.4
		A-2	(5C)	34,942.0	512.3	196.1	0.0	346.7	162.0	234.2	302.5	268.9	381.6	357.6	107.9	0.0	2,869.8	37,811.8
	濃縮汚泥掻寄機	A-1	(2C)	220,754.7	717.2	455.9	0.6	0.0	211.6	714.1	740.8	717.8	740.5	741.1	454.1	0.0	5,493.7	226,248.4
		A-2	(3C)	193,165.9	717.5	457.4	0.5	0.0	211.4	713.0	739.0	717.7	739.5	740.8	452.4	0.0	5,489.2	198,655.1
	濃縮汚泥引抜ポンプ	A-1	(2E)	32,169.4	156.3	140.7	58.2	128.8	14.5	99.0	12.3	106.6	11.2	151.5	83.4	0.0	962.5	33,131.9
		A-2	(2F)	34,518.8	114.7	64.8	117.8	20.8	145.9	25.2	165.7	0.0	181.6	32.9	106.2	0.0	975.6	35,494.4
	床排水ポンプ	A系	(2G)	3,413.6	16.6	20.0	44.9	18.0	15.0	22.7	18.4	18.9	18.7	18.6	13.2	0.9	225.9	3,639.5
	汚泥分離機	B-1	(3B)	16,071.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16,071.6
	し渣脱水機	B-1	(3H)	672.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	672.2
	濃縮汚泥掻寄機	B-1	(4A)	141,642.6	717.0	739.6	717.0	740.2	685.2	1.5	0.1	0.0	0.0	0.0	0.1	0.0	3,600.7	145,243.3
		B-2	(4B)	112,941.4	0.0	307.0	714.4	739.9	684.1	1.5	0.0	0.0	0.0	0.0	0.0	0.0	2,446.9	115,388.3
濃縮汚泥引抜ポンプ	B-1	(4D)	3.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.6	
し渣破砕機	B-1	(5E)	63,792.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	63,792.9	
C系重力濃縮設備 (F2-C-P1)	濃縮汚泥引抜ポンプ	C-1	(F1C)	2,946.8	13.9	147.4	25.0	140.4	44.2	122.5	12.3	149.1	4.3	143.6	172.0	322.0	1,296.7	4,243.5
		C-2	(F1D)	2,900.6	121.2	5.1	135.7	16.0	111.7	27.6	144.3	5.5	156.3	24.6	31.0	0.2	779.2	3,679.8
	床排水ポンプ	No. 1	(R1E)	533.9	2.5	1.8	5.3	4.4	3.0	2.5	1.8	1.0	2.8	2.3	0.8	0.3	28.5	562.4
		No. 2	(R1F)	581.4	2.5	5.3	9.0	4.4	3.0	2.5	1.8	1.0	2.8	2.3	0.8	0.3	35.7	617.1
A系ベルト濃縮設備	A系汚泥スクリーン		(2A)	81,845.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	81,845.5
	余剰汚泥供給ポンプ	No. 1	CRT	26,024.8	657.8	743.4	350.7	679.5	744.0	110.3	703.7	719.9	9.6	656.4	666.6	14.0	6,055.9	32,080.7
		No. 2	CRT	26,124.5	719.7	16.0	369.0	743.9	743.9	717.6	738.8	13.6	734.1	743.0	14.1	725.6	6,279.3	32,403.8
		No. 3	CRT	740.0	62.1	724.2	719.5	64.0	0.0	609.6	37.6	700.4	739.0	85.5	643.4	734.6	5,119.9	5,859.9
	濃縮汚泥移送ポンプ	A-1 No. 1	CRT	4,416.9	94.8	105.9	49.0	98.6	110.7	16.8	94.6	97.8	1.3	78.6	92.5	2.0	842.6	5,259.5
A-1 No. 2		CRT	2,831.0	129.6	2.8	64.1	115.6	118.4	131.3	117.4	2.3	107.6	96.7	1.7	119.0	1,006.5	3,837.5	
A-2 No. 1		CRT	96.1	9.0	126.9	108.1	8.4	0.0	88.2	8.2	105.6	92.1	10.6	90.7	86.8	734.6	830.7	

No. 10 (単位:時間)

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計		
A系 ベルト濃縮設備	高分子凝集剤 定量供給機	No. 1	CRT	1,000.0	32.1	34.5	32.6	33.6	33.0	33.4	35.1	34.1	35.1	33.2	33.3	34.9	404.9	1,404.9		
		No. 2	CRT	999.6	31.7	34.7	32.6	33.7	32.7	33.5	34.9	34.6	35.0	33.0	33.4	34.9	404.7	1,404.3		
	高分子凝集剤 供給ポンプ	No. 1	CRT	26,804.1	657.6	743.4	350.8	679.6	744.0	110.1	703.7	719.9	9.6	656.4	666.6	14.0	6,055.7	32,859.8		
		No. 2	CRT	26,051.4	719.7	15.9	368.9	743.9	743.9	717.7	738.8	13.6	734.1	743.0	14.1	725.6	6,279.2	32,330.6		
		No. 3	CRT	740.0	62.4	724.6	719.5	63.9	0.0	609.8	37.6	700.4	739.3	85.5	643.4	734.5	5,120.9	5,860.9		
	濃縮用空気圧縮機	No. 1	CRT	4,880.4	57.0	59.6	75.8	65.5	64.0	58.6	57.6	118.7	124.3	130.1	58.7	60.5	930.4	5,810.8		
		No. 2	CRT	4,853.8	54.9	56.5	41.9	57.8	57.7	54.2	57.4	2.6	0.0	0.0	52.9	61.6	497.5	5,351.3		
	補機室床排水ポンプ	A-1	(5B)	980.0	3.1	2.4	2.2	1.3	2.1	2.3	2.8	2.1	4.7	2.1	2.6	3.7	31.4	1,011.4		
		A-2	(5C)	681.4	3.0	2.4	2.1	1.3	2.0	2.3	2.8	2.0	4.6	2.1	2.5	3.7	30.8	712.2		
	B系 加圧浮上 濃縮設備 (F-C-J1)	余剰汚泥供給ポンプ	B-1	(F5A)	100,444.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	100,444.8
B-2			(F6A)	54,634.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	54,634.9	
B-3			(F7A)	90,647.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	90,647.0	
加圧水循環ポンプ		B-1	(R2C)	97,971.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	97,971.3
		B-2	(R3C)	55,808.4	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	55,808.5	
		B-3	(R4C)	90,327.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	90,327.2	
濃縮用空気圧縮機		B-1	(F3G)	17,673.8	0.6	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.9	17,674.7	
		B-2	(F3H)	21,411.7	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	21,411.9	
沈殿汚泥掻寄機		B-1	(F4D)	141,826.8	0.2	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	141,827.1	
		B-2	(F4F)	117,423.6	0.1	0.0	0.0	0.1	0.0	0.0	0.0	0.4	0.0	0.0	0.0	0.0	0.0	0.6	117,424.2	
フロス移送ポンプ		B-1	(F3B)	9,268.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	9,268.2	
		B-2	(F3C)	9,668.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	9,668.0	
B系汚泥スクリーン			(F3E)	7,890.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7,890.8	
沈殿汚泥引抜ポンプ			(F3F)	46.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	46.2	
補機室床排水ポンプ	B-1	(F2E)	1,145.4	1.8	15.1	2.6	14.2	1.6	12.8	1.2	13.8	0.5	12.7	0.6	0.1	77.0	1,222.4			
	B-2	(F2F)	1,602.1	15.5	0.7	13.3	1.6	20.8	2.0	17.2	0.6	14.8	2.0	0.5	0.0	89.0	1,691.1			
消化タンク設備 (L-C-Q1)	消化タンク攪拌機	A-1	(F3C)	218,744.1	718.6	741.7	720.0	729.3	698.0	712.4	709.6	715.2	739.1	734.7	648.1	738.0	8,604.7	227,348.8		
		A-2	(F3D)	40,047.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	40,047.5		
		A-3	(F3E)	174,138.0	718.7	742.4	720.0	737.9	724.1	713.0	712.6	720.0	193.6	0.0	426.3	741.3	7,149.9	181,287.9		
		A-4	(F4G)	130,377.9	718.7	741.7	720.0	736.7	724.1	713.0	712.9	720.0	744.0	742.9	647.1	736.7	8,657.8	139,035.7		

No. 11 (単位:時間)

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計
消化タンク設備 (L-C-Q1)	消化管廊床排水ポンプ	No-1	(F2E)	172.5	0.1	0.0	6.1	1.3	0.1	0.0	9.0	0.0	1.5	0.0	1.2	0.0	19.3	191.8
		No-2	(F2F)	271.3	0.3	0.0	0.0	0.1	0.1	0.0	0.0	0.1	0.1	0.0	0.3	0.6	1.6	272.9
	雑用水加圧ポンプ	No-1	(F3B)	505.7	0.4	1.5	0.0	1.2	0.0	0.0	0.0	0.7	0.1	0.0	0.0	0.0	3.9	509.6
	循環汚泥ポンプ	A-1	(R3C)	158,307.5	644.9	739.0	720.0	731.8	706.0	99.3	655.8	712.2	707.6	98.9	620.1	734.4	7,170.0	165,477.5
		A-2	(R3D)	2,978.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,978.2
		A-3	(R2C)	133,630.9	720.0	739.3	720.0	737.4	718.1	711.4	52.2	689.0	195.1	0.0	0.0	712.3	5,994.8	139,625.7
		A-4	(R2D)	127,732.8	482.8	741.3	720.0	618.5	0.3	612.1	708.1	334.8	28.1	638.8	456.9	734.5	6,076.2	133,809.0
	A-5	(F3C)	99,647.8	312.4	0.0	0.0	115.2	719.8	711.3	711.0	383.1	730.8	741.1	647.2	27.3	5,099.2	104,747.0	
A系ボイラー設備 (L-C-R1)	重油移送ポンプ	No-1	(F3G)	13.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13.0
		No-2	(F3H)	12.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	12.5
	消化用空気圧縮機	No-1	(F2C)	4,157.0	5.0	37.1	13.3	36.3	9.2	28.4	1.7	43.6	2.9	132.6	5.1	52.2	367.4	4,524.4
		No-2	(F2D)	4,242.0	33.0	1.3	23.7	3.9	29.1	7.5	33.0	1.4	212.1	24.4	105.7	2.5	477.6	4,719.6
	床排水ポンプ		(F2E)	10,400.1	0.5	0.2	0.1	2.2	4.9	2.4	2.0	8.0	2.8	0.1	1.4	1.4	26.0	10,426.1
	管廊床排水ポンプ		(F2F)	133.3	0.2	0.1	0.0	0.2	0.1	0.0	0.3	0.0	0.2	0.0	4.9	0.0	6.0	139.3
	A-1 温水ボイラー制御盤	抽気時間		100.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	100.9
		オイル燃焼時間		1,166.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,166.9
		ガス燃焼時間		170,627.7	592.1	415.2	11.3	362.3	37.4	395.9	391.4	398.7	185.4	256.4	395.8	255.7	3,697.6	174,325.3
	A-2 温水ボイラー制御盤	抽気時間		12.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	12.7
		オイル燃焼時間		6.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.2
ガス燃焼時間			60,348.5	264.5	192.4	444.8	92.3	218.6	72.4	210.4	266.8	509.8	391.8	366.4	375.3	3,405.5	63,754.0	
余剰ガス 燃焼装置	電気室電源盤内	燃焼時間	46,379.6	0.3	0.4	0.3	0.3	0.3	0.4	0.3	0.3	0.4	0.3	0.3	0.4	4.0	46,383.6	
	ボイラー設備盤 R22A内取付	ガス燃焼用送風機		46,379.6	0.3	0.4	0.3	0.3	0.3	0.4	0.3	0.3	0.4	0.3	0.3	0.4	4.0	46,383.6
		ガス昇圧	No-1-1	23,380.8	0.2	0.2	0.2	0.2	0.4	0.2	0.2	0.2	0.2	0.1	0.2	0.2	2.5	23,383.3
		ブロウ	No-1-2	23,551.2	0.2	0.2	0.2	0.2	0.2	0.3	0.2	0.2	0.2	0.3	0.2	0.2	2.6	23,553.8
脱水機設備 (H-C-K1)	脱水用空気圧縮機	A-1	(2A)	49,559.7	544.4	282.8	553.3	585.5	583.7	559.1	572.9	467.6	450.7	376.7	333.7	367.8	5,678.2	55,237.9
		A-2	(2B)	47,926.0	488.0	343.3	464.0	585.5	21.7	0.2	0.1	0.0	88.1	376.7	343.8	367.8	3,079.2	51,005.2
		A-3	(10C)	45,429.7	56.6	590.4	89.7	0.0	569.1	559.4	572.9	469.1	361.2	0.1	10.1	0.1	3,278.7	48,708.4
		B-1	(F5E)	1,214.1	12.2	12.3	12.1	13.6	13.8	13.6	14.6	14.8	17.9	27.2	20.8	27.3	200.2	1,414.3
		B-2	(F5F)	1,365.5	12.2	12.3	12.1	13.6	13.8	13.6	14.6	14.8	17.9	27.2	20.8	27.3	200.2	1,565.7

No. 12 (単位:時間)

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計
脱水機設備 (H-C-K1)	補機室床排水ポンプ	A-1	(2E)	217.1	0.5	0.2	0.7	1.5	0.9	3.6	2.3	0.5	5.4	56.0	11.9	14.3	97.8	314.9
		A-2	(2F)	196.8	0.5	0.2	0.6	1.3	0.8	1.3	1.6	0.4	1.4	6.1	3.2	3.7	21.1	217.9
		A-3	(2G)	3,016.5	5.7	4.7	5.0	6.1	6.4	4.5	6.5	4.3	3.5	3.0	2.7	3.2	55.6	3,072.1
		B-1	(R5B)	57.6	0.1	0.4	0.0	1.5	2.0	0.3	0.0	0.3	0.1	0.5	0.0	0.3	5.5	63.1
		B-2	(R5C)	57.2	0.3	0.0	0.4	0.3	0.7	0.1	0.6	0.1	0.1	0.1	0.1	0.3	0.0	3.0
	ろ布洗浄ポンプ	A-1	(3C)	60,068.8	671.3	701.0	106.5	649.1	195.7	325.2	680.4	14.3	112.5	619.1	30.3	135.5	4,240.9	64,309.7
		A-2	(3D)	56,853.4	334.0	402.8	631.6	216.2	616.9	105.6	275.7	679.6	100.6	94.3	476.9	13.6	3,947.8	60,801.2
		A-3	(10F)	44,010.5	0.0	0.0	280.5	20.2	246.1	626.8	36.6	306.6	497.2	80.4	107.8	677.9	2,880.1	46,890.6
		B-1	(R4C)	5,813.6	0.0	0.0	0.0		0.0	0.0	0.0	0.1	0.1	486.5	19.7	416.4	922.8	6,736.4
		B-2	(R4D)	6,625.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	161.9	40.9	294.7	115.8	613.4
	ろ布駆動装置	A-1	(5B)	80,746.4	657.3	682.3	422.5	129.5	30.2	23.4	145.6	641.0	682.1	616.7	494.3	669.7	5,194.6	85,941.0
		A-2	(6B)	72,873.6	657.5	688.7	681.3	684.5	528.2	457.9	246.6	0.0	0.0	166.2	499.2	681.6	5,291.7	78,165.3
		A-3	(7C)	66,499.3	364.7	427.4	335.5	124.9	13.1	0.0	126.1	664.0	701.1	273.8	112.4	128.8	3,271.8	69,771.1
		A-4	(8C)	66,885.3	0.0	0.0	0.0	0.0	536.1	643.9	667.5	669.9	692.3	684.9	493.9	399.5	4,788.0	71,673.3
		A-5	(R2F)	50,928.6	655.5	682.9	681.8	673.4	669.5	587.1	594.3	390.8	0.0	143.7	8.1	96.0	5,183.1	56,111.7
		A-6	(F2D)	44,603.3	0.0	0.0	297.2	667.8	665.9	639.9	552.5	4.0	0.2	0.4	0.0	0.0	2,827.9	47,431.2
		B-1	(F4A)	12,329.0	0.0	0.0	0.0	0.1	0.0	0.0	0.2	0.1	134.1	527.4	314.3	532.2	1,508.4	13,837.4
	脱水汚泥供給ポンプ	A-1	(5E)	71,142.8	562.5	583.9	346.8	91.1	19.7	14.1	110.6	497.9	533.4	489.2	386.7	540.0	4,175.9	75,318.7
		A-2	(6E)	64,432.0	542.5	592.2	609.0	586.3	433.7	354.6	197.1	0.0	0.0	127.4	390.2	545.3	4,378.3	68,810.3
		A-3	(7D)	58,700.0	270.0	349.4	261.5	76.9	7.3	0.0	89.6	516.7	539.1	190.2	81.2	86.2	2,468.1	61,168.1
		A-4	(8D)	59,559.4	0.0	0.0	0.0	0.0	462.1	553.3	594.3	576.5	591.4	541.2	382.2	300.9	4,001.9	63,561.3
		A-5	(R3A)	44,959.7	534.5	587.5	600.8	579.0	576.9	481.6	502.0	241.5	0.0	93.4	4.5	64.7	4,266.4	49,226.1
		A-6	(R4A)	39,625.7	0.0	0.0	244.8	581.9	581.0	552.4	469.0	3.1	0.0	0.0	0.0	0.0	2,432.2	42,057.9
		B-1	(R7A)	10,697.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	98.5	424.6	243.3	424.3	1,190.7
	凝集剤注入ポンプ	A-1	(5F)	71,076.8	562.5	583.9	346.8	91.1	19.8	14.0	110.7	497.8	533.4	489.3	386.7	540.0	4,176.0	75,252.8
		A-2	(6F)	64,275.5	542.5	592.2	609.0	586.2	433.7	354.6	196.9	0.0	0.0	127.6	390.2	545.3	4,378.2	68,653.7
		A-3	(7E)	58,770.1	269.7	349.3	261.4	76.8	7.4	0.0	89.6	516.7	539.0	190.2	81.2	86.1	2,467.4	61,237.5
		A-4	(8E)	59,590.8	0.0	0.0	0.0	0.0	462.1	553.3	594.3	576.5	591.4	541.2	382.2	300.9	4,001.9	63,592.7

No. 13 (単位:時間)

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計	
脱水機設備 (H-C-K1)	凝集剤注入ポンプ	A-5 (F3A)		44,988.3	534.3	587.5	599.8	578.2	576.6	481.3	501.7	241.4	0.0	93.3	4.6	64.6	4,263.3	49,251.6	
		A-6 (F4A)		39,657.1	0.0	0.0	244.2	575.2	566.6	549.0	469.0	3.1	0.0	0.0	0.0	0.0	0.0	2,407.1	42,064.2
		B-1 (F7A)		10,715.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	98.5	424.5	243.4	424.2	1,190.6	11,905.9
	高架水槽揚水ポンプ	A-1 (4A)		3,625.1	5.8	0.1	0.0	41.9	13.4	0.0	52.7	2.0	0.0	51.1	4.1	0.0	0.0	171.1	3,796.2
		A-2 (5A)		3,580.3	0.0	15.1	7.3	0.1	32.0	7.6	0.0	43.0	1.7	0.0	47.7	2.1	0.0	156.6	3,736.9
		A-3 (6A)		3,779.0	0.8	0.0	32.3	3.9	0.0	43.2	4.0	0.0	51.3	6.9	0.0	54.8	0.0	197.2	3,976.2
	高圧ろ布洗ポンプ	B-1 (R5D)		8,446.3	14.6	79.8	13.0	64.6	4.4	49.8	3.2	108.0	9.0	65.4	0.0	47.9	0.0	459.7	8,906.0
		B-2 (R6E)		8,281.8	39.0	4.4	74.1	8.5	59.7	13.6	110.5	3.6	43.0	0.0	24.7	3.6	0.0	384.7	8,666.5
	ケーキ圧送ポンプ	B-1 (F2A)		3,204.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	27.2	198.8	122.2	197.1	545.3	3,750.1
	第2ポンプ棟 放流ポンプ設備 (E-C-O1)	放流ポンプ (高圧)	No.1 (K-H-01)		828.2	0.2	0.1	0.2	0.2	17.8	0.3	76.0	0.1	0.2	0.0	0.4	0.2	0.0	95.7
No.2 (K-H-02)				278.4	0.2	0.2	0.1	0.2	0.5	0.0	49.1	0.2	0.1	0.0	0.4	0.1	0.0	51.1	329.5
No.3 (K-H-03)				135.8	0.1	0.2	0.2	0.1	2.9	0.0	9.5	0.9	0.1	0.0	0.2	0.2	0.0	14.4	150.2
No.4 (K-H-04)				114.0	0.1	0.3	0.1	0.1	5.1	0.1	33.0	0.2	0.2	0.0	0.2	0.1	0.0	39.5	153.5
ポンプ室床排水ポンプ		No.1 (2E)		15.9	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	16.0
		No.2 (3E)		18.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	18.2
放流ポンプ 冷却水ポンプ		No.1 (2F)		366.1	0.0	0.0	0.7	0.6	23.3	1.2	8.3	0.1	0.0	0.0	1.0	0.0	0.0	35.2	401.3
		No.2 (3F)		441.1	0.6	1.0	0.0	0.0	0.1	0.0	103.5	0.9	0.6	0.0	0.4	0.7	0.0	107.8	548.9
		予備 (2G)		0.0	-	-	-	-	-	-	-	-	-	-	-	-	0	0.0	0.0
		予備 (3G)		0.0	-	-	-	-	-	-	-	-	-	-	-	-	0	0.0	0.0
放流水計測室 (E-C-H1)	放流ポンプ (既設)	No.1 (4A)		449.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	449.6	
		No.2 (4B)		552.2	0.1	0.0	0.0	0.1	6.4	0.0	3.1	0.1	0.2	0.0	0.0	0.0	0.0	10.0	562.2
		No.3 (4C)		240.2	0.2	0.0	0.0	0.0	7.4	0.0	3.4	0.2	0.1	0.0	0.0	0.0	0.0	11.3	251.5
A系 急速ろ過設備 (M-C-S1)	汚泥処理送水ポンプ	No.1 (R6A)		34,500.8	2.8	18.3	93.6	74.1	69.6	9.1	8.9	51.3	172.8	574.3	94.6	88.9	1,258.3	35,759.1	
		No.2 (R6B)		28,082.3	1.9	297.1	14.3	9.7	9.9	7.7	7.0	7.8	22.9	98.9	23.5	8.0	508.7	28,591.0	
		No.3 (R6C)		29,064.8	534.2	326.7	0.0	0.0	152.6	540.9	587.6	211.7	4.8	7.2	320.8	128.8	2,815.3	31,880.1	
		No.4 (R3A)		12,021.9	122.1	150.5	576.9	557.9	477.6	88.0	104.0	384.8	455.7	2.0	37.7	466.0	3,423.2	15,445.1	
	逆洗排水ポンプ	A-1 (R4D)		31,498.8	0.0	214.4	321.1	326.2	302.3	304.9	259.2	301.1	317.5	315.1	188.7	8.9	2,859.4	34,358.2	
		A-2 (R5D)		28,120.1	355.4	208.1	207.3	201.3	156.4	148.4	139.4	164.6	186.2	173.2	42.3	308.0	2,290.6	30,410.7	
		A-3 (R6D)		27,017.8	165.9	121.8	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	210.1	185.6	683.8	27,701.6	

No. 14 (単位:時間)

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計	
A系 急速ろ過設備 (M-C-S1)	ポンプ室床排水ポンプ	No-1 (R3B)		12.9	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	13.1	
		No-2 (R3C)		7.9	0.1	0.0	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.3	8.2
	急ろ管廊床排水ポンプ	A-1 (R3D)		7.4	0.1	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.3	7.7
		A-2 (R3E)		113.3	0.3	0.3	0.3	0.2	0.2	0.1	0.5	0.9	0.6	0.5	0.4	0.4	4.7	118.0	
		A-3 (R11B)		12.2	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	0.4	12.6	
		A-4 (R11C)		10.1	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.4	10.5
	バルブピット床排水ポンプ	A-1 (R3F)		776.7	1.5	1.9	1.4	1.0	0.9	0.6	3.5	7.4	4.1	6.3	3.1	3.1	34.8	811.5	
	連絡管廊床排水ポンプ	No-1 (R3G)		1,385.6	6.3	6.3	5.7	5.3	5.2	5.3	6.0	5.5	5.6	6.6	6.0	6.6	70.4	1,456.0	
		No-2 (R3H)		17.4	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.3	17.7
	空洗ブロワ	A-1 (F5B)		2,264.0	15.7	16.3	22.6	23.8	22.9	23.0	19.7	23.0	24.0	23.9	21.4	22.8	259.1	2,523.1	
		A-2 (F6B)		2,050.3	8.1	7.3	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	15.5	2,065.8	
	揚水ポンプ	No-3 (M-H-M4)		9,917.0	193.0	186.8	176.5	194.5	191.3	188.6	157.3	192.6	187.4	175.9	171.8	169.0	2,184.7	12,101.7	
		No-4 (M-H-M3)		38.2	0.0	0.0	0.1	0.0	0.1	0.1	0.0	0.1	0.2	0.1	0.1	0.1	0.9	39.1	
		No-5 (M-H-M2)		46,994.0	239.5	256.8	252.8	277.7	251.7	287.2	296.4	267.8	299.5	273.5	225.6	258.5	3,187.0	50,181.0	
No-6 (M-H-M1)			49,547.6	303.0	295.2	295.3	290.4	283.9	250.7	223.4	285.6	254.3	275.1	261.9	298.2	3,317.0	52,864.6		
C系 最初沈殿池設備 (C2-C-D1)	汚泥掻寄機	C-1 (F3C)		19,129.2	1.2	6.0	2.2	2.8	1.2	1.4	1.4	0.0	92.0	224.3	0.0	0.0	332.5	19,461.7	
		C-2 (F3D)		133,951.0	720.0	742.5	720.0	743.2	744.0	718.6	744.0	718.2	741.6	740.5	665.8	742.6	8,741.0	142,692.0	
		C-3 (F3E)		42,826.2	0.0	5.1	2.2	2.1	0.0	1.2	1.3	0.0	1.8	1.0	2.0	0.0	16.7	42,842.9	
		C-4 (F4C)		26,697.3	1.1	11.5	3.5	2.8	1.1	1.3	2.4	0.0	1.7	1.1	0.0	0.0	26.5	26,723.8	
		C-5 (F4D)		89,083.3	720.0	280.1	2.1	671.5	744.0	713.9	744.0	711.0	741.5	740.3	651.0	742.7	7,462.1	96,545.4	
		C-6 (F4E)		40,603.1	1.1	474.6	720.0	77.0	1.1	6.8	2.4	10.9	91.3	224.2	15.6	0.1	1,625.1	42,228.2	
	汚泥引抜ポンプ	C-1 (F2C)		45,427.6	155.0	347.4	110.2	392.7	451.0	444.5	51.2	359.1	64.0	407.4	23.5	307.2	3,113.2	48,540.8	
		C-2 (F2D)		48,865.1	274.5	122.1	351.8	49.7	0.0	0.0	401.3	82.2	401.3	75.8	344.8	53.2	2,156.7	51,021.8	
	スカム移送ポンプ	C-1 (R4A)		3,174.0	1.8	1.7	0.0	1.5	1.7	2.4	1.1	1.6	0.5	1.0	0.9	1.2	15.4	3,189.4	
		C-2 (R4B)		3,295.4	0.0	0.6	2.7	0.0	1.0	1.0	0.0	0.2	1.3	0.0	0.8	0.0	7.6	3,303.0	
C系 最終沈殿池設備 (C2-C-E1)	汚泥掻寄機	C-1 (F3C)		143,708.5	720.0	740.7	719.6	742.4	742.4	716.1	733.2	713.4	738.6	741.7	667.8	735.6	8,711.5	152,420.0	
		C-2 (F3D)		151,446.1	720.0	742.0	720.0	742.7	743.7	717.5	743.2	717.7	740.0	741.1	668.4	737.1	8,733.4	160,179.5	
		C-3 (F3E)		143,562.2	720.0	742.5	720.0	742.4	743.4	717.9	742.6	718.4	740.3	742.4	667.4	736.7	8,734.0	152,296.2	
		C-4 (F4C)		123,944.4	720.0	742.5	719.6	743.4	740.5	716.1	741.8	717.5	740.6	742.1	667.6	736.4	8,728.1	132,672.5	
		C-5 (F4D)		124,793.9	720.0	742.8	720.0	742.9	743.9	717.4	742.2	717.7	740.1	741.1	668.3	736.9	8,733.3	133,527.2	
		C-6 (F4E)		124,145.9	719.7	742.7	720.0	742.3	743.5	699.4	733.0	718.0	738.7	740.5	664.3	735.6	8,697.7	132,843.6	

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計
C系 最終沈殿池設備 (C2-C-E1)	返送汚泥ポンプ	C-1	(F5A)	95,104.7	403.5	224.6	34.1	63.9	68.1	35.6	640.7	191.3	51.8	623.1	48.1	29.6	2,414.4	97,519.1
		C-2	(F6A)	94,007.8	32.6	518.1	180.7	0.0	9.8	0.0	245.8	572.7	122.8	57.5	623.8	143.4	2,507.2	96,515.0
		C-3	(F7A)	91,112.7	335.7	32.5	555.3	743.3	744.0	718.6	133.4	17.5	621.4	120.8	8.9	608.2	4,639.6	95,752.3
		C-4	(R5A)	79,932.6	130.4	3.2	37.9	63.9	64.9	35.5	640.4	220.6	23.1	624.3	48.2	29.6	1,922.0	81,854.6
		C-5	(R6A)	66,924.4	298.5	699.3	9.4	0.0	9.1	0.1	245.0	543.5	122.6	54.3	623.8	143.5	2,749.1	69,673.5
		C-6	(R7A)	79,078.8	350.4	72.5	720.0	743.3	744.0	718.6	133.6	17.4	621.5	119.7	9.0	608.1	4,858.1	83,936.9
	余剰汚泥ポンプ	C-1	(F3A)	35,286.9	107.2	243.4	73.9	312.0	77.5	259.2	51.2	248.1	48.5	188.8	10.9	258.4	1,879.1	37,166.0
		C-2	(F3B)	37,013.3	192.6	86.7	264.1	50.2	275.3	82.5	296.5	80.0	247.6	35.3	222.3	54.9	1,888.0	38,901.3
	スカム移送ポンプ	C-1	(F2B)	31,085.8	231.2	387.0	111.5	437.8	509.7	514.5	70.8	377.2	72.1	445.4	24.4	434.3	3,615.9	34,701.7
		C-2	(F2C)	31,804.0	279.2	156.0	407.9	59.8	0.0	0.0	329.0	112.0	458.9	71.5	469.8	81.4	2,425.5	34,229.5
	スカム分離機	C-1	(F2F)	65,475.4	506.5	538.2	519.7	491.3	505.7	509.5	399.7	484.5	525.8	512.6	491.1	511.3	5,995.9	71,471.3
	消泡水ポンプ	C系	(R4C)	55,028.2	497.5	341.2	336.9	352.9	351.7	342.9	303.5	355.4	363.8	367.1	332.3	360.3	4,305.5	59,333.7
		C/D系	(R4D)	34,555.9	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	34,556.0
		D系	(R4E)	17,449.4	499.4	342.4	337.5	353.4	337.5	342.6	318.2	356.0	363.4	367.9	335.3	361.3	4,314.9	21,764.3
C系 エアタン設備 (C2-C-C1)	C-1エアレータ	C-1-1	(F3B)	137,821.9	720.0	743.6	720.0	743.2	744.0	718.7	744.0	719.0	742.1	744.0	671.9	743.3	8,753.8	146,575.7
		C-1-2	(F3C)	138,263.0	720.0	743.6	720.0	743.2	744.0	718.7	743.5	719.6	741.9	744.0	671.9	743.3	8,753.7	147,016.7
		C-1-3	(F3D)	123,035.8	720.0	743.6	720.0	743.2	744.0	718.7	744.0	719.6	741.8	744.0	671.9	743.3	8,754.1	131,789.9
		C-1-4	(F3E)	126,339.8	720.0	743.6	720.0	743.2	744.0	718.5	744.0	719.6	741.6	744.0	672.0	743.2	8,753.7	135,093.5
		C-1-5	(F3F)	124,843.4	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	124,843.5
		C-1-6	(F3G)	112,839.7	718.6	743.1	720.0	743.2	740.7	718.7	729.2	719.5	741.9	744.0	671.9	743.2	8,734.0	121,573.7
		C-1-7	(F3H)	126,592.7	718.8	743.0	720.0	743.2	744.0	718.7	740.8	720.0	709.6	711.4	648.8	742.6	8,660.9	135,253.6
	C-2エアレータ	C-2-1	(F4B)	144,148.0	720.0	743.6	719.8	743.2	744.0	720.0	742.8	719.5	744.0	736.1	671.9	743.3	8,748.2	152,896.2
		C-2-2	(F4C)	141,103.2	720.0	742.4	720.0	743.2	744.0	718.7	743.6	719.5	741.8	744.0	672.0	743.3	8,752.5	149,855.7
		C-2-3	(F4D)	140,905.6	720.0	741.3	720.0	743.2	744.0	718.7	744.0	719.5	741.8	744.0	671.9	743.3	8,751.7	149,657.3
		C-2-4	(F4E)	138,535.6	719.2	743.4	720.0	743.2	744.0	718.6	744.0	719.5	741.8	744.0	672.0	743.3	8,753.0	147,288.6
		C-2-5	(F4F)	138,731.5	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	138,731.6
		C-2-6	(F4G)	143,801.8	719.5	742.7	720.0	743.2	723.3	718.7	729.2	719.5	741.9	744.0	664.2	743.3	8,709.5	152,511.3
		C-2-7	(F4H)	143,925.4	719.5	743.0	720.0	743.4	744.0	718.7	743.4	719.6	741.8	743.9	672.0	743.2	8,752.5	152,677.9

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計	
C系 エアタン設備 (C2-C-C1)	C-3エアレータ	C-3-1	(R2B)	143,119.7	720.0	742.5	720.0	743.2	744.0	718.6	744.0	719.6	741.8	744.0	671.9	743.0	8,752.6	151,872.3	
		C-3-2	(R2C)	142,631.0	716.3	741.9	720.0	743.2	744.0	718.6	743.6	719.5	727.9	744.0	672.0	742.8	8,733.8	151,364.8	
		C-3-3	(R2D)	143,760.3	720.0	743.5	696.9	743.2	744.0	718.6	744.0	719.6	741.8	743.9	672.0	0.0	7,987.5	151,747.8	
		C-3-4	(R2E)	143,873.7	720.0	743.5	717.4	703.8	744.0	720.0	744.0	720.0	741.0	744.0	672.0	744.0	8,713.7	152,587.4	
		C-3-5	(R2F)	141,014.4	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	141,014.5
		C-3-6	(R2G)	140,550.2	720.0	743.5	717.2	743.2	740.7	718.7	729.2	719.6	741.8	744.0	672.0	743.2	8,733.1	149,283.3	
		C-3-7	(R2H)	143,175.3	720.0	743.5	720.0	739.5	744.0	718.6	744.0	719.5	741.9	744.0	671.9	743.2	8,750.1	151,925.4	
	C-4エアレータ	C-4-1	(R3B)	124,570.6	720.0	743.5	720.0	743.6	744.0	718.7	744.0	719.3	741.9	744.0	671.7	743.2	8,753.9	133,324.5	
		C-4-2	(R3C)	124,470.9	0.0	19.2	720.0	743.3	744.0	718.7	743.4	719.5	741.8	744.0	671.9	743.2	7,309.0	131,779.9	
		C-4-3	(R3D)	124,594.7	720.0	743.5	720.0	743.2	744.0	718.6	744.0	719.5	741.9	744.0	671.9	743.2	8,753.8	133,348.5	
		C-4-4	(R3E)	124,562.9	720.0	743.5	720.0	743.2	744.0	718.6	744.0	719.5	741.6	744.0	672.0	743.2	8,753.6	133,316.5	
		C-4-5	(R3F)	114,167.3	0.0	0.1	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	114,167.5	
		C-4-6	(R3G)	124,598.6	720.0	743.5	720.0	741.8	740.7	718.6	729.3	719.5	741.3	744.0	671.9	743.2	8,733.8	133,332.4	
		C-4-7	(R3H)	124,569.9	720.0	743.5	720.0	740.8	744.0	718.6	744.0	719.5	741.9	744.0	671.9	743.2	8,751.4	133,321.3	
	C-5エアレータ	C-5-1	(F8B)	124,992.0	720.0	743.5	720.0	743.2	744.0	718.8	722.4	719.5	741.9	743.0	671.9	743.3	8,731.5	133,723.5	
		C-5-2	(F8C)	124,486.7	720.0	742.9	720.0	743.2	744.0	718.5	650.7	0.0	0.0	186.6	671.5	743.0	6,640.4	131,127.1	
		C-5-3	(F8D)	124,875.4	720.0	743.4	720.0	742.6	744.0	718.2	743.8	717.6	741.6	740.8	670.5	742.8	8,745.3	133,620.7	
		C-5-4	(F8E)	124,917.3	712.8	665.0	720.0	743.1	731.1	698.8	703.0	704.6	722.1	731.8	663.2	735.8	8,531.3	133,448.6	
		C-5-5	(F8F)	118,974.4	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	118,974.5	
		C-5-6	(F8G)	124,929.7	720.0	743.4	720.0	743.2	740.7	718.7	729.8	719.0	741.7	744.0	672.0	743.2	8,735.7	133,665.4	
		C-5-7	(F8H)	125,001.3	720.0	743.4	720.0	743.2	744.0	718.7	744.0	719.5	741.0	744.0	672.0	743.1	8,752.9	133,754.2	
	C-6エアレータ	C-6-1	(R8B)	121,590.4	720.0	743.5	720.0	743.4	744.0	718.8	744.0	719.6	741.7	744.0	671.9	741.6	8,752.5	130,342.9	
		C-6-2	(R8C)	123,913.5	720.0	743.5	720.0	743.2	744.0	718.8	743.5	719.5	741.7	744.0	672.0	743.1	8,753.3	132,666.8	
		C-6-3	(R8D)	124,572.1	720.0	743.5	720.0	743.2	744.0	718.8	744.0	719.5	741.8	744.0	670.3	743.2	8,752.3	133,324.4	
		C-6-4	(R8E)	121,884.6	720.0	743.5	719.2	743.2	744.0	718.7	744.0	719.6	741.7	744.0	671.9	743.2	8,753.0	130,637.6	
		C-6-5	(R8F)	106,967.7	0.0	0.1	0.1	0.0	0.0	2.0	0.0	0.0	0.0	0.0	0.0	0.1	2.3	106,970.0	
		C-6-6	(R8G)	124,361.1	720.0	743.4	717.3	743.2	740.6	718.7	729.3	719.5	741.8	744.0	671.9	743.1	8,732.8	133,093.9	
		C-6-7	(R8H)	123,831.9	720.0	743.4	718.8	743.2	744.0	718.7	744.0	719.5	741.7	744.0	672.0	743.1	8,752.4	132,584.3	

No. 17 (単位:時間)

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計
C系 エアタン設備 (C2-C-C1)	送風機	No.7	(C2-H-C1)	70,834.2	720.0	742.2	719.8	742.9	743.5	720.0	733.5	715.5	730.0	744.0	664.9	731.8	8,708.1	79,542.3
	冷却水ポンプ	No.1	(F3G)	35,124.8	720.0	741.9	144.6	0.1	0.0	575.4	268.8	523.2	120.3	623.8	49.0	618.2	4,385.3	39,510.1
		No.2	(F3H)	36,568.2	0.0	0.0	576.4	742.8	744.0	143.2	466.4	187.5	616.3	120.3	617.2	120.3	4,334.4	40,902.6
第1ポンプ棟	シャワー水	No.1	(7A)	387.7	56.1	365.3	11.1	362.3	10.5	338.1	12.0	350.7	409.3	344.9	10.9	347.9	2,619.1	3006.8
		No.2	(7B)	1,022.6	187.0	10.3	351.1	10.3	327.8	10.8	352.6	10.4	0.0	19.8	325.1	11.0	1,616.2	2638.8
B系 消化タンク設備	消化タンク攪拌機	B-1		81,760.8	715.7	736.0	720.0	699.9	633.6	712.8	712.3	720.0	744.0	743.6	650.1	736.5	8,524.5	90,285.3
		B-2		5,064.2	194.7	741.3	48.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	984.2
	管廊床排水ポンプ			18.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.3	18.3
	エレベーター棟床排水ポンプ			36.5	0.1	0.0	0.0	0.2	0.0	0.0	0.1	0.0	0.2	0.0	0.1	0.0	0.7	37.2
	雑用水加圧ポンプ			86,607.8	720.0	741.6	720.0	742.2	691.6	712.8	712.3	720.0	744.0	744.0	667.0	736.4	8,651.9	95,259.7
	循環汚泥ポンプ	B-1		42,300.3	0.0	0.0	0.0	167.5	0.0	0.0	0.0	0.0	430.8	738.9	655.5	27.8	2,020.5	44,320.8
		B-2		2,553.9	719.9	742.1	720.0	733.7	721.9	711.3	710.7	719.6	698.2	742.2	28.8	712.0	7,960.4	10,514.3
		B-4		49,181.3	719.9	742.2	720.0	567.9	721.7	711.6	708.8	715.4	345.8	0.0	626.5	735.8	7,315.6	56,496.9
	消化用空気圧縮機	No.1		1,915.2	2.0	18.0	6.8	18.1	4.6	14.8	1.4	16.8	0.6	15.9	0.6	17.9	117.5	2,032.7
No.2			2,556.7	15.6	0.6	11.7	1.9	15.4	3.2	16.4	0.7	17.0	2.4	15.4	0.7	101.0	2,657.7	
B系 ボイラー設備	管廊床排水ポンプ			83.4	0.1	0.1	0.0	0.7	0.0	0.1	0.1	0.1	0.4	0.1	0.9	0.1	2.7	86.1
	B系 温水ボイラー制御盤	オイル燃焼時間		2.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.1
		ガス燃焼時間		56865.3	705.1	663.5	573.3	421.3	366.6	425.3	521.3	535.7	650.8	673.3	576.3	716.5	6829.0	63694.3
汚泥乾燥設備 (N-C-T)	空気圧縮機	No. 1	(F3A)	32069.2	390.4	420.2	415.4	481.0	296.0	1.6	0.4	1.5	2.0	320.4	27.9	459.3	2816.1	34885.3
		No. 2	(F3B)	37593.6	3.2	0.0	0.0	2.4	10.8	0.7	0.9	17.5	3.7	10.4	35.2	0.5	85.3	37678.9
	砂ろ過水ポンプ	No. 1	(R3B)	43317.4	0.0	694.4	384.1	608.8	142.5	545.2	54.2	692.0	23.5	643.9	401.6	28.5	4218.7	47536.1
		No. 2	(R3C)	41543.2	575.0	47.0	338.0	75.2	562.9	117.9	675.9	28.4	270.0	97.6	0.0	566.5	3354.4	44897.6
	砂ろ過水送水ポンプ	No. 1	(R3F)	31612.3	420.0	34.4	437.0	80.5	523.9	183.7	227.9	0.1	192.5	389.8	139.7	444.0	3073.5	34685.8
		No. 2	(R3G)	31139.2	52.1	483.0	66.4	377.2	0.0	259.7	300.8	472.3	313.3	112.6	119.7	82.9	2640.0	33779.2
	脱臭ファン		(R4G)	12481.4	80.6	32.5	24.9	81.0	34.0	92.1	30.7	34.9	77.9	28.2	270.2	31.3	818.3	13299.7
汚泥乾燥設備 (N-C-U1)	1系排ガスファン		(R1A)	83370.9	657.3	741.3	720.0	685.7	744.0	658.3	743.5	720.0	688.5	743.4	401.6	741.8	8245.4	91616.3
	1系スクラバ循環ポンプ	No. 1	(R2B)	42162.7	287.8	47.3	0.0	608.8	142.9	533.1	54.3	691.9	23.5	643.9	401.6	741.7	4176.8	46339.5
		No. 2	(R2C)	43058.3	369.5	693.9	720.0	75.2	601.2	123.1	689.2	29.9	671.3	99.5	0.0	0.0	4072.8	47131.1

No. 18 (単位:時間)

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計
汚泥乾燥設備 (N-C-U1)	1系熱風炉用ブロワ	No. 1	(R2E)	44846.4	75.7	695.5	383.3	667.3	142.7	594.7	54.3	692.0	23.5	644.7	51.9	714.8	4740.4	49586.8
		No. 2	(R2F)	50043.6	644.6	47.4	338.8	75.2	601.3	123.0	689.2	29.9	720.6	99.6	611.8	28.5	4009.9	54053.5
	1系冷却塔循環ポンプ	No. 1-1	(R1E)	47654.3	434.5	125.1	0.0	0.2	74.8	263.8	241.6	506.0	339.7	242.7	298.3	341.8	2868.5	50522.8
		No. 1-2	(R1F)	45182.7	0.0	126.0	121.2	327.2	350.7	139.7	224.1	0.0	220.7	355.2	326.8	0.1	2191.7	47374.4
		No. 2-1	(R1G)	45499.5	359.5	168.9	0.0	0.0	0.4	178.8	6.0	220.8	71.0	714.9	477.3	122.4	2320.0	47819.5
		No. 2-2	(R1H)	47189.8	0.0	336.5	604.1	458.4	331.3	150.2	293.3	0.1	354.0	0.0	148.9	285.2	2962.0	50151.8
	脱水汚泥移送ポンプ	No. 1	CRT	14098.0	117.4	145.0	136.2	142.4	165.9	151.3	178.0	172.7	156.8	148.4	36.6	139.6	1690.3	15788.3
		No. 2	CRT	15710.9	123.6	126.8	127.0	108.2	107.1	85.2	94.6	89.5	89.1	116.9	88.5	89.9	1246.4	16957.3
D系 最初沈殿池設備 (C2-C-D2)	汚泥掻寄機	D-1	(F2C)	5497.1	1.0	6.3	1.9	2.7	1.1	1.2	1.4	0.0	90.6	223.8	0.0	0.0	330.0	5827.1
		D-2	(F2D)	55738.4	720.0	743.1	719.6	743.3	744.0	718.5	744.0	718.4	741.6	742.3	665.8	742.7	8743.3	64481.7
		D-3	(F2E)	27993.5	0.1	5.1	2.0	0.0	0.0	1.1	1.5	0.0	1.3	1.0	0.0	0.0	12.1	28005.6
		D-4	(F3C)	9016.8	0.9	10.3	1.9	4.7	1.0	1.1	2.5	0.0	1.4	1.0	1.9	0.1	26.8	9043.6
		D-5	(F3D)	62792.4	720.0	743.1	719.5	743.4	744.0	718.5	744.0	718.5	739.6	742.2	665.9	742.6	8741.3	71533.7
		D-6	(F3E)	8122.6	0.8	10.8	2.8	0.7	1.0	1.1	2.6	0.0	90.6	223.7	2.0	1.3	337.4	8460.0
	汚泥引抜ポンプ	D-1	(R2H)	18492.0	152.0	336.4	86.0	0.0	0.0	295.6	113.7	313.3	57.7	368.0	21.0	278.4	2022.1	20514.1
		D-2	(R3H)	20463.2	245.6	67.8	308.4	408.1	406.0	97.0	293.3	74.3	361.6	68.0	335.5	53.6	2719.2	23182.4
D系 エアタン設備 (C2-C-C2)	D-1エアレータ	D-1-1	(F2A)	69686.5	720.0	743.7	720.0	744.0	721.6	720.0	744.0	720.0	727.0	725.3	657.3	743.2	8686.1	78372.6
		D-1-2	(F2B)	69713.7	720.0	743.7	720.0	742.4	744.0	718.6	742.9	720.0	741.8	744.0	671.9	743.1	8752.4	78466.1
		D-1-3	(F2C)	69282.3	720.0	743.7	720.0	742.4	744.0	718.6	743.9	719.3	741.8	744.0	671.4	743.2	8752.3	78034.6
	D-2エアレータ	D-2-1	(F2D)	69703.1	720.0	741.6	720.0	742.2	744.0	713.0	744.0	718.7	741.7	736.6	671.8	743.1	8736.7	78439.8
		D-2-2	(F2E)	69716.6	720.0	743.7	720.0	742.3	744.0	718.7	743.6	720.0	741.0	744.0	671.6	742.7	8751.6	78468.2
		D-2-3	(F2F)	69643.5	720.0	743.4	720.0	742.3	744.0	718.6	743.6	719.5	741.8	744.0	672.0	743.1	8752.3	78395.8
	D-3エアレータ	D-3-1	(F3A)	69682.6	720.0	743.4	720.0	743.3	721.6	720.0	738.2	719.5	741.7	744.0	672.0	743.2	8726.9	78409.5
		D-3-2	(F3B)	69711.8	720.0	743.5	720.0	743.3	743.4	718.6	743.7	719.5	741.7	744.0	672.0	743.1	8752.8	78464.6
		D-3-3	(F3C)	69680.6	720.0	743.7	720.0	743.4	743.6	718.6	743.9	719.4	741.8	744.0	672.0	743.2	8753.6	78434.2
	D-4エアレータ	D-4-1	(F3D)	61518.8	720.0	743.7	720.0	743.4	743.5	718.6	744.0	719.5	741.2	744.0	671.9	742.5	8752.3	70271.1
		D-4-2	(F3E)	69006.9	720.0	743.7	720.0	743.4	743.1	718.6	743.8	719.4	738.3	743.7	672.0	742.8	8748.8	77755.7
		D-4-3	(F3F)	69193.8	720.0	743.7	720.0	743.4	741.2	712.6	743.7	719.5	741.4	744.0	672.0	715.4	8716.9	77910.7

No. 19 (単位:時間)

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計
D系 エアタン設備 (C2-C-C2)	D-5エアレータ	D-5-1	(F4A)	69014.3	720.0	742.8	720.0	743.4	743.2	718.6	744.0	718.6	740.7	744.0	671.9	743.2	8750.4	77764.7
		D-5-2	(F4B)	68967.8	720.0	743.7	720.0	743.4	743.3	718.7	743.6	719.5	741.8	744.0	672.0	743.2	8753.2	77721.0
		D-5-3	(F4C)	69373.9	720.0	743.7	720.0	743.4	744.0	720.0	744.0	719.5	741.7	744.0	671.9	743.2	8755.4	78129.3
	D-6エアレータ	D-6-1	(F4D)	69204.5	720.0	742.0	720.0	743.0	744.0	718.6	744.0	719.4	741.8	744.0	671.9	743.2	8751.9	77956.4
		D-6-2	(F4E)	68701.7	720.0	742.8	720.0	743.4	743.6	718.7	743.7	719.5	741.7	744.0	671.9	743.2	8752.5	77454.2
		D-6-3	(F4F)	63602.6	720.0	743.7	720.0	743.4	743.3	718.6	743.7	719.5	741.4	744.0	670.3	743.1	8751.0	72353.6
D系 最終沈殿池設備 (C2-C-E2)	汚泥掻寄機	D-1	(R1A)	69880.3	720.0	742.7	720.0	22.2	0.0	0.0	0.0	720.0	740.6	741.0	668.6	735.5	5810.6	75690.9
		D-2	(R1B)	69994.8	720.0	742.7	720.0	742.9	744.0	717.4	743.0	717.6	740.0	741.1	668.3	735.9	8732.9	78727.7
		D-3	(R2A)	69959.1	719.9	742.9	720.0	742.1	743.5	717.7	742.6	718.1	738.7	741.9	666.5	734.8	8728.7	78687.8
		D-4	(R2B)	69349.4	720.0	742.7	719.7	742.4	742.8	716.0	741.6	717.2	740.6	741.4	661.4	729.3	8715.1	78064.5
		D-5	(R2C)	69343.8	720.0	743.0	720.0	741.6	743.7	717.4	742.8	717.6	739.8	740.9	668.2	735.5	8730.5	78074.3
		D-6	(R2D)	69350.3	720.0	742.9	720.0	742.6	741.9	717.7	742.7	718.3	740.4	741.9	667.5	735.3	8731.2	78081.5
	返送汚泥ポンプ	D-1	(F3A)	46373.2	403.7	221.3	32.4	53.4	50.5	35.5	637.4	191.4	5.7	624.5	54.6	27.6	2338.0	48711.2
		D-2	(F4A)	44514.1	18.5	521.1	176.4	0.1	0.3	0.0	208.9	550.9	119.9	26.6	609.3	144.0	2376.0	46890.1
		D-3	(F5A)	42618.3	335.5	29.8	554.0	743.4	742.3	718.5	120.5	0.0	0.0	0.0	0.0	0.0	3244.0	45862.3
		D-4	(R3A)	45381.9	403.7	221.5	32.4	53.3	50.8	35.4	637.2	191.4	102.1	744.0	48.4	599.5	3119.7	48501.6
		D-5	(R4A)	44009.4	18.8	520.6	176.4	0.1	0.1	0.0	208.3	553.4	119.8	26.9	623.5	166.4	2414.3	46423.7
		D-6	(R5A)	42379.9	335.4	30.1	555.2	743.3	744.0	718.6	120.7	4.5	525.5	0.1	6.7	13.2	3797.3	46177.2
	余剰汚泥ポンプ	D-1	(F2E)	14191.9	68.3	150.4	44.6	191.5	217.2	202.3	28.4	148.2	28.2	159.3	10.2	140.1	1388.7	15580.6
		D-2	(F2F)	15076.5	124.0	56.0	175.5	33.7	0.0	0.0	184.6	50.8	160.3	26.4	155.2	32.4	998.9	16075.4
	沈砂設備 (J-C-N1A) <設備更新>	床排水ポンプ	No. 1	(F3E)	3.6	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1
No. 2			(F3F)	6.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.0	0.3	6.9
No. 3			(F3G)	3.4	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.0	0.4	3.8
加圧水ポンプ		No. 1	(F2C)	553.2	5.3	64.1	2.9	63.8	6.0	56.1	0.9	65.8	1.1	50.4	34.7	72.0	423.1	976.3
		No. 2	(F2D)	620.8	59.1	3.1	63.7	5.8	64.6	11.3	68.8	1.7	68.6	18.4	28.9	0.7	394.7	1015.5
揚砂ポンプ		No. 1		1658.5	3.9	2.5	3.6	3.0	2.6	3.2	3.8	3.1	1.7	3.5	2.3	2.4	35.6	1694.1
		No. 2	(F3C)	162.3	2.2	2.6	2.8	2.4	2.2	3.4	2.5	2.5	1.9	2.1	2.4	2.1	29.1	191.4
	No. 3	(F3D)	142.3	2.1	2.2	2.1	1.5	1.5	1.7	3.0	1.6	0.9	2.1	1.4	1.4	21.5	163.8	

区分	機器名称	機器番号		29年度末	30年4月	5月	6月	7月	8月	9月	10月	11月	12月	31年1月	2月	3月	年計	累計	
A系エアタン設備	反応槽攪拌装置	4-1	(F2F)	28058.9	720.0	225.0	588.0	743.0	744.0	719.0	744.0	345.0	340.0	742.0	671.0	743.0	7324.0	35382.9	
		4-2	(F2G)	28057.9	720.0	225.0	588.0	743.0	744.0	719.0	744.0	345.0	340.0	742.0	671.0	743.0	7324.0	35381.9	
		4-3	(F2H)	28057.0	720.0	225.0	588.0	743.0	744.0	720.0	744.0	344.0	340.0	743.0	669.0	743.0	7323.0	35380.0	
		5-1	(F2C)	29233.0	84.0	744.0	720.0	743.0	744.0	719.0	744.0	719.0	744.0	742.0	671.0	743.0	8117.0	37350.0	
		5-2	(F2D)	29229.0	84.0	744.0	720.0	743.0	744.0	719.0	744.0	720.0	744.0	742.0	671.0	743.0	8118.0	37347.0	
		5-3	(F2E)	29233.7	84.0	744.0	720.0	743.0	744.0	720.0	744.0	720.0	742.0	742.0	671.0	743.0	8117.0	37350.7	
		6-1	(R2D)	29230.6	720.0	744.0	364.0	326.0	744.0	718.0	744.0	720.0	744.0	742.0	671.0	743.0	7980.0	37210.6	
		6-2	(R2E)	29214.7	720.0	744.0	364.0	326.0	744.0	719.0	743.0	720.0	744.0	742.0	671.0	743.0	7980.0	37194.7	
		6-3	(R2F)	29232.4	720.0	744.0	364.0	326.0	744.0	719.0	744.0	719.0	744.0	743.0	671.0	743.0	7981.0	37213.4	
	凝集剤注入ポンプ	A-1	(R1C)		7491.8	438.8	521.1	472.4	448.6	559.5	500.3	622.9	458.5	465.3	570.2	451.4	592.6	6101.6	13593.4
		A-2	(R1D)		10003.4	0.0	0.0	0.1	0.1	33.4	22.6	11.7	0.0	0.0	0.3	0.2	10.1	78.5	10081.9