

4 機 械 関 係

(1) 機械設備稼動状況

浄化センター（その1）

（単位：時間）

設備	機 器 名	No	29年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	30年度計	30年度まで累計
沈砂池設備	揚 砂 ポ ン プ	No.1-1	96.3	0.5	0.8	0.5	0.3	0.2	0.5	0.2	0.7	0.5	0.7	0.8	0.4	6.1	102.4
		No.1-2	97.8	0.4	0.6	0.2	0.3	0.3	0.4	0.2	0.4	0.3	0.3	0.7	0.2	4.3	102.1
	細 目 除 塵 機	No.1	1,060.7	2.8	2.8	2.3	2.3	2.5	2.7	2.5	3.0	2.9	2.9	2.6	3.1	32.4	1,093.1
		No.1	1,017.6	1.0	2.2	1.5	3.5	1.9	1.0	1.4	1.3	2.6	1.0	1.7	1.4	20.5	1,038.1
		No.2	1,034.6	1.1	2.2	1.5	2.5	1.9	1.0	1.4	1.3	2.6	1.0	2.6	1.4	20.5	1,055.1
	し 渣 搬 出 コ ン ベ ア	No.3	1,086.8	2.6	3.0	1.9	3.6	1.9	2.0	1.5	1.7	2.7	2.6	2.9	1.8	28.2	1,115.0
		No.1	129,655.8	715.1	743.4	719.6	735.6	743.4	714.4	742.5	720.0	739.1	741.0	348.0	0.0	7,662.1	137,317.9
		No.1	26.3	0.1	0.1	0.1	0.3	0.1	0.2	0.2	0.1	0.1	0.1	0.1	0.1	1.6	27.9
床 排 水 ポ ン プ	No.1	1,219.2	2.4	3.0	1.9	3.7	1.8	2.6	1.3	2.4	2.7	2.6	2.8	1.7	28.9	1,248.1	
し 渣 ・ 沈 砂 洗 浄 機	No.1	289.2	2.1	2.8	1.9	3.9	2.2	2.3	1.5	2.0	2.7	2.4	2.9	1.4	28.1	317.3	
最初沈殿池	生 汚 泥 引 抜 ポ ン プ	No.1	13,061.3	94.2	1.2	93.1	7.8	70.7	4.9	109.9	5.9	68.0	45.3	48.5	0.9	550.4	13,611.7
		No.2	13,030.1	4.0	104.0	1.2	60.9	0.9	96.2	2.6	115.9	16.9	47.7	8.2	86.2	544.7	13,574.8
	床 排 水 ポ ン プ	No.1	191.7	6.7	6.3	4.8	4.2	4.6	3.8	5.6	5.2	6.8	8.9	114.4	309.5	480.8	672.5
	1 系 初 沈 汚 泥 掻 寄 機	No.1-1	168,855.1	390.4	402.5	506.1	400.2	504.3	718.5	735.3	687.2	633.1	78.4	254.1	364.8	5,674.9	174,530.0
		No.1-2	127,275.2	393.0	402.6	506.1	403.1	504.2	718.5	735.2	687.1	633.1	78.4	254.1	364.8	5,680.2	132,955.4
	2 系 汚 泥 掻 寄 機	No.2	71,273.3	505.4	407.4	509.4	407.1	507.5	718.5	735.2	687.0	86.8	362.1	324.7	365.1	5,616.2	76,889.5
	3 系 汚 泥 掻 寄 機	No.3	87,907.3	508.7	411.6	512.7	411.5	511.3	719.4	743.5	687.9	633.7	363.8	328.9	365.7	6,198.7	94,106.0
	池 排 水 ポ ン プ	No.1	72.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	2.3	1.5	0.0	4.3	76.6
	初 沈 ス カ ム 排 水 ポ ン プ	No.1	4,422.5	38.3	0.6	50.2	3.5	61.5	4.6	55.3	0.9	31.0	5.9	46.2	1.3	299.3	4,721.8
		No.2	5,022.9	1.0	53.8	0.9	55.1	1.7	52.4	1.0	47.0	4.5	19.4	0.4	50.2	287.4	5,310.3
汚泥処理設備	濃 縮 汚 泥 掻 寄 機	No.1	122,269.4	693.3	741.8	717.4	729.2	741.4	716.5	739.8	718.1	740.7	736.1	671.6	741.6	8,687.5	130,956.9
		No.2	76,348.7	693.1	742.4	717.6	731.3	741.5	717.3	738.6	717.9	443.3	0.1	34.8	742.3	7,020.2	83,368.9
	脱 水 ろ 液 移 送 ポ ン プ	No.1	53,241.7	441.3	371.5	540.7	400.0	497.9	495.5	424.9	441.1	649.1	548.8	551.9	462.2	5,824.9	59,066.6
		No.2	120,430.4	387.7	474.0	449.5	423.2	478.7	487.1	376.3	551.9	617.6	547.2	551.6	433.2	5,778.0	126,208.4
	汚 泥 貯 留 槽 攪 拌 機	No.1	116,969.3	333.8	362.8	376.1	366.7	364.3	328.0	372.1	349.7	372.1	352.8	362.0	350.8	4,291.2	121,260.5
		No.1	3,712.0	4.7	0.4	33.6	3.2	8.2	4.2	21.3	4.4	0.0	6.1	3.9	2.3	92.3	3,804.3
	汚 泥 供 給 ポ ン プ	No.2	3,379.4	21.2	8.0	2.4	1.4	5.6	0.6	1.0	45.8	0.0	56.4	4.3	11.5	158.2	3,537.6
		No.3	13,802.0	168.1	177.6	184.8	200.5	201.3	187.6	182.1	145.0	175.2	65.9	201.0	0.5	1,889.6	15,691.6
		No.4	14,813.6	0.1	1.5	0.1	0.1	0.1	0.1	0.0	0.1	32.5	83.5	15.3	202.4	335.8	15,149.4
	濃 縮 汚 泥 移 送 ポ ン プ	No.1	8,477.6	41.2	15.6	33.8	19.5	52.8	3.2	43.8	2.5	36.7	36.9	49.8	17.4	353.2	8,830.8
		No.2	7,076.9	20.8	34.9	1.3	36.8	21.2	36.6	1.6	40.5	12.4	37.3	43.5	43.8	330.7	7,407.6
	給 水 ポ ン プ	No.1	960.1	9.6	0.0	10.2	0.0	10.7	0.4	10.2	0.1	9.4	0.8	8.9	0.1	60.4	1,020.5
		No.2	1,055.6	0.0	8.5	0.1	10.2	0.0	8.4	0.0	8.9	0.0	8.2	0.4	8.2	52.9	1,108.5
	脱 臭 フ ァ ン	No.1	211,073.7	719.4	743.3	719.1	743.6	743.4	719.1	741.5	719.2	742.3	743.4	671.5	743.7	8,749.5	219,823.2
	ろ 布 洗 浄 ポ ン プ	No.3	19,102.6	213.4	4.2	229.2	7.0	251.2	15.0	225.9	4.7	262.6	26.8	256.3	0.5	1,496.8	20,599.4
		No.4	19,442.7	6.5	229.2	3.1	249.9	2.4	227.9	6.7	186.8	2.7	171.9	9.7	257.6	1,354.4	20,797.1
	床 排 水 ポ ン プ	No.1	652.4	17.7	0.4	12.8	1.8	12.8	0.9	14.3	0.4	176.7	130.3	304.6	119.5	792.2	1,444.6
No.2		510.0	1.0	13.3	0.7	17.9	0.4	13.1	0.7	11.1	62.7	212.9	158.5	382.8	875.1	1,385.1	

浄化センター（その2）

（単位：時間）

設備	機器名	No	29年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	30年度計	30年度まで累計
汚泥処理設備	空気圧縮機	No.1	4,934.3	63.8	65.4	63.3	65.1	69.3	88.2	74.5	73.2	75.6	72.7	63.9	69.4	844.4	5,778.7
		No.2	7,156.2	63.6	65.1	63.0	64.2	69.0	52.7	74.4	72.7	74.6	71.0	62.8	68.9	802.0	7,958.2
	溶解槽攪拌機	No.1	1,138.1	1.6	0.6	2.3	2.5	2.2	0.0	2.1	8.9	0.0	4.0	0.5	0.3	25.0	1,163.1
		No.2	27,477.3	15.4	13.2	15.5	17.4	16.2	21.8	17.7	11.4	22.9	12.1	14.2	11.9	189.7	27,667.0
	薬品定量供給機	No.1	226.0	0.7	0.2	0.8	0.2	0.4	0.0	0.7	1.0	0.0	1.4	0.2	0.2	5.8	231.8
	薬品供給機	No.1	924.6	4.0	3.9	4.2	4.9	4.9	4.5	4.2	3.6	4.3	3.1	4.1	3.7	49.4	974.0
	薬品供給ポンプ	No.1	3,767.2	21.3	0.4	11.2	3.3	8.2	3.7	21.4	9.3	0.0	25.4	4.3	3.0	111.5	3,878.7
		No.2	3,360.6	4.7	8.0	25.0	1.4	5.6	1.1	1.1	41.2	0.0	37.5	3.9	10.8	140.3	3,500.9
		No.3	14,013.9	165.1	2.7	182.0	4.2	197.2	12.0	179.2	1.7	205.1	20.2	207.7	0.1	1,177.2	15,191.1
		No.4	14,656.3	3.0	176.4	3.0	196.2	4.3	175.8	3.1	143.4	2.6	129.3	8.6	202.8	1,048.5	15,704.8
脱水機	No.1	7,091.4	25.9	8.4	36.0	4.6	13.8	4.8	22.3	50.2	0.0	62.5	8.2	13.8	250.5	7,341.9	
	No.2	28,621.6	168.2	179.1	184.9	200.6	201.4	187.7	182.1	145.1	207.7	149.4	216.3	202.9	2,225.4	30,847.0	
送風	送風機	No.1-1	77,256.6	0.3	0.6	0.0	37.2	14.6	0.3	9.9	0.4	0.3	0.2	0.8	0.2	64.8	77,321.4
		No.1-2	72,025.8	0.4	0.6	0.0	26.4	0.2	0.3	9.9	0.4	0.0	0.0	0.7	0.2	39.1	72,064.9
		No.2-1	91,182.5	503.6	443.6	576.9	245.9	28.0	499.2	603.0	658.1	742.6	733.1	663.1	739.1	6,436.2	97,618.7
		No.2-2	35,182.4	210.8	299.8	141.6	463.5	715.7	218.2	128.6	58.6	0.4	7.5	1.2	0.9	2,246.8	37,429.2
エアタン	水中攪拌機	No.1-1	76,053.6	720.0	744.0	720.0	744.0	444.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,372.0	79,425.6
		No.1-2	0.0	0.0	0.0	0.0	0.0	300.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	5,388.0	5,388.0
		No.2-1	78,887.7	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,760.0	87,647.7
		No.2-2	72.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	72.0
	散気装置	No.3-1	96,347.3	715.3	744.8	718.2	736.8	742.6	715.5	744.1	716.1	744.7	740.7	665.8	740.5	8,725.1	105,072.4
		No.3-2	96,124.4	715.7	744.8	718.2	736.8	742.6	715.5	744.1	716.1	744.7	740.7	665.8	740.5	8,725.5	104,849.9
最終沈殿池	1系返送汚泥ポンプ	No.1	40,846.5	680.2	10.5	708.0	10.4	733.7	57.8	731.0	9.9	681.5	84.8	655.3	10.7	4,373.8	45,220.3
		No.2	41,694.4	34.5	732.8	10.5	733.0	10.2	659.6	10.7	707.7	62.4	657.2	10.2	730.2	4,359.0	46,053.4
	2系返送汚泥ポンプ	No.1	47,888.0	680.2	10.4	707.8	10.5	733.7	57.8	731.0	10.0	681.6	85.3	654.8	10.7	4,373.8	52,261.8
		No.2	48,352.3	34.4	733.5	10.4	730.2	10.3	659.6	10.7	707.9	62.4	656.6	10.6	730.2	4,356.8	52,709.1
	余剰汚泥ポンプ	No.1	17,258.0	62.7	81.6	68.5	63.8	59.3	69.4	53.2	64.1	65.0	56.4	65.4	64.9	774.3	18,032.3
		No.2	1,594.6	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.2	1,595.8
		No.3	4,642.9	19.9	23.5	37.0	33.9	36.6	37.2	35.4	34.6	46.8	36.7	35.3	41.6	418.5	5,061.4
	1系終沈汚泥掻寄機	No.1-1	196,484.9	713.7	738.3	714.0	738.2	738.3	714.5	739.3	715.6	494.0	739.5	667.6	739.2	8,452.2	204,937.1
		No.1-2	200,702.7	713.7	738.2	713.8	738.2	738.2	713.9	739.3	715.5	213.4	739.5	667.6	739.2	8,170.5	208,873.2
	2系終沈汚泥掻寄機	No.2	172,477.2	713.7	738.2	714.2	738.1	738.1	714.4	738.7	715.3	734.8	739.2	667.6	739.3	8,691.6	181,168.8
	3系終沈汚泥掻寄機	No.3	95,836.7	716.1	740.0	716.5	740.4	741.0	715.8	740.5	716.2	737.1	740.5	669.2	741.0	8,714.3	104,551.0
	A・T床排水ポンプ	No.1	2,849.3	0.9	0.6	0.8	1.1	1.0	0.8	1.3	2.0	0.8	1.2	1.2	1.2	12.9	2,862.2
	終沈床排水ポンプ	No.1	2,174.9	9.5	0.4	7.9	0.0	8.0	1.1	10.3	0.3	10.9	1.7	13.6	0.5	64.2	2,239.1
		No.2	1,902.7	0.6	15.9	2.8	15.3	3.1	13.2	0.7	8.1	0.9	10.6	0.4	15.3	86.9	1,989.6
終沈スカム排水ポンプ	No.1	12,104.2	48.1	0.9	49.9	0.7	95.6	6.4	75.7	0.7	47.9	12.1	99.8	1.3	439.1	12,543.3	
	No.2	10,404.4	3.4	50.1	1.2	40.4	0.6	62.7	1.0	54.3	3.4	71.4	1.0	78.1	367.6	10,772.0	
池排水ポンプ	No.1	69.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.5	0.0	0.0	0.0	2.5	72.4	

浄化センター（その3）

（単位：時間）

設備	機器名	No	29年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	30年度計	30年度まで累計
用水設備	原水ポンプ	No.1	36,276.7	63.7	0.1	4.2	0.1	5.0	0.2	24.1	0.0	3.3	0.6	3.4	0.0	104.7	36,381.4
		No.2	32,808.7	0.2	3.5	0.1	4.3	0.6	89.0	4.8	4.5	0.3	9.2	0.0	3.2	119.7	32,928.4
		No.3	15,110.5	300.8	293.3	323.5	348.0	355.9	249.8	258.7	322.2	387.0	329.3	360.8	385.2	3,914.5	19,025.0
	消泡水ポンプ	No.1	2,092.0	21.8	0.9	24.1	0.1	24.1	6.1	30.5	0.1	17.8	0.6	23.5	0.0	149.6	2,241.6
		No.2	1,813.0	0.2	16.4	0.0	30.3	0.4	13.2	0.0	20.3	4.4	26.7	0.0	18.3	130.2	1,943.2
	逆洗排水ポンプ	No.1	4,410.9	55.3	0.0	4.1	0.0	14.8	3.8	21.0	0.0	8.6	0.1	4.1	0.0	111.8	4,522.7
		No.2	4,669.6	4.2	4.9	0.2	4.3	0.3	75.4	2.5	4.7	0.1	24.5	0.0	8.6	129.7	4,799.3
	濾過水移送ポンプ	No.1	8,062.2	77.7	1.7	84.3	0.5	92.9	6.4	71.5	1.0	87.0	8.8	87.5	1.4	520.7	8,582.9
		No.2	8,582.0	4.8	82.6	1.7	97.2	1.3	88.1	2.0	80.0	8.1	68.8	1.5	96.7	532.8	9,114.8
	空気圧縮機	No.1	13,049.5	44.2	0.0	9.6	0.1	4.4	0.2	17.4	0.3	12.7	1.7	10.0	0.1	100.7	13,150.2
		No.2	13,521.7	0.8	11.6	0.1	6.5	0.1	54.4	2.2	15.0	1.1	21.9	0.3	7.4	121.4	13,643.1
	用水床排水ポンプ	No.1	888.9	22.1	0.5	21.3	0.4	24.7	2.1	21.7	6.1	22.0	3.2	59.2	1.6	184.9	1,073.8
		No.2	990.4	1.5	26.7	0.9	19.9	0.5	25.5	0.6	25.0	2.3	43.1	0.8	88.1	234.9	1,225.3
	ろ過器	No.2	15,110.5	300.8	293.3	323.5	348.0	355.9	249.8	258.7	322.2	387.0	329.3	360.8	385.2	3,914.5	19,025.0
次亜塩素酸ソーダ注入ポンプ	No.1	93,649.0	711.6	742.9	676.4	742.1	377.6	0.8	344.5	717.1	740.4	741.3	662.9	740.3	7,197.9	100,846.9	
	No.2	87,020.8	1.4	0.1	1.3	1.2	268.1	715.7	397.3	0.1	0.4	0.2	0.4	0.1	1,386.3	88,407.1	
	No.3	10,114.0	0.3	0.2	41.0	0.2	97.9	1.1	0.1	0.2	0.1	0.2	0.4	0.1	141.8	10,255.8	
機械濃縮設備	※余剰汚泥貯留槽攪拌機	No.1	107,343.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	317.9	743.1	1,061.0	108,404.4
	汚泥供給ポンプ	No.1	34,848.3	325.4	5.0	485.2	30.0	392.6	43.2	337.2	25.0	432.1	48.9	386.5	2.2	2,513.3	37,361.6
		No.3	35,217.9	33.3	456.5	9.4	386.4	11.4	380.7	8.3	370.0	35.7	337.4	12.7	421.8	2,463.6	37,681.5
	浮上濃縮機	No.1	70,063.7	358.7	461.4	494.6	416.4	404.0	423.9	345.5	395.0	467.8	386.3	399.2	423.9	4,976.7	75,040.4
	凝集剤供給機	No.1	722.5	4.8	5.6	5.9	5.9	6.8	6.6	4.4	4.9	5.8	5.0	5.3	6.0	67.0	789.5
		No.2	738.4	4.8	5.4	6.3	5.9	6.6	6.6	4.5	5.1	5.7	5.1	5.7	5.7	67.4	805.8
	凝集剤注入ポンプ	No.1	35,129.7	327.2	5.0	485.6	30.0	394.0	43.4	338.5	25.1	434.3	48.9	388.0	2.2	2,522.2	37,651.9
		No.2	35,379.1	33.3	458.8	9.4	387.3	11.5	381.8	8.3	371.4	35.2	338.8	12.7	422.7	2,471.2	37,850.3
	濃縮汚泥貯留槽攪拌機	No.1	22,926.5	7.3	13.8	5.4	16.1	11.8	13.1	3.3	10.8	7.4	15.9	6.7	7.3	118.9	23,045.4
	濃縮汚泥移送ポンプ	No.1	1,843.5	9.4	7.7	11.5	8.4	9.6	9.7	9.9	9.7	11.2	10.9	10.1	10.3	118.4	1,961.9
		No.2	1,790.0	7.3	11.7	11.2	9.8	11.1	10.8	6.8	9.6	9.6	10.5	10.7	10.3	119.4	1,909.4
	凝集剤溶解槽攪拌機	No.1	5,923.5	20.3	24.2	25.4	25.5	28.0	29.1	19.1	21.6	24.1	22.9	22.0	25.4	287.6	6,211.1
		No.2	5,966.0	20.1	24.0	25.2	24.0	28.7	26.5	20.1	20.1	25.0	21.3	22.5	25.0	282.5	6,248.5
	空気圧縮機	No.1	19,563.0	170.0	10.0	200.0	10.0	230.0	20.0	210.0	10.0	230.0	30.0	200.0	10.0	1,330.0	20,893.0
		No.2	20,880.0	20.0	260.0	10.0	240.0	10.0	280.0	10.0	290.0	10.0	270.0	10.0	300.0	1,710.0	22,590.0
	起泡用水ポンプ	No.1	33,912.7	319.7	11.7	477.4	34.0	384.8	52.1	332.8	30.5	425.5	58.9	337.7	46.5	2,511.6	36,424.3
		No.3	36,547.4	45.4	448.5	18.6	380.3	18.0	374.3	15.5	363.2	42.2	329.3	65.4	380.0	2,480.7	39,028.1
	起泡助剤希釈槽攪拌機	No.1	410.7	1.3	1.3	2.6	1.3	1.2	2.6	1.3	1.3	1.3	1.2	1.3	2.6	19.3	430.0
	起泡助剤注入ポンプ	No.1	35,233.5	319.7	11.7	477.4	34.0	384.8	52.1	332.8	43.0	425.2	58.9	384.0	6.3	2,529.9	37,763.4
		No.3	35,274.1	45.4	448.5	18.6	380.3	18.0	374.3	15.5	350.8	42.6	329.3	17.2	420.1	2,460.6	37,734.7
脱気槽攪拌機	No.1	71,181.2	366.6	461.9	500.2	415.0	403.8	427.6	349.2	394.9	468.9	391.3	402.5	427.3	5,009.2	76,190.4	
床排水ポンプ	No.1	785.8	1.8	0.0	2.7	0.2	2.5	0.3	1.9	0.5	2.9	0.3	2.2	0.0	15.3	801.1	
	No.2	787.5	0.2	2.5	0.1	2.3	0.1	4.6	0.1	3.9	0.1	23.9	0.1	2.5	40.4	827.9	

中継ポンプ場（その1）

（単位：時間）

設備	機器名	No	29年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	30年度計	30年度まで累計
獅子崎	細目除塵機	No.1		15.0	15.5	15.0	12.4	12.4	12.0	15.5	15.0	15.5	15.5	14.0	15.5	173.3	
	破砕機	No.1		35.0	36.1	35.0	28.9	28.9	28.0	36.1	35.0	36.1	36.1	32.6	36.1	403.9	
	汚水ポンプ	No.1	56,563.5	0.0	0.1	0.1	38.4	0.0	0.4	33.0	0.0	0.1	0.0	1.8	0.7	74.6	56,638.1
		No.2	55,605.9	0.1	0.0	0.1	79.6	0.6	0.5	27.7	0.0	0.1	0.1	0.1	0.7	109.6	55,715.5
		No.3	5,297.0	0.2	0.1	0.1	0.2	0.0	0.1	0.1	0.0	0.1	0.0	0.0	0.1	1.0	5,298.0
		No.4	80,968.8	665.3	789.9	719.9	737.3	766.5	668.8	789.4	716.5	663.8	784.6	662.7	714.3	8,679.0	89,647.8
		No.5	将来設備	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	水中ミキサー	No.1	113,412.0	671.8	792.0	722.1	741.6	767.7	671.6	791.4	719.7	672.0	791.9	672.0	717.7	8,731.5	122,143.5
		No.2	157,824.5	670.0	790.9	721.4	740.3	742.0	671.7	791.4	719.7	672.0	791.9	671.9	713.7	8,696.9	166,521.4
	脱臭ファン	No.1	111,050.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,760.0	119,810.0
鶴賀	細目除塵機	No.1		20.1	20.8	20.1	12.4	12.4	12.0	20.8	20.1	20.8	20.8	18.8	20.8	219.9	
	破砕機	No.1		46.8	48.5	46.8	28.9	28.9	28.0	48.5	46.8	48.5	48.5	43.8	48.5	512.5	
	汚水ポンプ	No.1	68,078.4	15.6	0.1	17.6	37.1	16.9	0.7	39.0	0.1	10.7	8.2	6.6	4.3	156.9	68,235.3
		No.2	68,538.2	0.1	16.6	0.0	83.6	0.1	23.3	5.4	17.8	7.2	10.1	0.1	11.7	176.0	68,714.2
		No.3	5,669.7	2.1	2.0	2.0	1.3	2.0	0.1	1.7	2.6	0.6	1.3	1.8	1.5	19.0	5,688.7
		No.4	70,972.3	644.7	771.1	697.4	726.4	746.2	654.1	774.2	696.1	645.5	772.9	654.8	699.2	8,482.6	79,454.9
		No.5	将来設備	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	水中ミキサー	No.1	183,896.9	672.2	791.9	721.4	742.5	767.6	672.2	791.8	719.3	672.1	792.0	669.7	718.7	8,731.4	192,628.3
		No.2	81,796.5	672.2	791.9	721.4	742.5	767.6	672.2	791.8	719.3	672.1	792.0	667.3	719.8	8,730.1	90,526.6
	脱臭ファン	No.1		720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,760.0	
須津	破砕機	No.1-1	142,882.7	641.4	754.2	681.6	713.5	736.3	648.6	761.0	686.1	649.5	766.1	642.1	687.2	8,367.6	151,250.3
		No.1-2	143,734.4	641.4	754.2	681.6	713.5	736.3	648.6	761.0	686.1	649.5	766.1	642.1	687.2	8,367.6	152,102.0
	汚水ポンプ	No.1	74,763.2	637.9	1.2	679.4	45.4	325.5	12.2	755.1	0.3	626.5	737.0	636.5	0.5	4,457.5	79,220.7
		No.2	74,976.5	0.1	753.7	0.3	710.2	406.6	645.1	18.0	696.3	0.1	8.1	0.1	680.6	3,919.2	78,895.7
		No.3	将来設備	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		No.4	1,721.9	3.3	5.2	2.8	19.8	6.0	3.1	19.3	26.6	22.9	24.6	5.5	6.2	145.3	1,867.2
	水中ミキサー		34,114.1	672.1	791.9	720.5	743.3	767.9	672.1	791.7	719.3	670.4	790.7	671.8	720.2	8,731.9	42,846.0
			33,067.3	672.1	791.9	720.5	743.3	767.9	672.1	791.7	719.3	670.4	788.9	671.8	720.2	8,730.1	41,797.4
	脱臭ファン	No.1	138,911.5	671.6	791.6	719.5	742.5	762.4	671.9	790.9	718.9	671.4	792.0	666.9	719.8	8,719.4	147,630.9
	床排水ポンプ	No.1	32.7	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.1	0.0	0.1	0.4	33.1
		No.2	18.8	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.1	0.4	19.2
	シール水ポンプ	No.1	22,101.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.1	22,101.5
		No.2	15,866.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.1	15,866.6

中継ポンプ場（その2）

（単位：時間）

設備	機器名	No	29年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	30年度計	30年度まで累計	
堂谷	破 碎 機	No.1-1	119,436.5	546.7	643.7	573.7	610.1	607.7	544.8	454.8	568.4	496.6	656.0	544.0	583.8	6,830.3	126,266.8	
		No.1-2	119,536.5	546.7	643.7	573.7	610.1	607.7	544.8	454.8	568.4	496.6	656.0	544.0	583.8	6,830.3	126,366.8	
	汚 水 ポ ン プ	No.1	62,669.6	546.7	89.9	573.7	120.0	607.7	72.6	270.8	63.3	119.6	107.8	70.5	79.4	2,722.0	65,391.6	
		No.2	67,485.7	62.2	643.7	66.6	610.1	62.2	544.8	454.8	568.4	496.6	656.0	544.0	583.8	5,293.2	72,778.9	
		No.3	将来設備	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
		No.4	407.8	0.1	0.1	0.1	11.4	1.9	1.6	13.1	0.5	0.2	0.1	0.1	0.1	29.3	437.1	
		No.5	将来設備	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	水 中 ミ キ サ ー	No.1	174,476.8	671.7	791.3	715.4	743.4	767.1	671.7	791.0	718.4	667.8	791.4	671.3	719.6	8,720.1	183,196.9	
		No.2	88,916.8	671.7	791.3	715.1	743.4	767.0	671.7	791.0	718.4	668.5	791.4	671.2	714.7	8,715.4	97,632.2	
	脱 臭 フ ァ ン	No.1	54,985.9	236.4	277.4	248.8	260.0	264.9	234.1	279.0	255.4	240.2	283.0	236.5	253.9	3,069.6	58,055.5	
	床 排 水 ポ ン プ	No.1	6.7	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.3	7.0
		No.2	11.3	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.7	12.0
	シ ー ル 水 ポ ン プ	No.1	12,109.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.1	0.3	12,109.3	
		No.2	12,580.3	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.3	0.1	0.0	0.0	0.6	12,580.9	
四辻	破 碎 機	No.1-1	108,606.2	570.4	727.2	604.1	664.3	609.4	590.6	600.4	618.4	555.9	506.1	787.1	657.8	7,491.7	116,097.9	
		No.1-2	105,470.8	570.4	727.2	604.1	664.3	609.4	590.6	600.4	618.4	555.9	506.1	787.1	657.8	7,491.7	112,962.5	
	汚 水 ポ ン プ	No.1	63,321.9	570.4	137.5	604.1	155.6	609.4	65.8	600.4	62.3	555.9	270.8	787.1	83.4	4,502.7	67,824.6	
		No.2	64,060.4	66.7	727.2	68.2	664.3	44.0	590.6	21.4	618.4	49.7	506.1	529.0	657.8	4,543.4	68,603.8	
		No.3	240.8	3.3	3.4	5.2	2.9	4.5	2.7	3.3	3.5	2.6	4.4	2.6	3.1	41.5	282.3	
		No.4	将来設備	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	水 中 ミ キ サ ー	No.1	1,731,059.6	671.8	791.7	717.3	745.2	767.6	671.6	787.9	719.8	672.1	791.9	671.8	720.0	8,728.7	1,739,788.3	
		No.2	50,035.2	671.9	791.7	717.3	745.2	767.6	671.6	787.9	719.8	672.1	791.9	671.8	720.0	8,728.8	58,764.0	
	脱 臭 フ ァ ン	No.1	46,417.4	136.1	159.3	143.9	148.2	151.8	133.1	157.4	143.6	134.7	159.4	136.8	144.6	1,748.9	48,166.3	
	床 排 水 ポ ン プ	No.1	3.4	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.4	3.8	
		No.2	5.5	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.1	0.4	5.9	
	シ ー ル 水 ポ ン プ	No.1	10,758.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10,758.5	
		No.2	11,719.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	11,719.2	