

## 4 機械関係

### (1) 機械設備稼働状況

No. 1 (単位:時間)

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計
自家発電棟	非常用自家発電機	No.4		38.9	0.1	0.1	0.2	0.2	0.1	0.2	0.1	0.1	0.2	0.2	0.4	2.0	3.9	42.8
		No.3		167.9	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	2.3	3.5
第1ポンプ棟	主ポンプ	1号	(J-H-N6)	1,615.5	4.5	0.8	30.5	13.8	15.5	40.4	22.1	4.5	3.8	0.3	0.4	26.4	163.0	1,778.5
		2号	(J-H-N3)	1,280.0	4.9	4.1	31.3	6.3	5.8	57.2	24.3	7.9	3.2	7.8	4.3	49.3	206.4	1,486.4
		3号	(J-H-N5)	94,672.2	587.0	637.2	605.8	667.0	662.4	616.1	617.1	653.1	683.6	573.6	637.0	625.3	7,565.2	102,237.4
		4号	(J-H-N2)	76,057.7	267.0	239.6	298.3	440.6	349.7	364.3	360.4	314.7	247.6	334.0	246.6	169.5	3,632.3	79,690.0
		5号	インバータ盤	118,418.6	457.7	473.0	356.7	222.5	321.7	278.2	328.7	329.5	397.2	422.3	326.1	422.9	4,336.5	122,755.1
第1ポンプ棟 し渣設備 (J-C-N1)	し渣スキップホイスト		(2G)	1,873.5	-	-	-	-	-	-	-	-	-	-	-	-	0.0	1,873.5
	細目自動除塵機	No.1	(3A)	12,279.6	9.7	10.0	10.8	10.5	10.8	9.7	11.2	10.3	10.7	11.0	9.5	10.8	125.0	12,404.6
		No.2	(3B)	19,083.5	9.6	9.9	11.0	10.5	10.7	9.8	11.2	10.3	10.5	10.1	9.4	10.6	123.6	19,207.1
		No.3	(3C)	19,832.5	9.9	10.4	11.7	10.7	10.9	10.0	11.4	10.4	10.8	11.4	9.5	10.9	128.0	19,960.5
	し渣破砕機		(3D)	422.1	-	-	-	-	-	-	-	-	-	-	-	-	0.0	422.1
	し渣脱水機		(3E)	22,851.5	-	-	-	-	-	-	-	-	-	-	-	-	0.0	22,851.5
	粗目自動除塵機	No.1	(4A)	476.6	2.1	2.4	2.2	2.1	2.3	2.2	2.2	2.1	2.2	2.3	2.0	2.1	26.2	502.8
		No.2	(7C)	430.4	1.8	1.8	1.8	1.9	2.1	1.6	1.9	1.6	1.6	2.2	1.6	1.7	21.6	452.0
		No.3	(7E)	450.2	1.9	1.9	2.0	1.9	2.0	1.8	1.9	1.8	1.9	2.0	1.7	1.8	22.6	472.8
	し渣搬出機	No.1	(4D)	1,186.5	7.2	7.9	7.7	7.4	8.6	7.2	7.4	7.0	7.6	8.4	6.7	7.4	90.5	1,277.0
		No.2	(4E)	1,358.7	7.7	8.5	8.2	7.9	9.2	7.7	7.9	7.5	8.1	8.8	7.2	7.9	96.6	1,455.3
		No.3	(4F)	23,770.3	42.0	44.1	45.5	46.6	46.0	41.9	46.2	43.3	44.7	45.0	39.6	45.2	530.1	24,300.4
		No.4	(4G)	23,540.6	-	-	-	-	-	-	-	-	-	-	-	-	0.0	23,540.6
	し渣洗浄攪拌機		(5D)	24,909.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24,909.0
	予備		(6A)	0.0	-	-	-	-	-	-	-	-	-	-	-	-	0.0	0.0
沈砂池室床排水ポンプ	No.1	(6B)	19.6	-	-	-	-	-	-	-	-	-	-	-	-	0.0	19.6	
	No.2	(6C)	4,088.0	-	-	-	-	-	-	-	-	-	-	-	-	0.0	4,088.0	
	No.3	(6D)	4,128.5	-	-	-	-	-	-	-	-	-	-	-	-	0.0	4,128.5	

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計	
第1ポンプ棟 沈砂設備 (J-C-N2)	高架水槽揚水ポンプ	No.1	(6E)	4,124.7	14.5	14.7	16.3	17.7	17.6	18.7	17.9	15.8	14.7	15.2	12.6	18.2	193.9	4,318.6	
		No.2	(6F)	4,168.2	14.0	14.0	15.7	17.0	17.0	18.5	17.3	15.1	14.4	14.6	12.4	17.4	187.4	4,355.6	
	沈砂池揚砂ポンプ	No.1	(2A)	1,481.2	8.8	8.6	8.5	8.9	8.3	7.6	8.1	9.0	6.1	6.6	5.5	4.7	90.7	1,571.9	
		No.2	(2B)	1,824.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	1,824.5
		No.3	(2C)	1,525.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	1,525.5
	沈砂洗浄攪拌機		(3A)	5,533.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	5,533.8
	沈砂搬出機		(3D)	6,319.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	6,319.7
沈砂スキップホイスト		(3E)	228.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	228.7	
第1ポンプ棟	主ポンプ室床排水ポンプ	No.1	(2E)	5,763.7	28.1	28.8	37.1	39.4	36.0	47.3	37.3	31.6	29.3	29.4	27.3	42.0	413.6	6,177.3	
		No.2	(2F)	4,932.7	20.0	20.3	25.9	27.4	25.3	31.3	26.2	22.2	20.8	20.8	19.3	29.1	288.6	5,221.3	
	主ポンプ冷却水ポンプ	No.1	(2G)	109,189.8	523.7	522.8	485.0	325.1	387.1	371.5	438.9	346.7	404.2	414.4	336.7	312.7	4,868.8	114,058.6	
		No.2	(2H)	101,591.6	195.5	220.3	254.0	418.0	356.6	386.4	304.7	373.5	339.6	329.8	335.1	430.8	3,944.3	105,535.9	
	分配槽床排水ポンプ	No.1	(4D)	6.1	0.1	0.0	0.1	0.0	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.1	7.2
No.2		(4E)	4.1	0.0	0.1	0.1	0.0	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.1	5.2	
第1送風機棟 送風機設備 (C-C-C)	送風機3相420V	No.1	(2B)	70,780.3	169.5	296.2	244.6	197.0	215.4	125.6	334.1	195.8	316.3	85.6	60.6	200.3	2,441.0	73,221.3	
		No.2	(3B)	62,535.4	205.5	257.4	188.4	215.2	144.9	111.4	14.1	0.0	0.0	0.0	0.0	1,136.9	63,672.3		
		No.3	(4A)	100,043.6	429.3	130.2	339.4	256.2	347.1	453.9	552.6	545.7	495.2	130.5	107.7	496.5	4,284.3	104,327.9	
	送風機3相6600V	No.4	(C-H-C1)	99,985.7	323.7	310.0	201.5	169.7	149.3	306.8	477.7	409.7	435.3	339.7	318.5	401.9	3,843.8	103,829.5	
		No.5	(C-H-C2)	77,737.5	642.7	487.5	64.1	313.7	668.3	655.9	205.4	148.2	18.3	247.0	85.8	163.6	3,700.5	81,438.0	
		No.6	(C-H-C3)	62,309.7	0.8	100.8	605.2	217.4	33.0	0.0	0.0	0.0	404.2	101.2	234.9	112.1	1,809.6	64,119.3	
	潤滑油ポンプ	No.1	(7B)	108,180.2	43.0	621.1	58.4	584.8	26.0	520.2	74.8	362.0	122.1	228.0	72.0	473.2	3,185.6	111,365.8	
		No.2	(7C)	98,995.6	571.4	23.4	554.1	21.4	594.3	50.3	610.1	246.1	521.5	204.0	300.5	132.0	3,829.1	102,824.7	
		No.3	(9B)	71,760.8	1.3	575.7	49.7	521.9	22.5	615.6	96.4	91.3	0.4	297.8	107.1	229.1	2,608.8	74,369.6	
		No.4	(9C)	68,784.2	644.2	25.4	604.0	28.2	682.7	44.9	115.2	65.9	429.0	65.9	229.7	55.6	2,990.7	71,774.9	
	潤滑油冷却塔	No.1	(7F)	161,135.6	0.0	453.7	612.6	606.2	620.2	567.6	684.7	608.1	124.4	0.0	0.0	0.0	4,277.5	165,413.1	
		No.2	(9F)	102,183.9	0.0	408.5	653.7	550.1	705.2	660.4	211.6	157.2	4.7	0.0	0.0	0.0	3,351.4	105,535.3	
	冷却水ポンプ	No.1	(7D)	177,292.6	614.0	640.2	612.6	606.2	620.2	567.6	684.7	608.0	643.3	431.2	371.9	604.8	7,004.7	184,297.3	
No.2		(7E)	29,807.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	285.7	363.6	336.8	284.6	1,270.7	31,078.0		
No.3		(9D)	138,719.8	645.4	601.0	653.7	550.1	705.2	660.4	211.7	157.2	143.9	0.1	0.1	0.1	4,328.9	143,048.7		

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計
第1送風機棟 A系 最初沈殿池設備 (C-C-D1)	汚泥掻寄機	A-1-1	(2E)	17,755.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	235.5	0.0	568.6	741.1	1,545.2	19,300.6
		A-1-2	(2F)	34,172.5	0.0	0.5	5.2	7.3	7.9	0.0	1.4	1.0	6.0	7.8	2.3	1.0	40.4	34,212.9
		A-2	(2G)	131,799.2	719.8	744.1	719.5	742.5	743.7	716.6	743.6	720.1	743.6	744.2	665.6	741.1	8,744.4	140,543.6
		A-3	(2A)	88,876.9	0.0	0.4	6.5	1.4	5.1	0.0	1.7	1.0	5.8	1.6	7.3	1.0	31.8	88,908.7
		A-4	(6B)	43,417.8	0.0	0.0	10.6	3.0	3.7	0.0	0.7	1.0	5.7	0.0	2.3	1.0	28.0	43,445.8
		A-5	(6C)	99,890.5	0.0	0.0	0.4	3.3	1.4	0.0	0.7	1.0	5.8	7.7	2.3	1.0	23.6	99,914.1
	A-6	(6D)	69,343.0	0.0	0.0	14.3	5.8	1.5	0.0	0.7	1.0	5.8	7.7	2.3	0.9	40.0	69,383.0	
	汚泥引抜ポンプ	A-1	(3E)	8,065.0	0.0	0.0	0.1	0.0	0.0	0.1	0.0	0.0	0.1	111.1	99.5	109.5	320.4	8,385.4
		A-2	(3F)	65,724.5	24.2	284.3	30.7	275.0	10.7	259.2	10.6	0.0	247.3	46.8	184.5	33.5	1,406.8	67,131.3
	A-3	(3G)	71,586.9	238.2	10.8	225.1	10.0	253.4	19.6	249.9	251.9	18.7	169.3	32.8	193.6	1,673.3	73,260.2	
	スカム移送ポンプ	A-1	(4E)	1,743.5	0.0	0.3	0.0	0.9	0.6	0.0	0.0	0.7	0.8	1.0	0.1	0.0	4.4	1,747.9
		A-2	(4F)	1,590.6	0.6	0.0	0.5	0.1	0.1	0.9	1.0	0.7	0.3	0.1	1.0	0.4	5.7	1,596.3
	沈殿池管廊床排水P	A-1	(3B)	505.7	0.7	0.1	0.4	0.7	0.2	9.1	0.3	0.2	0.2	0.1	0.4	0.2	12.6	518.3
		A-2	(9F)	62.5	0.1	0.0	0.1	0.1	0.0	8.4	0.1	0.1	0.1	0.1	0.1	0.1	9.3	71.8
	送風機管廊床排水ポンプ	No-1	(3C)	113.3	0.0	0.1	0.0	0.0	0.0	7.4	0.1	0.1	0.1	0.1	0.1	0.1	8.1	121.4
No-2		(3D)	607.4	0.5	0.7	1.1	0.5	0.2	60.5	1.2	0.3	0.2	0.1	0.1	0.2	65.6	673.0	
No-3		(9G)	137.0	0.3	0.0	0.3	0.1	0.1	15.5	1.1	0.2	0.1	0.1	0.1	0.2	18.1	155.1	
第1送風機棟 B系 最初沈殿池設備 (C-C-D2)	汚泥掻寄機	B-1	(F2C)	96,627.3	719.8	744.1	719.5	742.3	743.7	246.9	11.5	1.1	5.8	378.4	655.3	741.1	5,709.5	102,336.8
		B-2	(F2D)	91,733.6	6.2	5.0	16.1	12.1	7.7	474.4	743.6	720.1	743.7	366.7	0.0	0.9	3,096.5	94,830.1
		B-3	(F2E)	106,024.1	719.8	744.1	719.5	742.3	743.7	244.3	1.2	0.0	0.0	378.1	655.3	741.1	5,689.4	111,713.5
		B-4	(F2F)	57,309.4	719.8	744.1	719.5	742.3	743.7	715.7	743.6	720.1	743.8	362.2	0.0	0.8	6,955.6	64,265.0
		B-5	(F4E)	75,907.9	7.6	4.8	0.0	0.0	0.0	1.9	15.0	7.7	8.9	379.8	655.3	741.1	1,822.1	77,730.0
		B-6	(F4F)	96,585.6	6.2	5.2	14.2	424.3	26.1	476.0	743.6	720.1	743.8	365.2	0.0	0.8	3,525.5	100,111.1
	汚泥引抜ポンプ	B-1	(F2A)	80,142.9	18.2	415.4	55.2	17.2	16.3	390.1	21.9	400.9	30.9	316.2	63.4	334.6	2,080.3	82,223.2
		B-2	(F2B)	79,191.1	402.7	15.2	362.6	424.7	425.8	30.3	416.8	17.1	386.7	76.2	293.4	54.3	2,905.8	82,096.9
	スカム移送ポンプ	B-1	(R2A)	977.3	0.0	0.8	0.9	1.2	0.3	0.1	0.0	1.0	0.9	0.9	0.0	0.7	6.8	984.1
		B-2	(R2B)	1,123.1	1.4	0.0	0.1	0.1	0.1	0.9	1.0	0.1	0.1	0.1	0.2	0.1	4.2	1,127.3
	管廊床排水ポンプ	B-1	(R2E)	99.7	0.6	0.2	0.8	0.3	0.3	6.8	0.6	0.2	0.2	0.2	0.2	0.4	10.8	110.5
		B-2	(R2F)	65.8	0.2	0.0	0.1	0.1	0.1	5.6	0.1	0.1	0.1	0.1	0.1	0.1	6.7	72.5

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計	
第1送風機棟 A系 エアタン設備 (C-C-C2)	A-4エアレータ	A-4-1	(F2A)	148,150.9	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,150.9	
		A-4-2	(F2B)	148,482.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,482.9
		A-4-3	(F2C)	148,623.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,623.8
		A-4-4	(F2D)	147,807.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,807.7
		A-4-5	(F2E)	147,606.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,606.3
		A-4-6	(F2F)	148,092.1	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	148,092.1
		A-4-7	(F2G)	147,723.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,723.9
		A-4-8	(F2H)	147,175.2	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	147,175.2
	A-5エアレータ	A-5-1	(F3A)	155,223.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,223.6
		A-5-2	(F3B)	156,674.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,674.5
		A-5-3	(F3C)	156,748.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,748.3
		A-5-4	(F3D)	155,027.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,027.5
		A-5-5	(F3E)	156,772.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,772.9
		A-5-6	(F3F)	156,466.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,466.5
		A-5-7	(F3G)	156,599.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,599.3
		A-5-8	(F3H)	155,889.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,889.5
	A-6エアレータ	A-6-1	(R2A)	155,711.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,711.6
		A-6-2	(R2B)	156,258.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,258.8
		A-6-3	(R2C)	156,152.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,152.6
		A-6-4	(R2D)	154,393.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	154,393.9
		A-6-5	(R2E)	156,679.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,679.6
		A-6-6	(R2F)	155,738.7	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,738.7
		A-6-7	(R2G)	156,060.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	156,060.9
		A-6-8	(R2H)	155,251.4	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	155,251.4
第1送風機棟 B系 エアタン設備 (C-C-C3)	B-1エアレータ	B-1-1	(F2A)	177,194.8	713.5	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	743.8	671.8	744.0	8,752.7	185,947.5	
		B-1-2	(F2B)	177,421.6	719.8	743.7	713.4	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,752.9	186,174.5	
		B-1-3	(F2C)	177,092.1	719.8	744.1	712.8	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,752.7	185,844.8	
		B-1-4	(F2D)	175,665.8	719.8	744.1	719.5	737.0	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,752.1	184,417.9	

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計	
第1送風機棟 B系 エアタン設備 (C-C-C3)	B-1エアレータ	B-1-5	(F2E)	175,878.2	719.8	744.1	719.5	744.3	743.7	720.5	736.7	720.1	743.7	744.2	671.8	744.0	8,752.4	184,630.6	
		B-1-6	(F2F)	173,763.1	719.8	744.1	717.9	744.3	743.7	720.5	743.7	720.1	743.7	720.3	671.8	744.0	8,733.9	182,497.0	
		B-1-7	(F2G)	177,676.9	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	743.8	671.8	744.0	8,759.0	186,435.9	
		B-1-8	(F2H)	171,709.2	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	180,468.6	
	B-2エアレータ	B-2-1	(F3A)	177,432.5	712.6	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,752.2	186,184.7	
		B-2-2	(F3B)	172,439.6	719.8	743.7	713.3	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,752.8	181,192.4	
		B-2-3	(F3C)	177,648.3	719.8	744.1	713.1	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,753.0	186,401.3	
		B-2-4	(F3D)	177,309.6	719.8	744.1	719.5	744.3	743.7	720.5	736.8	720.1	743.7	744.2	671.8	744.0	8,752.5	186,062.1	
		B-2-5	(F3E)	177,385.8	719.8	744.1	719.5	706.9	743.7	720.5	736.7	720.1	743.7	744.2	671.8	744.0	8,715.0	186,100.8	
		B-2-6	(F3F)	177,557.2	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	737.8	671.8	744.0	8,753.0	186,310.2	
		B-2-7	(F3G)	177,641.1	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	736.6	671.8	744.0	8,751.8	186,392.9	
		B-2-8	(F3H)	176,350.5	719.8	744.1	719.5	744.3	708.0	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,723.7	185,074.2	
	B-3エアレータ	B-3-1	(R2A)	177,350.4	713.0	744.1	719.5	744.3	732.6	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,741.5	186,091.9	
		B-3-2	(R2B)	177,109.7	719.8	744.1	713.4	744.3	732.6	720.5	743.7	720.1	740.0	744.2	671.8	744.0	8,738.5	185,848.2	
		B-3-3	(R2C)	176,417.1	719.8	744.1	671.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,135.7	178,552.8
		B-3-4	(R2D)	171,554.7	719.8	744.1	719.5	744.3	732.6	720.5	736.8	720.1	743.7	744.2	671.8	744.0	8,741.4	180,296.1	
		B-3-5	(R2E)	176,569.8	719.8	744.1	719.5	744.3	732.6	720.5	736.7	720.1	743.7	744.2	671.8	744.0	8,741.3	185,311.1	
		B-3-6	(R2F)	176,903.9	719.8	744.1	719.5	744.3	732.6	720.5	743.7	720.1	743.7	738.1	671.8	744.0	8,742.2	185,646.1	
		B-3-7	(R2G)	174,921.3	719.8	744.1	719.5	744.3	732.6	720.5	743.7	720.1	743.7	743.1	671.8	744.0	8,747.2	183,668.5	
		B-3-8	(R2H)	175,806.0	719.8	744.1	719.5	744.3	732.6	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,748.3	184,554.3	
	B-4エアレータ	B-4-1	(F4A)	155,111.1	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	163,870.5	
		B-4-2	(F4B)	153,470.4	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	162,229.8	
		B-4-3	(F4C)	155,241.8	719.8	744.1	719.5	744.3	743.7	720.5	742.0	720.1	743.7	744.2	671.8	744.0	8,757.7	163,999.5	
		B-4-4	(F4D)	154,448.7	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	163,208.1	
		B-4-5	(F4E)	153,822.9	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	162,582.3	
		B-4-6	(F4F)	154,657.2	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	163,416.6	
		B-4-7	(F4G)	149,024.2	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	157,783.6	
		B-4-8	(F4H)	154,544.3	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	163,303.7	

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計
第1送風機棟 B系 エアタン設備 (C-C-C3)	B-5エアレータ	B-5-1	(F5A)	155,346.7	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	164,106.1
		B-5-2	(F5B)	155,126.1	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	163,885.5
		B-5-3	(F5C)	154,404.4	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	163,163.8
		B-5-4	(F5D)	155,397.6	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	164,157.0
		B-5-5	(F5E)	154,696.8	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	163,456.2
		B-5-6	(F5F)	154,752.6	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	163,512.0
		B-5-7	(F5G)	154,783.6	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	163,543.0
		B-5-8	(F5H)	153,263.4	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	162,022.8
	B-6エアレータ	B-6-1	(R4A)	154,898.1	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	163,657.5
		B-6-2	(R4B)	148,876.6	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	157,636.0
		B-6-3	(R4C)	155,309.8	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	164,069.2
		B-6-4	(R4D)	154,936.3	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	163,695.7
		B-6-5	(R4E)	153,511.3	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	162,270.7
		B-6-6	(R4F)	155,343.1	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	164,102.5
		B-6-7	(R4G)	153,978.7	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	162,738.1
B-6-8		(R4H)	154,390.7	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.8	744.0	8,759.4	163,150.1	
エアタン管廊床 排水ポンプ	B-1	(R3A)	205.2	0.3	0.2	0.9	0.5	0.3	22.4	1.7	0.3	0.2	0.1	0.1	0.4	27.4	232.6	
	B-2	(R3B)	134.8	0.4	0.1	1.2	0.4	0.4	10.5	0.9	0.3	0.1	0.1	0.1	0.5	15.0	149.8	
第1送風機棟 A系 最終沈殿池設備 (C-C-E1)	汚泥掻寄機	A-1-1	(2A)	224,877.1	719.9	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.1	743.3	8,758.1	233,635.2
		A-1-2	(2B)	227,870.3	719.9	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.1	743.3	8,758.1	236,628.4
		A-2	(2C)	223,736.1	719.9	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.7	744.2	671.1	743.3	8,758.1	232,494.2
		A-3	(6B)	214,768.8	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.2	744.2	671.1	742.9	8,757.1	223,525.9
		A-4	(7B)	153,014.4	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	743.5	744.2	671.1	743.2	8,757.7	161,772.1
		A-5	(7C)	159,917.2	719.8	744.1	719.5	744.3	743.7	720.5	719.0	605.4	0.0	0.0	187.4	743.4	6,647.1	166,564.3
		A-6	(7D)	159,199.2	719.8	744.1	719.5	744.3	743.7	720.5	743.7	720.1	742.5	744.2	671.1	743.3	8,756.8	167,956.0

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計	
第1送風機棟 A系 最終沈殿池設備 (C-C-E1)	返送汚泥ポンプ	A-1	(3A)	132,119.0	28.7	0.1	626.2	46.5	139.1	671.1	82.9	475.6	63.7	8.4	56.2	21.2	2,219.7	134,338.7	
		A-2	(3B)	158,758.6	690.7	25.3	96.2	714.3	47.8	111.9	715.6	49.9	690.0	152.4	0.3	456.3	3,750.7	162,509.3	
		A-3	(3C)	162,650.2	14.4	724.1	150.2	27.8	715.1	101.3	81.6	220.6	1.3	598.6	622.9	333.5	3,591.4	166,241.6	
		A-4	(9E)	149,601.4	719.7	743.8	719.5	744.0	743.4	720.4	743.7	719.9	743.7	744.2	670.8	743.2	8,756.3	158,357.7	
		A-5	(9F)	142,610.9	719.7	743.9	719.5	744.3	743.7	720.3	743.7	720.1	743.7	744.2	670.8	742.9	8,756.8	151,367.7	
	スカム分離機	A-1	(2D)	51,541.0	79.8	69.5	64.6	77.7	75.1	77.8	73.6	70.7	70.8	72.8	66.4	70.1	868.9	52,409.9	
	スカム移送ポンプ	A-1	(2E)	24,001.6	2.4	66.2	7.0	73.4	3.2	70.4	3.0	67.1	4.7	56.6	7.7	60.4	422.1	24,423.7	
		A-2	(2F)	24,225.5	76.1	2.1	56.5	2.5	70.5	5.7	69.0	2.9	64.2	14.4	56.9	8.5	429.3	24,654.8	
	余剰汚泥ポンプ	A-1	(4B)	39,158.9	0.0	103.0	13.4	169.4	8.5	198.4	7.4	138.2	184.5	25.3	0.1	124.1	972.3	40,131.2	
		A-2	(4C)	42,296.1	71.9	2.3	77.3	4.1	155.6	19.1	135.5	2.1	0.1	88.3	112.0	16.6	684.9	42,981.0	
		A-3	(9C)	14,714.6	2.1	60.9	5.5	74.3	2.8	72.1	1.0	60.9	7.6	82.0	10.8	85.8	465.8	15,180.4	
		A-4	(9D)	14,368.2	69.4	3.8	92.4	6.3	112.3	14.2	107.3	4.6	89.2	14.4	81.7	10.1	605.7	14,973.9	
	消泡水ポンプ	A-1	(5C)	101,794.1	8.5	181.9	18.7	173.6	6.8	156.5	8.4	71.3	0.0	191.6	192.3	188.9	1,198.5	102,992.6	
		A-2	(5D)	114,369.6	173.4	5.2	140.1	10.8	149.7	12.6	215.8	113.2	195.5	39.3	0.0	0.0	1,055.6	115,425.2	
	管廊床排水ポンプ	管理棟	(4E)	928.6	0.2	0.1	1.5	0.2	0.1	16.5	1.3	0.2	0.1	0.1	0.1	0.1	0.3	20.7	949.3
		終沈A-1	(4F)	724.0	1.0	0.9	0.7	1.3	3.1	27.9	3.1	0.8	0.9	0.7	0.4	0.6	41.4	765.4	
		終沈A-2	(9B)	271.7	0.4	0.3	0.4	0.1	1.0	8.9	1.3	1.0	0.6	0.5	0.7	0.4	15.6	287.3	
		濃縮A-1	(4G)	166.8	0.0	0.1	0.5	0.1	0.2	11.5	0.4	0.1	0.1	0.1	0.1	0.1	13.3	180.1	
		濃縮A-2	(4H)	989.5	1.8	1.1	0.3	2.6	1.4	11.1	1.4	7.2	13.3	27.5	3.2	1.0	71.9	1,061.4	
	放流水消毒設備	A系次亜塩注入ポンプ	No-1		40,053.7	-	-	-	-	-	-	-	-	-	-	-	-	0.0	40,053.7
No-2				63,307.6	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	63,307.6
No-3				66,540.3	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	66,540.3
B系次亜塩注入ポンプ		No-4		51,686.8	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	51,686.8
		No-5		39,011.2	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	39,011.2
		No-6		44,626.5	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	44,626.5

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計
第1送風機棟 B系 最終沈殿池設備 (C-C-E2)	汚泥掻寄機	B-1	(F2B)	175,231.7	719.9	744.1	719.5	744.3	743.7	720.4	743.8	720.1	743.7	744.2	670.9	743.3	8,757.9	183,989.6
		B-2	(F2C)	177,177.4	719.9	744.1	719.5	744.3	743.7	720.4	743.8	720.1	743.7	744.2	670.9	743.3	8,757.9	185,935.3
		B-3	(F2D)	176,902.2	719.9	744.1	719.5	744.3	743.7	720.4	743.8	720.1	743.7	744.2	670.9	743.3	8,757.9	185,660.1
		B-4	(F4B)	153,480.0	719.9	744.1	719.5	744.3	742.8	720.4	743.8	720.1	743.7	744.2	670.9	743.3	8,757.0	162,237.0
		B-5	(F4C)	153,797.8	719.9	744.1	719.5	744.3	742.8	720.4	743.8	720.1	743.7	744.2	670.9	743.3	8,757.0	162,554.8
		B-6	(F4D)	153,735.2	719.9	744.1	719.5	744.3	742.8	720.4	743.8	720.1	743.7	744.2	670.9	743.3	8,757.0	162,492.2
	返送汚泥ポンプ	B-1	(F2E)	172,527.5	719.8	743.5	719.0	744.3	743.4	720.3	743.8	719.6	743.7	744.2	670.5	743.3	8,755.4	181,282.9
		B-2	(F2F)	166,483.4	719.8	743.7	719.0	744.3	743.4	720.3	743.8	719.6	743.7	744.2	670.5	743.3	8,755.6	175,239.0
		B-3	(F4E)	151,552.9	719.8	743.9	719.1	744.3	740.7	720.3	743.8	719.6	743.7	744.2	670.5	743.3	8,753.2	160,306.1
		B-4	(F4F)	148,411.9	719.8	743.9	719.0	744.3	740.2	720.3	743.8	720.1	743.7	744.2	670.5	743.3	8,753.1	157,165.0
	余剰汚泥ポンプ	B-1	(F3B)	21,525.7	7.9	166.3	22.3	189.2	8.4	167.9	6.4	128.7	15.5	135.6	15.1	115.6	978.9	22,504.6
		B-2	(F3C)	24,871.9	183.4	6.9	160.4	5.6	190.9	10.7	171.3	7.4	149.9	34.6	131.6	22.5	1,075.2	25,947.1
	消泡水ポンプ	B-1	(F3E)	66,165.1	179.2	181.5	157.3	165.7	200.2	163.3	178.6	174.4	192.0	201.1	175.5	195.7	2,164.5	68,329.6
		B-2	(F3F)	67,016.7	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.0	0.0	0.0	0.0	0.5	67,017.2
	スカム移送ポンプ	B-1	(R2A)	31,430.4	14.1	343.2	35.2	293.2	40.7	296.6	14.7	305.0	23.8	282.6	36.9	334.1	2,020.1	33,450.5
		B-2	(R2B)	36,189.7	336.8	11.3	248.7	10.1	301.3	24.6	311.1	13.7	331.5	68.9	285.7	44.3	1,988.0	38,177.7
	スカム分離機	B-1	(R2E)	62,871.2	324.9	319.9	250.8	268.4	311.0	297.0	297.6	279.2	322.1	315.9	294.7	348.3	3,629.8	66,501.0
	管廊床排水ポンプ	B-1	(R2G)	123.8	0.3	0.2	0.6	0.3	0.4	8.2	0.5	0.3	0.2	0.1	0.2	1.1	12.4	136.2
		B-2	(R2H)	285.0	0.4	0.2	0.5	0.2	0.5	8.5	0.8	0.3	0.3	0.2	1.5	10.4	23.8	308.8
	井水棟設備	深井戸揚水ポンプ	No.-1		78,524.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
No.-2				48,889.0	36.8	142.2	156.4	198.2	308.4	128.8	192.9	36.9	36.3	38.1	30.1	29.9	1,335.0	50,224.0
No.-3				40,655.9	49.4	112.6	300.6	274.8	404.9	272.4	33.6	30.2	30.2	32.2	30.1	20.1	1,591.1	42,247.0
送水ポンプ		No.-1		94,217.9	243.1	260.9	287.6	264.0	239.2	241.7	264.3	271.7	243.2	0.4	235.3	240.5	2,791.9	97,009.8
		No.-2		98,022.1	213.1	244.1	239.3	220.9	263.9	230.4	267.6	232.5	259.1	239.7	286.1	242.6	2,939.3	100,961.4
		No.-3		87,731.3	265.4	238.1	192.7	259.5	240.0	240.7	211.8	215.7	240.7	473.9	192.6	261.4	3,032.5	90,763.8
次亜塩注入ポンプ		No.-1		35,941.1	7.5	8.5	10.5	9.6	8.9	12.5	8.3	7.3	16.3	20.0	6.8	10.7	126.9	36,068.0
		No.-2		19,969.9	8.4	9.9	9.8	10.4	11.3	10.2	12.1	13.3	10.7	3.8	13.8	8.3	122.0	20,091.9
		No.-3		19,955.5	9.8	9.8	9.1	10.8	12.9	12.6	13.2	9.4	3.8	8.4	9.1	10.3	119.2	20,074.7



区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計
井水棟設備	急速ろ過器逆洗ポンプ	No.1		838.4	0.5	0.6	0.4	0.5	1.5	1.1	0.8	0.3	0.2	0.9	0.5	0.8	8.1	846.5
		No.2		568.4	0.3	0.3	0.4	0.8	0.0	0.1	0.5	0.5	0.7	0.0	0.5	0.0	0.0	4.1
	急速ろ過器	No.1		46,997.4	11.7	13.5	14.5	13.8	14.1	18.0	13.9	13.0	24.2	20.1	14.3	14.6	185.7	47,183.1
		No.2		31,109.0	14.2	14.6	14.7	16.4	18.8	17.4	19.7	17.2	6.8	12.1	15.8	14.6	182.3	31,291.3
A・B 系重力濃縮設備 (F-C-P1)	し渣破碎机	A-1	(5D)	29,943.8	58.5	316.8	101.9	339.0	351.5	342.3	146.2	357.2	42.7	340.2	85.6	379.3	2,861.2	32,805.0
		A-2	(5C)	25,879.9	378.2	127.7	330.0	116.6	103.5	89.0	306.3	73.4	415.9	125.8	355.0	91.1	2,512.5	28,392.4
	濃縮汚泥掻寄機	A-1	(2C)	194,606.5	716.1	740.3	715.3	741.6	739.7	711.2	741.0	716.6	740.3	741.3	668.7	739.3	8,711.4	203,317.9
		A-2	(3C)	167,025.7	716.1	740.3	714.8	741.0	739.1	710.6	740.6	716.1	739.7	740.7	667.4	738.8	8,705.2	175,730.9
	濃縮汚泥引抜ポンプ	A-1	(2E)	27,915.1	65.9	70.1	22.0	0.0	158.1	200.0	12.3	232.1	44.2	203.3	83.7	210.1	1,301.8	29,216.9
		A-2	(2F)	29,661.9	214.9	198.1	199.8	211.0	32.2	13.0	203.3	0.9	221.7	152.1	191.9	72.1	1,711.0	31,372.9
	床排水ポンプ	A系	(2G)	2,789.2	20.0	16.4	17.8	18.3	14.7	17.5	16.5	16.4	21.2	24.8	16.3	23.9	223.8	3,013.0
	汚泥分離機	B-1	(3B)	16,071.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16,071.6
	し渣脱水機	B-1	(3H)	16,481.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16,481.5
	濃縮汚泥掻寄機	B-1	(4A)	116,050.4	717.1	741.2	716.0	741.5	739.8	708.7	741.3	716.9	740.7	741.3	668.1	739.4	8,712.0	124,762.4
		B-2	(4B)	87,699.9	716.0	740.4	714.7	741.3	739.1	710.5	737.9	715.4	739.2	740.1	667.4	734.9	8,696.9	96,396.8
	濃縮汚泥引抜ポンプ	B-1	(4D)	3.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.6
し渣破碎机	B-1	(5E)	47,848.7	415.2	423.0	408.4	415.0	414.8	400.8	414.4	406.0	433.2	446.9	399.8	436.2	5,013.7	52,862.4	
C系 重力濃縮設備 (F2-C-P1)	濃縮汚泥引抜ポンプ	C-1	(F1C)	1,431.7	3.2	72.6	8.4	90.4	3.3	75.5	2.9	84.1	6.2	67.8	8.2	72.6	495.2	1,926.9
		C-2	(F1D)	1,341.5	68.2	2.4	74.3	3.3	87.3	6.4	88.5	2.6	86.3	14.8	66.1	10.0	510.2	1,851.7
	床排水ポンプ	No.1	(R1E)	291.5	4.8	1.0	0.4	15.0	0.9	2.0	5.5	3.3	2.1	3.9	2.1	4.1	45.1	336.6
		No.2	(R1F)	287.0	4.6	1.0	0.4	31.3	0.9	2.0	5.5	3.3	2.0	3.9	2.1	3.9	60.9	347.9
A系 ベルト濃縮設備	A系汚泥スクリーン		(2A)	81,845.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	81,845.5
	余剰汚泥供給ポンプ	No.1	CRT	13,716.0	13.8	729.0	63.5	727.0	13.4	653.9	14.0	710.6	33.7	614.4	62.7	662.4	4,298.4	18,014.4
		No.2	CRT	12,252.2	706.2	14.0	656.2	16.0	730.6	37.6	729.0	9.4	706.1	129.6	602.3	78.5	4,415.5	16,667.7
	濃縮汚泥移送ポンプ	No.1	CRT	2,093.9	60.0	58.2	58.4	55.7	56.6	44.0	52.7	52.0	60.1	60.1	52.4	55.8	666.0	2,759.9
No.2		CRT	1,314.9	43.1	45.9	41.5	42.6	39.8	31.9	35.7	36.4	39.9	41.2	35.2	35.3	468.5	1,783.4	

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計
A系 ベルト濃縮設備	高分子凝集剤 定量供給機	No. 1	CRT	483.3	14.9	13.5	12.0	11.1	10.7	9.0	11.2	11.9	13.6	14.6	13.6	15.0	151.1	634.4
		No. 2	CRT	483.4	15.0	13.2	11.9	11.4	10.4	9.3	11.2	11.8	13.5	14.4	13.9	14.9	150.9	634.3
	高分子凝集剤 供給ポンプ	No. 1	CRT	12,987.5	13.8	729.1	63.4	727.4	13.5	653.9	13.8	710.6	37.7	614.4	62.7	659.1	4,299.4	17,286.9
		No. 2	CRT	13,683.2	706.2	13.9	656.3	15.6	730.5	37.6	729.2	9.4	706.1	129.6	602.3	81.8	4,418.5	18,101.7
	濃縮用空気圧縮機	No. 1	CRT	2,510.3	69.8	72.7	74.7	65.4	73.3	70.0	70.9	70.7	74.9	74.0	62.9	69.8	849.1	3,359.4
		No. 2	CRT	2,449.6	73.8	75.9	70.4	74.0	69.7	70.7	72.8	71.2	72.6	74.6	67.9	73.4	867.0	3,316.6
	補機室床排水ポンプ	A-1	(5B)	906.5	2.7	2.9	3.4	2.2	1.8	1.5	1.7	0.6	0.1	0.0	0.2	0.1	17.2	923.7
		A-2	(5C)	611.6	2.8	2.4	2.0	1.8	1.6	1.4	1.7	0.7	0.1	0.0	0.1	0.1	14.7	626.3
B系 加圧浮上 濃縮設備 (F-C-J1)	余剰汚泥供給ポンプ	B-1	(F5A)	82,146.2	720.2	744.5	436.3	704.3	743.2	332.9	682.9	551.0	238.6	336.7	656.7	739.4	6,886.7	89,032.9
		B-2	(F6A)	44,398.1	291.6	0.0	283.0	27.4	0.0	641.5	619.6	507.0	743.6	407.6	0.0	332.5	3,853.8	48,251.9
		B-3	(F7A)	74,659.3	428.6	644.4	719.3	744.3	743.2	409.9	0.0	0.0	504.1	744.3	661.2	264.8	5,864.1	80,523.4
	加圧水循環ポンプ	B-1	(R2C)	81,373.0	720.2	744.6	436.4	680.1	652.7	126.2	651.9	345.5	237.5	336.7	665.5	739.3	6,336.6	87,709.6
		B-2	(R3C)	45,801.0	291.8	0.0	282.8	51.0	0.0	641.1	619.7	507.5	743.6	407.6	0.0	332.5	3,877.6	49,678.6
		B-3	(R4C)	74,070.1	428.4	644.4	719.3	744.9	743.2	410.0	0.0	0.0	504.8	744.3	661.3	264.8	5,865.4	79,935.5
	濃縮用空気圧縮機	B-1	(F3G)	8,665.8	3.2	76.4	7.7	76.4	2.7	80.5	2.6	53.5	5.2	432.7	75.2	650.2	1,466.3	10,132.1
		B-2	(F3H)	9,823.3	390.8	27.3	581.0	29.0	716.9	51.0	594.5	21.8	693.0	142.6	592.4	89.1	3,929.4	13,752.7
	沈殿汚泥掻寄機	B-1	(F4D)	115,556.3	720.2	744.5	719.5	744.9	743.2	713.9	744.2	718.4	743.5	744.3	670.4	740.3	8,747.3	124,303.6
		B-2	(F4F)	91,153.1	720.2	744.5	719.5	744.9	743.2	713.9	744.2	718.4	743.5	744.3	670.4	740.3	8,747.3	99,900.4
	フロス移送ポンプ	B-1	(F3B)	7,623.6	4.4	87.4	9.7	96.2	4.2	98.2	4.9	65.4	7.1	102.8	11.2	83.2	574.7	8,198.3
		B-2	(F3C)	7,828.6	91.6	4.4	99.2	5.7	116.0	7.1	77.8	3.5	119.0	25.5	95.6	16.5	661.9	8,490.5
	A系汚泥スクリーン		(F3E)	7,890.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7,890.8
	沈殿汚泥引抜ポンプ		(F3F)	46.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	46.2
	補機室床排水ポンプ	B-1	(F2E)	532.7	0.1	1.9	0.2	3.2	0.1	3.3	0.1	7.2	0.8	8.7	1.6	14.8	42.0	574.7
		B-2	(F2F)	528.0	10.7	0.7	15.6	0.9	19.6	1.3	15.9	16.5	16.8	3.4	14.5	2.1	118.0	646.0
消化タンク設備 (L-C-Q1)	消化タンク攪拌機	A-1	(F3C)	194,305.0	715.9	742.9	698.1	743.5	734.9	690.5	743.2	718.7	406.5	0.0	169.9	739.3	7,103.4	201,408.4
		A-2	(F3D)	40,047.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	40,047.5
		A-3	(F3E)	148,060.8	709.7	743.0	694.2	743.3	734.9	690.7	743.1	718.7	743.7	730.2	665.7	738.9	8,656.1	156,716.9
		A-4	(F4G)	105,749.3	715.4	742.9	681.7	744.5	737.0	690.7	743.2	719.8	743.7	733.2	666.0	738.6	8,656.7	114,406.0

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計	
消化タンク設備 (L-C-Q1)	消化管廊床排水ポンプ	No-1	(F2E)	47.0	0.1	0.0	0.1	0.0	0.0	8.1	0.4	2.0	4.5	9.1	26.5	28.5	79.3	126.3	
		No-2	(F2F)	163.9	0.0	6.1	0.0	0.2	0.1	5.6	0.5	0.1	0.4	0.1	0.1	0.3	13.5	177.4	
	雑用水加圧ポンプ	No-1	(F3B)	493.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.3	0.0	0.0	2.3	495.7	
	循環汚泥ポンプ	A-1	(R3C)	137,904.6	718.5	506.8	233.3	742.2	728.8	586.3	144.5	716.7	406.4	0.3	167.5	736.6	5,687.9	143,592.5	
		A-2	(R3D)	2,978.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,978.2	
		A-3	(R2C)	113,789.4	718.5	742.9	454.2	287.4	728.8	683.3	596.6	95.4	741.4	521.1	287.7	168.2	6,025.5	119,814.9	
		A-4	(R2D)	108,548.3	406.3	236.1	687.5	743.1	631.8	97.0	741.1	716.7	718.3	452.5	379.8	735.9	6,546.1	115,094.4	
A-5	(F3C)	82,968.3	312.0	742.6	687.9	454.7	97.0	683.2	741.1	622.2	23.1	495.1	668.1	568.5	6,095.5	89,063.8			
A系ボイラー設備 (L-C-R1)	重油移送ポンプ	No-1	(F3G)	12.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	12.7	
		No-2	(F3H)	12.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	12.5	
	消化用空気圧縮機	No-1	(F2C)	3,265.2	1.1	29.9	3.3	28.7	1.2	28.4	1.2	27.3	2.0	32.2	3.7	28.1	187.1	3,452.3	
		No-2	(F2D)	3,161.6	29.8	1.2	26.1	1.1	28.3	2.1	59.5	1.0	31.8	8.0	29.1	3.9	221.9	3,383.5	
	床排水ポンプ		(F2E)	10,367.8	0.7	1.0	1.4	0.6	0.4	8.3	0.9	1.0	0.2	1.2	1.4	0.6	17.7	10,385.5	
	管廊床排水ポンプ		(F2F)	117.8	0.0	0.3	0.2	0.1	0.0	6.4	0.7	1.6	1.7	0.3	0.6	0.4	12.3	130.1	
	A-1 温水ボイラー制御盤	抽気時間		100.9	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	100.9
		オイル燃焼時間		1,166.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,166.8
		ガス燃焼時間		152,798.5	718.2	740.2	644.7	559.1	400.7	490.6	617.0	716.2	713.7	642.1	433.5	0.0	6,676.0	159,474.5	
	A-2 温水ボイラー制御盤	抽気時間		11.5	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.0	0.0	0.1	0.6	12.1
		オイル燃焼時間		6.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.1
		ガス燃焼時間		44,336.5	397.0	285.9	251.5	258.9	155.9	178.9	233.7	324.8	530.2	585.6	557.0	734.1	4,493.5	48,830.0	
	余剰ガス 燃焼装置	電気室電源盤内	燃焼時間	46,362.1	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.6	0.3	5.8	0.3	0.3	9.3	46,371.4
ボイラー設備盤 R22A内取付		ガス燃焼用送風機	47,933.0	0.7	0.9	0.5	0.5	0.5	0.5	0.5	0.6	0.7	0.7	6.7	0.6	0.5	13.4	47,946.4	
		ガス昇圧	No-1-1	23,367.9	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.2	0.2	5.9	0.2	0.2	8.0	23,375.9	
		ブロフ	No-1-2	23,543.8	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.2	0.2	0.2	0.2	2.5	23,546.3	
脱水機設備 (H-C-K1)	脱水用空気圧縮機	A-1	(2A)	41,964.4	277.0	11.2	257.0	305.3	13.1	263.6	306.4	6.7	363.4	384.7	42.5	339.2	2,570.1	44,534.5	
		A-2	(2B)	38,725.8	266.9	282.6	32.2	293.8	318.4	21.1	295.6	298.6	23.4	328.9	352.7	45.8	2,560.0	41,285.8	
		A-3	(10C)	36,403.5	10.1	271.4	289.2	11.5	305.6	284.5	10.9	290.0	386.8	55.9	310.4	382.8	2,609.1	39,012.6	
		B-1	(F5E)	646.3	6.2	6.1	6.1	6.1	6.0	6.0	6.6	6.5	6.6	6.1	5.5	6.1	73.9	720.2	
		B-2	(F5F)	797.7	6.2	6.1	6.1	6.1	6.0	6.0	6.6	6.5	6.6	6.1	5.5	6.1	73.9	871.6	

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計	
脱水機設備 (H-C-K1)	補機室床排水ポンプ	A-1	(2E)	204.7	0.2	0.2	0.4	0.5	0.3	1.0	0.4	0.3	0.2	0.3	0.3	0.4	4.5	209.2	
		A-2	(2F)	170.4	0.2	0.1	0.3	15.9	0.3	0.6	0.4	0.3	0.2	0.3	0.3	0.3	0.3	19.2	189.6
		A-3	(2G)	1,963.7	46.6	77.8	69.8	78.1	74.6	57.4	54.9	54.6	51.3	47.7	50.7	56.3	719.8	2,683.5	
		B-1	(R5B)	46.6	0.0	0.4	0.0	0.8	0.0	0.5	0.1	0.4	0.1	0.2	0.1	0.4	3.0	49.6	
		B-2	(R5C)	45.5	0.8	0.0	0.5	0.0	0.7	0.1	0.5	0.1	0.3	0.1	0.2	0.3	3.6	49.1	
	ろ布洗浄ポンプ	A-1	(3C)	49,112.3	314.9	7.9	274.1	327.4	7.5	274.7	317.8	2.5	370.1	358.1	31.1	301.9	2,588.0	51,700.3	
		A-2	(3D)	47,719.7	304.3	310.0	41.7	309.8	334.9	14.9	305.4	327.3	15.8	331.5	342.5	34.5	2,672.6	50,392.3	
		A-3	(10F)	38,443.1	6.9	299.5	313.6	15.7	323.1	291.8	6.9	304.4	438.0	55.7	302.3	341.9	2,699.8	41,142.9	
		B-1	(R4C)	5,480.9	0.0	2.8	0.0	9.8	9.7	9.8	0.0	8.6	0.0	3.6	1.7	4.1	50.1	5,531.0	
		B-2	(R4D)	6,272.9	7.5	0.0	8.7	0.0	0.0	0.0	9.8	0.0	9.0	6.6	5.1	0.0	46.7	6,319.6	
	ろ布駆動装置	A-1	(5B)	68,972.4	309.0	307.0	312.2	321.2	329.7	273.1	311.8	296.2	389.3	385.1	341.0	333.4	3,909.0	72,881.4	
		A-2	(6B)	61,062.2	309.0	307.9	309.8	326.1	334.9	289.4	297.1	298.1	396.3	392.1	340.8	331.8	3,933.3	64,995.5	
		A-3	(7C)	53,608.7	311.8	307.0	311.2	326.2	330.2	290.0	312.9	293.4	422.6	390.8	341.0	336.2	3,973.3	57,582.0	
		A-4	(8C)	55,191.1	309.5	307.5	308.4	297.7	330.1	289.7	307.1	296.1	30.9	0.0	168.6	333.7	2,979.3	58,170.4	
		A-5	(R2F)	39,293.3	313.2	308.1	311.5	320.6	324.0	290.5	314.2	311.0	387.9	354.5	309.1	337.5	3,882.1	43,175.4	
		A-6	(F2D)	33,862.0	307.2	291.9	308.4	322.4	327.9	287.8	308.4	303.2	386.5	350.8	318.8	322.6	3,835.9	37,697.9	
		B-1	(F4A)	11,632.0	7.3	2.8	8.7	9.8	9.7	9.8	9.8	8.6	9.0	10.1	6.8	4.4	96.8	11,728.8	
	脱水汚泥供給ポンプ	A-1	(5E)	60,404.9	279.8	278.7	279.9	288.0	301.5	244.8	283.3	267.5	355.2	354.9	310.9	298.6	3,543.1	63,948.0	
		A-2	(6E)	53,786.4	280.6	278.7	280.0	295.6	298.9	259.8	264.1	267.5	357.9	360.2	314.2	300.7	3,558.2	57,344.6	
		A-3	(7D)	47,190.9	242.4	278.8	282.6	295.7	298.3	261.3	283.4	263.8	357.3	360.1	314.2	304.1	3,542.0	50,732.9	
		A-4	(8D)	49,020.3	281.7	278.8	277.5	266.5	301.4	261.3	275.4	261.2	27.0	0.0	149.6	303.9	2,684.3	51,704.6	
		A-5	(R3A)	34,532.0	283.7	276.4	280.2	283.4	287.0	258.9	283.4	264.5	356.5	326.2	279.7	306.7	3,486.6	38,018.6	
		A-6	(R4A)	29,977.7	281.2	256.2	282.3	293.8	301.3	261.1	280.5	276.3	354.5	325.9	292.6	291.7	3,497.4	33,475.1	
		B-1	(R7A)	10,096.4	6.7	2.0	7.9	8.9	8.9	8.9	8.9	7.8	8.1	9.3	6.0	3.2	86.6	10,183.0	
	凝集剤注入ポンプ	A-1	(5F)	60,410.3	279.8	307.0	279.9	288.0	301.5	244.8	283.3	267.5	355.2	354.9	310.9	298.6	3,571.4	63,981.7	
		A-2	(6F)	53,700.6	280.6	307.9	280.0	295.6	298.9	259.8	264.1	267.5	357.9	360.2	314.2	300.7	3,587.4	57,288.0	
		A-3	(7E)	47,192.6	282.4	307.0	282.6	295.7	298.3	261.3	283.4	263.8	357.3	360.1	314.2	304.1	3,610.2	50,802.8	
		A-4	(8E)	49,023.0	281.7	307.5	277.5	266.5	301.4	261.3	275.4	261.2	27.0	0.0	149.6	303.9	2,713.0	51,736.0	

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計	
脱水機設備 (H-C-K1)	凝集剤注入ポンプ	A-5 (F3A)		34,559.1	283.6	308.1	280.2	283.4	287.0	258.9	283.4	264.5	356.5	326.2	279.7	306.7	3,518.2	38,077.3	
		A-6 (F4A)		29,977.4	281.2	291.9	282.3	293.8	301.3	261.1	280.5	276.3	354.5	325.9	292.6	291.7	3,533.1	33,510.5	
		B-1 (F7A)		10,113.2	6.7	2.8	7.9	8.9	8.9	8.9	8.9	7.8	8.1	9.3	6.0	3.2	87.4	10,200.6	
	高架水槽揚水ポンプ	A-1 (4A)		3,311.0	18.2	0.7	0.0	18.7	0.6	0.0	18.4	0.5	0.0	85.1	2.5	22.7	167.4	3,478.4	
		A-2 (5A)		3,313.1	0.0	20.0	2.1	0.0	17.6	1.2	0.0	20.8	1.5	0.0	18.6	2.8	84.6	3,397.7	
		A-3 (6A)		3,509.7	0.6	0.0	17.0	0.8	0.0	16.8	0.6	0.0	21.7	4.3	0.0	0.1	61.9	3,571.6	
	高圧ろ布洗ポンプ	B-1 (R5D)		8,006.5	0.4	3.6	1.3	5.6	5.6	33.8	0.0	29.1	0.0	33.8	0.0	32.2	145.4	8,151.9	
		B-2 (R6E)		7,831.2	0.0	0.0	14.8	0.0	29.5	0.0	37.2	0.1	31.4	0.0	33.5	0.4	146.9	7,978.1	
	ケーキ圧送ポンプ	B-1 (F2A)		3,014.8	2.0	0.2	2.1	2.5	2.2	2.3	2.3	1.8	2.2	2.6	1.4	0.8	22.4	3,037.2	
	第2ポンプ棟 放流ポンプ設備 (E-C-O1)	放流ポンプ (高圧)	No.1 (K-H-01)		713.4	0.2	0.3	0.2	0.1	0.1	29.8	0.2	0.2	0.1	0.2	0.5	0.8	32.7	746.1
No.2 (K-H-02)				220.5	0.2	0.3	0.2	0.1	0.1	10.9	0.1	0.2	0.1	0.2	0.1	0.2	12.7	233.2	
No.3 (K-H-03)				98.7	0.2	0.3	0.2	0.1	0.1	18.2	0.1	0.2	0.1	0.1	0.2	0.1	19.9	118.6	
No.4 (K-H-04)				74.4	0.2	0.3	0.2	0.1	0.1	22.2	0.1	0.2	0.1	0.1	0.2	0.1	23.9	98.3	
ポンプ室床排水ポンプ		No.1 (2E)		13.5	0.0	0.1	0.0	0.0	0.0	0.4	0.1	0.1	0.1	0.1	0.1	0.1	1.1	14.6	
		No.2 (3E)		15.5	0.0	0.1	0.0	0.0	0.0	0.4	0.1	0.1	0.1	0.1	0.1	0.0	1.0	16.5	
放流ポンプ 冷却水ポンプ		No.1 (2F)		254.3	0.8	0.0	0.0	0.5	0.0	30.7	0.6	0.9	0.0	0.4	1.1	0.1	35.1	289.4	
		No.2 (3F)		391.1	0.0	1.1	0.8	0.8	0.6	17.9	0.0	0.0	0.7	0.3	0.0	1.3	23.5	414.6	
		予備 (2G)		0.0	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	0.0
		予備 (3G)		0.0	-	-	-	-	-	-	-	-	-	-	-	-	-	0.0	0.0
放流水計測室 (E-C-H1)	放流ポンプ (既設)	No.1 (4A)		449.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	449.6	
		No.2 (4B)		536.8	0.2	0.2	0.1	0.1	0.1	8.5	0.2	0.1	0.1	0.1	0.1	0.1	9.9	546.7	
		No.3 (4C)		228.2	0.2	0.1	0.2	0.1	0.1	5.3	0.1	0.1	0.1	0.1	0.1	0.1	6.6	234.8	
A系 急速ろ過設備 (M-C-S1)	汚泥処理送水ポンプ	No.1 (R6A)		28,399.8	249.0	269.4	1.6	1.2	1.1	8.7	164.1	340.0	459.6	325.2	1.8	104.2	1,925.9	30,325.7	
		No.2 (R6B)		20,055.3	72.8	243.2	481.8	515.6	540.7	297.9	18.0	32.0	167.3	506.6	418.8	395.2	3,689.9	23,745.2	
		No.3 (R6C)		22,177.6	0.8	69.2	228.5	254.0	253.7	352.4	308.8	4.2	15.3	199.5	264.7	164.2	2,115.3	24,292.9	
		No.4 (R3A)		6,577.7	237.3	1.9	6.5	4.6	4.2	121.8	454.9	620.9	435.4	21.9	39.6	5.4	1,954.4	8,532.1	
	逆洗排水ポンプ	A-1 (R4D)		25,357.4	15.5	146.6	236.5	42.6	203.8	214.5	60.5	204.3	254.3	42.4	36.1	393.1	1,850.2	27,207.6	
		A-2 (R5D)		23,417.3	212.5	13.1	183.4	218.2	31.9	198.7	221.1	37.3	208.9	172.9	164.4	65.9	1,728.3	25,145.6	
		A-3 (R6D)		20,490.5	181.2	253.4	60.6	231.7	243.0	26.9	232.0	260.2	33.9	246.1	204.2	0.3	1,973.5	22,464.0	

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計	
A系 急速ろ過設備 (M-C-S1)	ポンプ室床排水ポンプ	No-1	(R3B)	9.8	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.1	0.9	1.3	11.1	
		No-2	(R3C)	6.1	0.1	0.0	0.1	0.0	0.0	0.0	0.2	0.0	0.0	0.1	0.1	0.1	0.0	0.7	6.8
	急ろ管廊床排水ポンプ	A-1	(R3D)	5.6	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.7	6.3
		A-2	(R3E)	100.8	0.2	0.3	0.2	0.2	0.1	0.3	0.3	0.3	0.3	0.4	0.4	0.3	0.4	3.4	104.2
		A-3	(R11B)	10.5	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.0	0.0	0.0	0.4	10.9
		A-4	(R11C)	8.4	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.0	0.0	0.0	0.4	8.8
	バルブピット床排水ポンプ	A-1	(R3F)	586.1	2.3	1.7	0.9	0.8	0.6	2.5	2.5	4.4	4.1	3.2	3.1	3.1	29.2	615.3	
	連絡管廊床排水ポンプ	No-1	(R3G)	1,169.0	5.8	5.9	5.5	5.4	5.0	9.9	4.9	6.0	6.1	4.6	5.5	6.1	70.7	1,239.7	
		No-2	(R3H)	9.7	0.0	0.1	0.0	0.1	0.0	6.0	0.1	0.3	0.1	0.1	0.1	0.1	0.1	7.0	16.7
	空洗ブロワ	A-1	(F5B)	1,779.2	15.0	8.8	16.6	11.4	17.6	10.6	15.9	7.9	17.6	14.1	12.4	17.5	165.4	1,944.6	
		A-2	(F6B)	1,882.5	11.4	18.4	10.7	15.4	9.6	14.9	11.3	18.4	9.6	12.2	11.3	9.7	152.9	2,035.4	
	揚水ポンプ	No-3	(M-H-M4)	4,216.3	136.6	151.8	133.4	174.3	178.6	160.9	149.0	144.7	202.9	223.6	202.1	197.5	2,055.4	6,271.7	
		No-4	(M-H-M3)	34.8	0.0	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	1.3	36.1
		No-5	(M-H-M2)	37,349.2	259.5	265.1	261.9	249.5	241.1	226.1	255.9	277.1	218.0	221.7	380.0	423.8	3,279.7	40,628.9	
No-6		(M-H-M1)	39,906.3	290.5	285.9	291.2	255.2	244.3	248.5	324.4	276.6	262.2	235.4	33.2	59.3	2,806.7	42,713.0		
C系 最初沈殿池設備 (C2-C-D1)	汚泥掻寄機	C-1	(F3C)	14,046.2	7.4	4.8	0.0	0.0	0.0	3.2	4.6	1.1	5.5	0.0	0.2	0.0	26.8	14,073.0	
		C-2	(F3D)	114,491.5	198.5	744.1	719.6	744.3	743.6	717.8	743.8	720.1	743.7	489.8	0.0	3.2	6,568.5	121,060.0	
		C-3	(F3E)	39,009.6	534.2	16.2	20.1	21.2	15.7	8.7	0.0	0.0	0.0	263.5	667.1	741.1	2,287.8	41,297.4	
		C-4	(F4C)	26,354.8	12.0	21.2	20.1	21.0	15.7	7.7	0.0	0.0	1.5	0.0	0.0	2.7	101.9	26,456.7	
		C-5	(F4D)	78,434.5	534.2	0.0	1.2	0.0	0.0	2.8	11.5	1.1	15.4	264.9	667.1	741.1	2,239.3	80,673.8	
		C-6	(F4E)	24,766.3	197.0	744.1	719.6	744.3	743.6	717.8	743.8	720.1	738.1	486.9	1.3	0.0	6,556.6	31,322.9	
	汚泥引抜ポンプ	C-1	(F2C)	37,818.8	16.2	401.8	44.3	390.8	15.3	367.1	15.3	384.5	31.9	353.1	44.3	371.8	2,436.4	40,255.2	
		C-2	(F2D)	40,755.0	393.0	14.6	358.1	17.2	393.4	29.2	392.6	15.3	395.0	87.1	348.9	58.9	2,503.3	43,258.3	
	スカム移送ポンプ	C-1	(R4A)	3,116.6	1.2	2.0	1.4	1.2	1.8	0.0	0.2	2.9	1.7	3.0	2.3	2.7	20.4	3,137.0	
		C-2	(R4B)	3,252.1	0.8	0.0	0.1	1.1	0.0	1.5	2.0	0.2	0.1	1.3	0.2	0.0	7.3	3,259.4	
C系 最終沈殿池設備 (C2-C-E1)	汚泥掻寄機	C-1	(F3C)	117,443.3	720.7	744.1	719.6	744.4	743.6	720.5	743.8	720.1	743.7	744.2	671.6	743.4	8,759.7	126,203.0	
		C-2	(F3D)	125,210.6	720.7	744.1	719.6	744.4	743.6	720.5	743.8	720.1	743.7	744.2	671.6	743.4	8,759.7	133,970.3	
		C-3	(F3E)	117,439.6	720.7	744.1	719.6	744.4	743.6	720.5	743.8	720.1	743.7	744.2	671.6	743.4	8,759.7	126,199.3	
		C-4	(F4C)	97,753.2	720.7	744.1	719.6	744.4	743.6	720.5	743.8	720.1	738.1	744.2	671.6	743.4	8,754.1	106,507.3	
		C-5	(F4D)	98,612.2	720.7	744.1	719.6	744.4	743.6	720.5	734.3	720.1	738.1	744.2	671.6	743.4	8,744.6	107,356.8	
		C-6	(F4E)	98,512.4	720.7	744.1	719.6	744.4	743.6	720.5	743.8	720.1	738.1	744.2	671.6	743.4	8,754.1	107,266.5	

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計
C系 最終沈殿池設備 (C2-C-E1)	返送汚泥ポンプ	C-1	(F5A)	79,496.1	720.6	28.1	639.8	744.3	46.1	675.7	743.8	40.5	691.2	743.9	75.7	647.5	5,797.2	85,293.3
		C-2	(F6A)	77,210.1	691.1	744.1	136.0	715.4	743.3	101.4	715.6	719.7	52.5	599.3	671.4	109.9	5,999.7	83,209.8
		C-3	(F7A)	76,552.0	29.6	716.0	719.4	40.2	714.6	720.4	61.5	692.4	743.7	151.5	596.0	743.3	5,928.6	82,480.6
		C-4	(R5A)	65,198.8	29.6	716.5	715.7	40.3	714.6	720.4	61.4	692.7	743.3	151.6	595.9	743.2	5,925.2	71,124.0
		C-5	(R6A)	52,549.1	720.6	27.8	642.5	742.7	46.1	675.7	743.8	39.9	690.9	744.1	75.5	647.5	5,797.1	58,346.2
		C-6	(R7A)	61,147.2	691.1	743.9	135.6	713.8	743.4	101.4	715.6	720.1	52.5	599.6	671.5	109.9	5,998.4	67,145.6
	余剰汚泥ポンプ	C-1	(F3A)	30,127.4	11.3	218.8	29.6	332.7	12.4	295.8	13.7	260.2	66.2	80.8	0.5	271.4	1,593.4	31,720.8
		C-2	(F3B)	30,911.2	240.0	13.4	296.4	19.9	358.9	20.8	263.1	16.4	272.8	263.3	328.0	52.2	2,145.2	33,056.4
	スカム移送ポンプ	C-1	(F2B)	21,295.9	22.2	502.5	58.4	553.5	24.4	474.3	24.1	520.2	41.6	463.5	246.0	551.2	3,481.9	24,777.8
		C-2	(F2C)	22,575.2	491.4	15.4	464.6	23.4	514.4	39.3	524.7	23.0	556.7	122.9	284.4	0.0	3,060.2	25,635.4
	スカム分離機	C-1	(F2F)	46,659.4	508.8	511.3	516.1	569.2	531.8	501.8	543.3	541.3	593.5	582.4	524.4	545.3	6,469.2	53,128.6
	消泡水ポンプ	C系	(R4C)	47,372.6	171.9	171.4	141.5	167.7	162.5	154.5	169.6	175.7	173.9	178.8	151.5	166.3	1,985.3	49,357.9
		C/D系	(R4D)	34,555.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	34,555.9
		D系	(R4E)	11,439.2	171.9	171.5	141.5	167.7	167.6	154.6	169.7	175.7	175.2	180.6	154.1	166.7	1,996.8	13,436.0
C系 エアタン設備 (C2-C-C1)	C-1エアレータ	C-1-1	(F3B)	111,558.1	720.7	744.1	719.6	744.5	743.4	716.1	743.8	720.1	743.7	742.8	671.6	744.0	8,754.4	120,312.5
		C-1-2	(F3C)	111,982.4	720.7	744.1	719.6	744.5	743.4	716.2	743.8	720.1	743.7	744.2	671.6	744.0	8,755.9	120,738.3
		C-1-3	(F3D)	96,779.9	720.7	744.1	719.6	744.5	743.4	720.5	743.8	720.1	743.7	744.2	671.6	744.0	8,760.2	105,540.1
		C-1-4	(F3E)	100,062.7	720.7	744.1	719.6	744.5	743.4	720.5	743.8	720.1	743.7	742.8	671.6	744.0	8,758.8	108,821.5
		C-1-5	(F3F)	100,368.7	720.7	744.1	719.6	744.5	743.4	720.5	743.8	720.1	743.7	742.8	671.6	744.0	8,758.8	109,127.5
		C-1-6	(F3G)	86,559.9	720.7	744.1	719.6	744.5	743.4	720.5	743.8	720.1	743.7	744.2	671.6	744.0	8,760.2	95,320.1
		C-1-7	(F3H)	100,320.1	720.7	744.1	719.6	744.5	743.4	720.5	743.8	720.1	743.7	744.2	671.6	744.0	8,760.2	109,080.3
	C-2エアレータ	C-2-1	(F4B)	117,883.3	720.7	744.1	719.6	744.5	743.4	716.2	743.8	720.1	743.7	742.8	671.6	744.0	8,754.5	126,637.8
		C-2-2	(F4C)	115,068.1	720.7	744.1	719.6	744.5	743.4	716.2	743.8	720.1	743.7	744.2	671.6	744.0	8,755.9	123,824.0
		C-2-3	(F4D)	114,630.8	720.7	744.1	719.6	744.5	743.4	720.5	743.8	720.1	743.7	744.2	671.6	744.0	8,760.2	123,391.0
		C-2-4	(F4E)	112,327.6	720.7	744.1	719.6	744.5	743.4	720.5	743.8	720.1	743.7	742.8	671.6	744.0	8,758.8	121,086.4
		C-2-5	(F4F)	117,508.2	720.7	744.1	719.6	744.5	743.4	720.5	743.8	720.1	743.7	742.8	671.6	744.0	8,758.8	126,267.0
		C-2-6	(F4G)	117,525.1	720.7	744.1	719.6	744.5	743.4	720.5	743.8	720.1	743.7	744.2	671.6	744.0	8,760.2	126,285.3
		C-2-7	(F4H)	117,654.0	720.7	744.1	719.6	744.5	743.4	720.5	743.8	720.1	743.7	744.2	671.6	744.0	8,760.2	126,414.2

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計
C系 エアタン設備 (C2-C-C1)	C-3エアレータ	C-3-1	(R2B)	116,867.6	720.7	744.0	719.6	744.5	743.4	716.3	743.8	720.1	743.7	742.8	671.6	744.0	8,754.5	125,622.1
		C-3-2	(R2C)	116,591.5	720.7	744.0	719.6	744.5	743.4	716.3	743.8	720.1	743.7	744.2	671.6	744.0	8,755.9	125,347.4
		C-3-3	(R2D)	117,486.0	720.7	744.0	719.6	744.5	743.4	720.5	743.8	720.1	743.7	744.2	671.6	744.0	8,760.1	126,246.1
		C-3-4	(R2E)	117,593.1	720.7	744.0	719.6	744.5	743.4	720.5	743.8	720.1	743.7	742.8	671.6	744.0	8,758.7	126,351.8
		C-3-5	(R2F)	117,545.0	720.7	744.0	719.6	744.5	743.4	720.5	743.8	720.1	743.7	742.8	671.6	744.0	8,758.7	126,303.7
		C-3-6	(R2G)	114,273.3	720.7	744.0	719.6	744.5	743.4	720.5	743.8	720.1	743.7	744.2	671.6	744.0	8,760.1	123,033.4
		C-3-7	(R2H)	117,231.8	720.7	744.0	719.6	744.5	743.4	720.5	743.8	720.1	743.7	744.2	671.6	744.0	8,760.1	125,991.9
	C-4エアレータ	C-4-1	(R3B)	98,305.1	720.7	744.0	719.6	744.5	743.4	716.3	743.9	720.1	743.7	742.8	671.6	744.0	8,754.6	107,059.7
		C-4-2	(R3C)	98,192.7	720.7	744.0	719.6	744.5	743.4	716.3	743.9	720.1	743.7	743.3	671.6	744.0	8,755.1	106,947.8
		C-4-3	(R3D)	98,319.8	720.7	744.0	719.6	744.5	743.4	720.5	743.9	720.1	743.7	744.2	671.6	744.0	8,760.2	107,080.0
		C-4-4	(R3E)	98,283.7	720.7	744.0	719.6	744.5	743.4	720.5	743.9	720.1	743.7	742.8	671.6	744.0	8,758.8	107,042.5
		C-4-5	(R3F)	98,298.2	720.7	744.0	719.6	744.5	743.4	720.5	743.9	720.1	743.7	742.8	671.6	744.0	8,758.8	107,057.0
		C-4-6	(R3G)	98,315.6	720.7	744.0	719.6	744.5	743.4	720.5	743.9	720.1	743.7	744.2	671.6	744.0	8,760.2	107,075.8
		C-4-7	(R3H)	98,291.8	720.7	744.0	719.6	744.5	743.4	720.5	743.9	720.1	743.7	744.2	671.6	744.0	8,760.2	107,052.0
	C-5エアレータ	C-5-1	(F8B)	98,728.7	720.6	744.1	719.6	744.5	743.4	716.2	743.9	720.1	743.7	742.8	671.6	744.0	8,754.5	107,483.2
		C-5-2	(F8C)	98,724.7	720.6	744.1	719.6	744.5	743.4	716.2	743.9	720.1	743.7	744.2	671.6	743.0	8,754.9	107,479.6
		C-5-3	(F8D)	99,051.9	720.6	744.1	719.6	744.5	743.4	720.5	743.9	720.1	743.7	744.2	671.6	744.0	8,760.2	107,812.1
		C-5-4	(F8E)	98,740.5	720.6	744.1	719.6	744.5	743.4	720.5	743.9	720.1	743.7	742.8	671.6	744.0	8,758.8	107,499.3
		C-5-5	(F8F)	94,160.2	720.6	744.1	719.6	744.5	743.4	720.5	743.9	720.1	743.7	742.8	671.6	744.0	8,758.8	102,919.0
		C-5-6	(F8G)	99,045.0	720.6	744.1	719.6	744.5	743.4	720.5	743.9	720.1	743.7	744.2	671.6	744.0	8,760.2	107,805.2
		C-5-7	(F8H)	98,728.8	720.6	744.1	719.6	744.5	743.4	720.5	743.9	720.1	743.7	744.2	671.6	744.0	8,760.2	107,489.0
	C-6エアレータ	C-6-1	(R8B)	97,277.5	720.6	744.1	719.6	744.5	743.4	716.2	743.9	720.1	743.7	742.8	671.6	744.0	8,754.5	106,032.0
		C-6-2	(R8C)	98,087.0	720.6	744.1	719.6	744.5	743.4	716.2	743.9	720.1	743.7	744.2	671.6	744.0	8,755.9	106,842.9
		C-6-3	(R8D)	98,370.2	720.6	744.1	719.6	744.5	743.4	720.5	743.9	720.1	743.7	744.2	671.6	744.0	8,760.2	107,130.4
		C-6-4	(R8E)	98,093.9	720.6	744.1	719.6	744.5	743.4	720.5	743.9	720.1	743.7	742.0	671.6	744.0	8,758.0	106,851.9
		C-6-5	(R8F)	98,424.1	720.6	744.1	719.6	744.5	743.4	720.5	743.9	720.1	743.7	527.6	671.6	0.0	7,799.6	106,223.7
		C-6-6	(R8G)	98,076.0	720.6	744.1	719.6	744.5	743.4	720.5	743.9	720.1	743.7	744.3	671.6	744.0	8,760.3	106,836.3
		C-6-7	(R8H)	98,423.7	720.6	744.1	719.6	744.5	743.4	720.5	743.9	720.1	743.7	620.5	671.6	744.0	8,636.5	107,060.2



区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計	
C系 エアタン設備 (C2-C-C1)	送風機	No.7	(C2-H-C1)	47,984.5	338.5	560.2	453.5	709.3	522.2	327.4	671.5	719.8	452.0	744.2	671.9	656.3	6,826.8	54,811.3	
	冷却水ポンプ	No.1	(F3G)	25,172.9	220.2	10.4	316.1	66.7	386.9	79.9	0.1	0.0	328.9	744.2	168.4	505.4	2,827.2	28,000.1	
		No.2	(F3H)	23,572.7	124.1	550.5	144.5	644.3	143.2	254.5	672.1	720.1	123.9	0.1	503.5	153.1	4,033.9	27,606.6	
第1ポンプ棟	シャワー水	No.1	(7A)	259.2	1.1	3.0	3.9	2.4	1.3	0.5	0.0	3.2	0.0	1.7	0.0	2.7	19.8	279.0	
		No.2	(7B)	907.9	0.0	0.0	0.7	0.0	2.1	0.0	2.4	3.4	0.5	0.0	0.7	0.0	9.8	917.7	
B系 消化タンク設備	消化タンク攪拌機	B-1		63,997.1	704.2	678.6	590.8	571.1	562.1	551.0	597.4	0.7	706.9	721.2	661.7	660.3	7,006.0	71,003.1	
		B-2		2,740.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,740.2
	管廊床排水ポンプ			2.9	0.1	0.0	0.0	0.0	0.0	5.5	0.2	0.1	6.6	0.0	2.0	0.1	14.6	17.5	
	エレベーター棟床排水ポンプ			24.3	0.2	0.0	0.1	0.1	0.1	0.0	1.5	0.1	5.7	0.1	1.0	0.2	9.1	33.4	
	雑用水加圧ポンプ			66,896.9	704.2	678.9	591.4	571.8	562.9	551.5	598.0	601.3	707.0	721.3	661.7	660.5	7,610.5	74,507.4	
	循環汚泥ポンプ	B-1			36,370.4	407.2	236.3	458.3	287.3	631.2	95.9	550.9	95.0	448.0	0.1	0.2	0.1	3,210.5	39,580.9
		B-2			240.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	240.3
		B-4			30,497.9	312.0	507.2	230.2	454.7	96.8	587.4	190.4	624.1	241.5	741.7	644.5	737.0	5,367.5	35,865.4
消化用空気圧縮機	No.1			1,339.1	1.0	26.1	2.8	27.3	1.0	25.1	1.1	29.3	2.1	21.6	2.8	24.3	164.5	1,503.6	
	No.2			2,067.2	24.4	1.1	23.5	1.1	26.9	1.9	32.5	1.0	25.6	5.2	21.3	3.3	167.8	2,235.0	
B系 ボイラー設備	管廊床排水ポンプ			41.7	0.3	0.3	0.2	0.4	0.3	9.0	2.9	0.4	3.9	4.7	2.8	0.4	25.6	67.3	
	B系 温水ボイラー制御盤	オイル燃焼時間		2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.0	
		ガス燃焼時間			42,702.6	428.0	387.3	306.9	274.8	219.6	225.0	280.9	372.4	506.9	615.3	518.1	482.2	4,617.4	47,320.0
汚泥乾燥設備 (N-C-T)	空気圧縮機	No.1	(F3A)	23,991.4	241.2	356.9	152.3	310.8	123.3	2.7	2.1	0.0	2.0	276.5	475.4	328.9	2,272.1	26,263.5	
		No.2	(F3B)	24,067.9	468.8	410.7	533.5	431.8	613.8	689.7	658.5	588.2	598.2	360.0	0.7	205.1	5,559.0	29,626.9	
	砂ろ過水ポンプ	No.1	(R3B)	30,941.4	245.6	332.7	147.3	308.5	336.5	140.6	481.8	189.2	440.8	355.1	213.3	260.2	3,451.6	34,393.0	
		No.2	(R3C)	29,467.8	453.3	322.7	571.8	365.0	403.9	530.1	213.4	530.0	259.9	175.0	358.8	479.1	4,663.0	34,130.8	
	砂ろ過水送水ポンプ	No.1	(R3F)	22,651.2	179.0	238.6	524.1	291.1	299.7	394.3	0.0	136.4	325.2	265.5	157.9	192.5	3,004.3	25,655.5	
		No.2	(R3G)	22,181.6	328.2	236.5	2.0	219.6	240.8	101.6	507.4	391.0	197.3	134.6	268.4	363.2	2,990.6	25,172.2	
	脱臭ファン		(R4G)	9,924.0	51.4	118.3	33.0	95.3	35.1	81.1	76.7	30.2	73.5	198.1	76.4	62.4	931.5	10,855.5	
汚泥乾燥設備 (N-C-U1)	1系排ガスファン		(R1A)	60,397.4	698.9	655.2	719.1	673.4	740.5	670.6	690.9	719.8	700.8	531.2	572.1	739.3	8,111.8	68,509.2	
	1系スクラバ循環ポンプ	No.1	(R2B)	29,051.1	623.7	193.6	548.5	534.1	50.4	522.2	74.6	548.3	247.9	404.4	70.2	732.6	4,550.5	33,601.6	
		No.2	(R2C)	31,401.0	75.2	461.6	170.6	139.2	690.1	148.4	620.6	171.4	452.8	125.9	502.0	306.7	3,864.5	35,265.5	

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計	
汚泥乾燥設備 (N-C-U1)	1系熱風炉用ブロワ	No. 1	(R2E)	33,716.2	124.9	355.4	315.5	619.2	219.2	596.8	98.0	525.6	316.3	405.6	435.0	500.3	4,511.8	38,228.0	
		No. 2	(R2F)	34,889.5	596.0	388.1	404.1	125.1	522.4	123.8	646.1	194.2	427.0	339.0	239.5	240.8	4,246.1	39,135.6	
	1系冷却塔循環ポンプ	No. 1-1	(R1E)	33,381.9	0.0	501.5	719.6	44.9	0.0	454.3	716.5	0.0	439.6	573.1	0.0	598.1	4,047.6	37,429.5	
		No. 1-2	(R1F)	33,491.0	720.9	236.1	0.0	693.4	737.2	261.2	21.9	719.8	212.5	165.9	674.5	137.9	4,581.3	38,072.3	
		No. 2-1	(R1G)	32,880.0	708.7	308.1	69.5	725.5	164.2	430.2	741.8	0.0	597.0	549.2	0.0	573.9	4,868.1	37,748.1	
		No. 2-2	(R1H)	34,325.0	0.0	364.3	624.5	0.0	572.0	285.2	0.1	716.3	140.6	190.1	674.5	161.6	3,729.2	38,054.2	
	脱水汚泥移送ポンプ	No. 1	CRT	9,056.1	131.8	124.1	137.2	132.0	143.8	135.0	128.9	137.1	142.7	77.1	119.4	158.0	1,567.1	10,623.2	
		No. 2	CRT	11,289.3	129.7	117.2	126.1	119.2	127.8	109.2	123.8	131.5	120.3	113.7	107.0	140.5	1,466.0	12,755.3	
D系 最初沈殿池設備 (C2-C-D2)	汚泥掻寄機	D-1	(F2C)	1,321.0	11.9	22.8	14.0	20.8	15.8	146.9	747.4	716.6	743.7	701.6	0.0	1.1	3,142.6	4,463.6	
		D-2	(F2D)	43,086.4	720.7	744.1	719.2	744.5	743.4	577.7	14.6	7.7	8.8	51.0	667.1	740.6	5,739.4	48,825.8	
		D-3	(F2E)	9,952.7	720.7	744.1	719.2	744.5	743.4	717.8	747.4	716.6	743.7	701.6	0.0	7.6	7,306.6	17,259.3	
		D-4	(F3C)	2,237.5	14.1	21.3	19.9	20.7	15.7	6.5	0.0	0.0	0.0	47.1	663.2	740.6	1,549.1	3,786.6	
		D-5	(F3D)	42,984.4	720.7	744.1	719.2	744.5	743.4	717.8	747.4	716.6	738.7	701.7	12.4	7.5	7,314.0	50,298.4	
		D-6	(F3E)	1,377.9	11.8	5.0	0.0	0.0	1.0	2.2	14.7	7.7	16.7	49.9	663.5	740.6	1,513.1	2,891.0	
	汚泥引抜ポンプ	D-1	(R2H)	11,441.2	14.5	369.2	38.8	368.9	13.9	27.4	14.5	357.1	356.2	62.0	0.0	331.0	1,953.5	13,394.7	
		D-2	(R3H)	12,540.5	356.1	13.1	331.5	14.8	370.1	346.4	370.6	12.5	27.2	322.5	346.5	51.7	2,563.0	15,103.5	
	D系 エアタン設備 (C2-C-C2)	D-1エアレータ	D-1-1	(F2A)	43,400.0	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	742.8	672.2	743.4	8,754.7	52,154.7
			D-1-2	(F2B)	43,427.2	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	742.8	672.2	743.4	8,754.7	52,181.9
D-1-3			(F2C)	43,015.7	720.7	744.1	719.6	744.5	743.4	716.4	737.5	716.5	743.7	740.9	672.2	743.4	8,742.9	51,758.6	
D-2エアレータ		D-2-1	(F2D)	43,425.4	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	742.8	672.2	743.4	8,754.7	52,180.1	
		D-2-2	(F2E)	43,430.1	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	742.8	672.2	743.4	8,754.7	52,184.8	
		D-2-3	(F2F)	43,424.3	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	742.8	672.2	737.5	8,748.8	52,173.1	
D-3エアレータ		D-3-1	(F3A)	43,426.8	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	742.8	672.2	743.4	8,754.7	52,181.5	
		D-3-2	(F3B)	43,425.6	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	742.8	672.2	743.4	8,754.7	52,180.3	
		D-3-3	(F3C)	43,401.8	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	742.8	672.2	743.4	8,754.7	52,156.5	
D-4エアレータ		D-4-1	(F3D)	41,710.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	118.7	742.8	672.2	743.4	2,277.1	43,987.3	
		D-4-2	(F3E)	43,104.2	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	360.1	672.2	743.4	8,372.0	51,476.2	
		D-4-3	(F3F)	43,104.5	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	553.6	672.2	743.4	8,565.5	51,670.0	

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計
D系 エアタン設備 (C2-C-C2)	D-5エアレータ	D-5-1	(F4A)	43,107.1	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	363.9	672.2	743.4	8,375.8	51,482.9
		D-5-2	(F4B)	43,106.6	720.7	744.1	719.6	744.5	743.4	716.4	707.3	716.5	358.5	742.8	672.2	743.4	8,329.4	51,436.0
		D-5-3	(F4C)	43,107.3	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	742.8	672.2	743.4	8,754.7	51,862.0
	D-6エアレータ	D-6-1	(F4D)	43,106.6	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	554.2	672.2	743.4	8,566.1	51,672.7
		D-6-2	(F4E)	43,102.7	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	742.8	672.2	55.9	8,067.2	51,169.9
		D-6-3	(F4F)	37,323.9	720.7	744.1	719.6	744.5	743.4	716.4	747.4	716.5	743.7	742.7	672.2	743.4	8,754.6	46,078.5
D系 最終沈殿池設備 (C2-C-E2)	汚泥掻寄機	D-1	(R1A)	43,752.2	720.7	744.1	719.6	744.5	743.4	720.5	747.4	716.5	743.7	744.2	672.2	742.6	8,759.4	52,511.6
		D-2	(R1B)	43,727.6	720.7	744.1	719.6	744.5	743.4	720.5	747.4	716.5	743.7	744.2	672.2	742.8	8,759.6	52,487.2
		D-3	(R2A)	43,730.6	720.7	744.1	719.6	744.5	743.4	720.5	747.4	716.5	743.7	744.2	672.2	742.8	8,759.6	52,490.2
		D-4	(R2B)	43,088.3	720.7	744.1	719.6	744.5	743.4	720.5	747.4	716.5	739.3	744.2	672.2	742.8	8,755.2	51,843.5
		D-5	(R2C)	43,086.3	720.7	744.1	719.6	744.5	743.4	720.5	747.4	716.5	738.3	744.2	672.2	742.8	8,754.2	51,840.5
		D-6	(R2D)	43,092.0	720.7	744.1	719.6	744.5	743.4	720.5	747.4	716.5	738.0	744.2	672.2	742.8	8,753.9	51,845.9
	返送汚泥ポンプ	D-1	(F3A)	29,938.2	720.6	25.3	643.6	744.5	45.8	720.5	747.4	693.0	691.1	744.2	75.2	647.8	6,499.0	36,437.2
		D-2	(F4A)	28,850.4	691.2	744.0	133.9	715.8	743.5	101.2	719.6	36.1	52.3	508.0	597.1	109.0	5,151.7	34,002.1
		D-3	(F5A)	28,719.0	29.5	718.9	717.5	39.9	714.8	720.4	70.0	716.5	743.3	243.3	672.2	742.8	6,129.1	34,848.1
		D-4	(R3A)	31,146.3	29.5	718.9	719.5	39.8	714.8	720.4	60.5	36.2	743.3	152.1	597.1	742.6	5,274.7	36,421.0
		D-5	(R4A)	27,539.2	720.6	25.3	641.5	744.5	45.8	676.0	747.4	716.5	691.1	744.1	75.2	647.9	6,475.9	34,015.1
		D-6	(R5A)	27,467.9	691.2	743.9	134.1	715.9	743.2	101.2	719.6	693.0	52.3	598.9	672.2	109.0	5,974.5	33,442.4
	余剰汚泥ポンプ	D-1	(F2E)	10,253.9	12.1	233.0	19.5	221.6	9.7	245.3	10.5	172.1	15.8	223.8	30.0	215.9	1,409.3	11,663.2
		D-2	(F2F)	10,360.9	259.0	8.7	235.1	11.0	238.0	15.3	174.4	8.1	242.3	76.5	218.2	45.8	1,532.4	11,893.3
沈砂設備 (J-C-N1A) <設備更新>	床排水ポンプ	No. 1	(F3E)	1.2	0.0	0.1	0.0	0.1	0.0	0.0	0.1	0.0	0.1	0.1	0.1	0.0	0.6	1.8
		No. 2	(F3F)	5.4	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.0	0.4	5.8
		No. 3	(F3G)	2.1	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.5	2.6
	加圧水ポンプ	No. 1	(F2C)	199.2	0.6	23.3	2.0	24.0	0.6	21.9	0.8	23.5	1.3	19.7	2.3	22.2	142.2	341.4
		No. 2	(F2D)	219.9	22.2	0.8	22.0	1.0	24.3	1.4	25.0	0.9	23.1	4.2	19.9	2.3	147.1	367.0
	揚砂ポンプ	No. 2	(F3C)	55.9	3.9	4.2	4.5	6.3	5.4	3.3	7.5	3.9	3.6	4.2	3.6	2.7	53.1	109.0
No. 3		(F3D)	58.0	3.9	4.0	4.3	4.3	4.8	3.3	3.8	4.5	3.9	3.9	3.2	2.4	46.3	104.3	

区分	機器名称	機器番号		24年度末	25年4月	5月	6月	7月	8月	9月	10月	11月	12月	26年1月	2月	3月	年計	累計
A系エアタン設備	反応槽攪拌装置	4-1	(F2F)	2,952.1	720.0	744.0	719.4	744.0	744.0	720.0	744.0	720.0	743.9	744.0	672.0	743.4	8,758.7	11,710.8
		4-2	(F2G)	2,952.1	720.0	744.0	719.4	744.0	744.0	720.0	744.0	720.0	743.9	744.0	672.0	743.4	8,758.7	11,710.8
		4-3	(F2H)	2,952.1	720.0	744.0	719.4	744.0	744.0	720.0	744.0	720.0	743.9	744.0	672.0	743.4	8,758.7	11,710.8
		5-1	(F2C)	2,952.1	720.0	744.0	719.4	744.0	744.0	720.0	744.0	720.0	743.9	744.0	672.0	743.4	8,758.7	11,710.8
		5-2	(F2D)	2,952.1	720.0	744.0	719.4	744.0	744.0	720.0	744.0	720.0	743.9	744.0	672.0	743.4	8,758.7	11,710.8
		5-3	(F2E)	2,952.1	720.0	744.0	719.4	744.0	744.0	720.0	744.0	720.0	743.9	744.0	672.0	743.4	8,758.7	11,710.8
		6-1	(R2D)	2,951.6	720.0	744.0	719.4	744.0	744.0	720.0	744.0	720.0	743.9	744.0	672.0	743.4	8,758.7	11,710.3
		6-2	(R2E)	2,951.6	720.0	744.0	719.4	744.0	744.0	720.0	744.0	720.0	743.9	744.0	672.0	726.4	8,741.7	11,693.3
		6-3	(R2F)	2,951.6	720.0	744.0	719.4	744.0	744.0	720.0	744.0	720.0	743.9	744.0	672.0	743.4	8,758.7	11,710.3
	凝集剤注入ポンプ	A-1	(R1C)	1,272.9	45.5	140.5	108.3	77.1	147.9	0.3	0.1	69.1	24.2	264.8	300.1	374.5	1,552.4	2,825.3
		A-2	(R1D)	1,456.3	275.1	201.3	84.2	32.3	159.7	172.5	132.1	52.3	414.4	328.6	84.2	0.2	1,936.9	3,393.2