

# 4 機械関係

## (1) 機械設備稼動状況

浄化センター(その1)

(単位：時間)

設備	機器名	No	24年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	25年度計	25年度まで累計	
沈砂池設備	揚砂ポンプ	No.1-1	70.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.2	0.0	0.0	0.0	0.0	0.4	70.9
		No.1-2	82.1	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.4	82.5
	細目除塵機	No.1	1,007.6	0.4	0.3	0.0	0.1	0.2	0.4	0.1	0.5	0.5	0.3	0.2	0.6	3.6	1,011.2	
		No.1	936.3	1.1	0.9	0.7	1.1	0.5	0.9	2.3	1.5	1.0	0.8	0.9	1.4	13.1	949.4	
		No.2	951.8	0.9	0.8	0.7	1.2	0.5	0.9	2.4	1.5	1.0	0.8	0.9	1.4	13.0	964.8	
	し渣搬出コンベア	No.3	983.7	0.9	0.8	1.0	1.4	0.3	0.7	2.5	1.2	1.1	1.5	0.6	1.3	13.3	997.0	
		No.1	114,882.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	114,882.1	
		No.1	19.4	0.2	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.1	1.1	20.5	
	し渣・沈砂洗浄機	No.1	1,091.7	1.1	0.8	1.1	1.4	0.6	0.8	2.3	1.5	1.6	1.5	0.6	1.2	14.5	1,106.2	
沈砂搬出コンベア	No.1	174.0	0.9	0.6	0.9	1.3	0.2	0.6	2.4	1.6	1.3	0.5	0.7	1.3	12.3	186.3		
最初沈殿池	生污泥引抜ポンプ	No.1	9,365.2	135.2	1.8	123.4	2.5	139.5	6.7	1.8	1.8	105.1	0.4	111.9	11.4	641.5	10,006.7	
		No.2	9,096.2	1.9	140.3	10.9	138.1	2.9	122.3	129.5	119.8	26.6	141.4	13.1	130.4	977.2	10,073.4	
	床排水ポンプ	No.1	4,579.7	9.5	5.6	7.6	4.8	5.2	8.7	7.1	7.5	5.0	機器更新			61.0	4,640.7	
	床排水ポンプ	No.1	—	—	—	—	—	—	—	—	—	7.8	7.7	9.8	14.3	39.6	39.6	
	1系初沈污泥掻寄機	No.1-1	140,113.2	0.6	1.3	564.8	742.8	742.9	716.4	741.0	719.1	395.8	0.8	1.3	1.0	4,627.8	144,741.0	
		No.1-2	98,291.1	0.6	1.3	564.8	742.8	742.9	716.2	741.0	719.1	397.0	0.9	1.3	1.0	4,628.9	102,920.0	
	2系污泥掻寄機	No.2	45,075.2	718.1	741.0	156.6	0.5	19.7	1.1	0.7	1.2	348.4	735.4	669.0	742.4	4,134.1	49,209.3	
	3系污泥掻寄機	No.3	52,467.3	718.7	740.6	718.0	743.0	743.2	719.4	741.0	719.3	741.1	736.4	670.4	743.2	8,734.3	61,201.6	
	池排水ポンプ	No.1	55.3	0.0	0.0	1.4	0.0	0.0	0.0	0.0	0.0	1.5	0.0	0.0	0.1	3.0	58.3	
	初沈スカム排水ポンプ	No.1	3,379.4	46.6	0.9	49.9	1.2	50.6	2.4	44.7	1.4	34.5	0.1	34.8	3.2	270.3	3,649.7	
		No.2	3,751.5	1.0	46.7	3.6	55.1	0.4	36.0	0.6	34.8	8.4	38.2	3.2	38.2	266.2	4,017.7	
污泥処理設備	濃縮污泥掻寄機	No.1	79,159.8	717.1	742.0	718.0	740.9	741.7	718.3	739.8	717.0	742.7	742.3	669.7	742.7	8,732.2	87,892.0	
		No.2	33,305.1	717.4	742.2	718.2	741.1	741.9	718.2	740.3	717.3	742.8	742.8	670.2	743.0	8,735.4	42,040.5	
	脱水ろ液移送ポンプ	No.1	30,766.8	495.2	9.8	218.1	61.4	79.7	3.3	0.1	0.6	0.4	2.0	85.8	47.3	1,003.7	31,770.5	
		No.2	36,342.6	277.8	439.2	261.4	428.2	428.8	441.1	406.9	444.4	468.6	510.5	376.3	475.7	4,958.9	41,301.5	
	污泥貯留槽攪拌機	No.1	95,502.6	720.0	744.0	720.0	744.0	744.0	720.0	742.2	719.3	719.5	743.8	639.7	744.0	8,700.5	104,203.1	
	污泥供給ポンプ	No.1	1,600.1	1.8	3.8	79.8	2.4	122.1	10.4	136.0	9.6	51.3	3.1	0.0	2.4	422.7	2,022.8	
		No.2	1,147.7	2.2	140.6	32.4	90.6	3.8	5.2	12.5	205.3	6.1	1.4	0.0	96.8	596.9	1,744.6	
		No.3	10,448.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	47.5	47.5	10,496.3	
		No.4	9,904.0	183.4	38.4	91.7	121.2	97.9	178.9	58.3	3.9	124.2	201.0	197.5	81.0	1,377.4	11,281.4	
	濃縮污泥移送ポンプ	No.1	6,744.3	72.6	11.9	50.4	1.8	37.0	5.1	46.9	5.6	60.4	79.4	49.5	45.1	465.7	7,210.0	
		No.2	5,590.0	43.2	37.8	9.2	30.3	0.3	23.5	4.7	30.4	52.4	79.6	48.4	45.5	405.3	5,995.3	
	給水ポンプ	No.1	660.1	8.4	0.2	10.0	0.4	10.5	0.8	11.6	0.1	7.4	0.0	9.6	0.1	59.1	719.2	
		No.2	739.0	0.0	12.2	2.0	9.8	1.8	7.2	0.0	13.9	3.2	10.0	0.4	12.7	73.2	812.2	
	脱臭ファン	No.1	167,339.2	719.3	743.3	718.9	742.6	742.7	719.6	741.3	719.0	742.2	743.1	668.8	743.4	8,744.2	176,083.4	
	ろ布洗浄ポンプ	No.3	13,642.0	238.0	0.0	119.8	0.1	121.9	15.8	67.5	1.3	128.6	0.0	225.2	4.8	923.0	14,565.0	
		No.4	14,275.3	3.7	55.9	3.4	155.9	4.1	211.6	5.8	11.4	37.0	254.2	20.3	158.8	922.1	15,197.4	
	床排水ポンプ	No.1	3,914.7	28.6	2.1	19.9	0.6	42.7	4.5	79.0	4.5	71.2	1.5	52.1	4.2	310.9	4,225.6	
No.2		3,460.1	1.8	30.0	2.1	24.6	1.9	63.1	3.3	68.7	14.6	66.6	4.5	35.7	316.9	3,777.0		

浄化センター（その2）

（単位：時間）

設備	機器名	No	24年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	25年度計	25年度まで累計	
汚泥処理設備	空気圧縮機	No.1	1,794.8	58.5	62.3	66.0	66.8	67.3	57.0	54.9	50.5	51.0	60.4	58.4	78.5	731.6	2,526.4	
		No.2	2,104.5	59.4	63.2	67.8	67.7	71.3	58.7	55.2	50.6	50.7	62.6	60.2	79.9	747.3	2,851.8	
	溶解槽攪拌機	No.1	601.9	0.3	24.5	19.6	9.2	15.0	1.1	16.6	32.5	9.1	1.2	0.0	15.0	144.1	746.0	
		No.2	26,591.9	25.9	4.5	12.5	13.9	9.0	20.5	4.1	0.0	21.5	25.6	37.3	19.2	194.0	26,785.9	
	薬品定量供給機	No.1	100.5	0.1	4.4	3.1	2.6	4.0	0.5	4.8	6.1	1.6	0.1	0.0	3.4	30.7	131.2	
	薬品供給ポンプ	No.1	738.4	4.1	0.9	2.1	2.8	2.4	4.2	1.2	0.0	3.7	6.0	5.5	3.2	36.1	774.5	
		No.1	1,674.9	1.8	3.9	80.2	2.5	122.7	15.3	136.5	4.5	30.8	3.1	0.0	2.4	403.7	2,078.6	
		No.2	1,090.0	2.3	141.8	32.6	90.9	3.8	0.5	12.6	211.2	26.8	1.4	0.0	97.3	621.2	1,711.2	
		No.3	9,920.5	131.7	0.0	90.1	5.2	85.5	0.1	52.2	0.4	98.1	0.1	180.9	3.7	648.0	10,568.5	
	脱水機	No.1	10,485.3	51.8	38.4	1.5	116.3	12.3	178.8	6.1	3.5	26.1	200.9	16.6	124.6	776.9	11,262.2	
No.2		2,747.8	4.0	144.4	112.2	93.0	125.9	15.6	148.5	214.9	57.4	4.5	0.0	99.2	1,019.6	3,767.4		
送風	送風機	No.1-1	20,358.8	183.4	38.4	91.7	121.2	97.9	178.9	58.3	3.9	124.2	201.0	197.5	128.5	1,424.9	21,783.7	
		No.1-2	76,933.1	6.8	1.4	2.3	0.0	30.2	3.6	0.1	2.6	0.1	0.2	2.2	0.1	49.6	76,982.7	
		No.1-2	71,902.2	6.9	1.4	2.2	0.0	2.1	3.6	0.0	2.5	0.2	0.1	2.3	0.2	21.5	71,923.7	
		No.2-1	69,851.5	701.8	17.1	655.4	19.1	391.1	0.8	706.3	32.4	596.7	9.5	601.0	88.5	3,819.7	73,671.2	
エアタンク	水中攪拌機	No.2-2	12,972.6	11.1	723.6	60.9	724.7	348.4	714.0	28.7	683.4	144.1	729.8	66.4	655.5	4,890.6	17,863.2	
		No.1-1	32,644.8	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,760.0	41,404.8	
		No.1-2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
		No.2-1	35,063.7	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	8,760.0	43,823.7	
	散気装置	No.2-2	72.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	72.0	
		No.3-1	52,688.3	720.6	738.7	721.7	744.4	741.0	714.8	735.0	719.4	744.3	738.3	667.5	743.3	8,729.0	61,417.3	
	最終沈殿池	1系返送汚泥ポンプ	No.3-2	52,463.5	720.8	738.7	721.7	744.4	741.0	715.6	729.0	719.4	744.3	738.3	667.5	743.3	8,724.0	61,187.5
			No.1	19,230.1	708.9	9.7	658.8	11.5	727.9	35.3	725.3	11.7	597.0	0.4	610.4	57.8	4,154.7	23,384.8
		2系返送汚泥ポンプ	No.2	19,654.1	10.5	732.8	60.0	732.4	11.3	683.2	10.8	706.8	145.0	739.5	59.6	686.0	4,577.9	24,232.0
			No.1	26,276.1	709.1	9.6	658.7	11.4	727.8	32.7	725.0	11.7	597.0	0.2	605.9	57.8	4,146.9	30,423.0
余剰汚泥ポンプ		No.2	26,326.3	10.4	732.5	59.9	732.3	11.4	682.5	10.8	706.9	145.1	739.8	62.1	686.0	4,579.7	30,906.0	
		No.1	14,479.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	14,479.9	
		No.2	688.6	60.9	45.2	59.0	68.0	62.0	54.9	45.0	66.4	67.0	78.2	67.3	63.0	736.9	1,425.5	
1系終沈汚泥掻寄機		No.3	2,521.5	38.0	27.2	32.0	33.5	31.0	29.6	24.2	24.2	34.6	40.6	38.9	41.4	395.2	2,916.7	
		No.1-1	153,411.1	712.2	736.6	711.8	734.9	735.9	712.2	732.8	712.8	736.7	733.8	666.8	738.2	8,664.7	162,075.8	
2系終沈汚泥掻寄機		No.1-2	157,599.0	712.2	736.7	712.1	734.8	735.8	712.2	732.8	712.8	736.7	734.2	666.7	738.3	8,665.3	166,264.3	
		No.2	129,144.8	712.1	736.8	712.0	734.8	736.0	712.3	732.5	712.6	736.8	733.7	666.3	738.0	8,663.9	137,808.7	
3系終沈汚泥掻寄機		No.3	52,351.1	715.7	740.1	716.1	740.1	739.7	716.7	737.5	716.1	740.6	737.6	667.0	738.2	8,705.4	61,056.5	
A・T床排水ポンプ		No.1	1,969.6	15.9	12.9	13.3	5.1	11.2	15.6	18.3	17.4	19.6	21.8	15.9	20.3	187.3	2,156.9	
		No.1	2,076.3	0.7	0.2	1.3	0.1	5.2	8.2	4.7	0.3	1.5	0.1	4.7	0.3	27.3	2,103.6	
終沈床排水ポンプ		No.2	1,743.5	0.1	1.2	0.3	8.0	0.5	3.3	0.4	29.2	0.6	1.5	0.2	1.3	46.6	1,790.1	
		No.1	10,220.6	49.6	0.7	59.0	1.0	73.1	3.5	68.3	0.9	48.3	0.1	40.6	3.3	348.4	10,569.0	
終沈スカム排水ポンプ	No.2	8,699.4	0.7	50.8	5.4	61.5	0.8	60.0	0.9	55.0	11.3	53.6	4.5	39.6	344.1	9,043.5		
	No.1	64.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	64.7		

浄化センター（その3）

（単位：時間）

設備	機器名	No	24年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	25年度計	25年度まで累計	
用水設備	原水ポンプ	No.1	35,689.4	4.4	0.1	3.8	0.0	48.2	0.1	3.8	0.1	42.6	0.1	3.2	0.5	106.9	35,796.3	
		No.2	32,251.2	0.2	3.7	0.3	42.5	6.4	4.8	0.1	72.4	6.4	4.2	1.1	2.5	144.6	32,395.8	
		No.3	1,671.7	233.4	112.1	153.9	159.0	159.4	230.7	129.5	32.6	178.8	288.5	284.4	246.5	2,208.8	3,880.5	
	消泡水ポンプ	No.1	1,860.2	14.8	0.5	6.6	0.0	2.3	0.0	10.9	0.0	6.5	0.0	0.3	0.5	42.4	1,902.6	
		No.2	1,599.5	0.1	14.7	2.0	6.6	0.1	4.0	0.0	6.7	1.4	1.4	0.0	1.1	38.1	1,637.6	
	逆洗排水ポンプ	No.1	4,110.1	7.7	0.0	9.5	0.0	1.2	0.0	0.7	0.0	4.9	0.1	1.0	0.4	25.5	4,135.6	
		No.2	4,327.2	0.1	9.1	0.1	17.4	0.1	5.2	0.0	10.4	0.2	5.9	0.1	1.1	49.7	4,376.9	
	濾過水移送ポンプ	No.1	6,189.3	79.8	0.0	44.2	0.1	46.2	0.5	29.9	0.1	45.3	7.4	76.3	3.4	333.2	6,522.5	
		No.2	6,652.2	1.2	26.0	1.3	55.8	2.1	74.7	1.1	16.4	13.2	78.5	7.0	56.8	334.1	6,986.3	
	空気圧縮機	No.1	12,651.4	2.8	0.2	0.3	0.0	17.5	0.1	0.8	0.6	21.1	0.3	4.2	0.2	48.1	12,699.5	
		No.2	12,813.0	0.2	4.5	0.1	18.5	2.0	3.3	0.0	37.6	4.3	10.6	1.0	9.0	91.1	12,904.1	
	用水床排水ポンプ	No.1		4,998.6	38.7	0.6	26.2	0.6	32.6	1.5	29.2	45.4	3.2	機器更新			178.0	5,176.6
				—	—	—	—	—	—	—	—	—	30.2	0.1	37.1	3.2	70.6	70.6
		No.2	5,438.7	0.9	54.1	4.7	53.8	1.5	28.4	0.7	0.0	5.8	機器更新			149.9	5,588.6	
	ろ過器	No.2		—	—	—	—	—	—	—	—	—	0.6	41.6	5.9	50.7	98.8	98.8
			1,671.7	233.4	112.1	153.9	159.0	159.4	230.7	129.5	32.6	178.8	288.5	284.4	246.5	2,208.8	3,880.5	
次亜塩素酸ソーダ注入ポンプ	No.1	67,378.4	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.0	1.2	0.1	2.5	67,380.9		
	No.2	71,202.9	718.2	742.1	718.1	743.6	738.5	718.5	735.5	719.0	740.7	464.0	418.8	743.5	8,200.5	79,403.4		
	No.3	8,587.3	0.1	0.1	0.1	0.3	0.4	0.3	0.1	0.2	0.5	275.9	250.7	0.2	528.9	9,116.2		
機械濃縮設備	余剰汚泥貯留槽攪拌機	No.1	79,086.0	717.7	742.2	700.3	743.0	737.2	707.9	729.6	682.6	733.8	733.5	662.9	736.1	8,626.8	87,712.8	
	汚泥供給ポンプ	No.1	23,539.1	415.3	5.6	353.5	10.6	404.5	42.2	308.8	21.9	321.8	0.3	371.1	36.0	2,291.6	25,830.7	
		No.3	23,511.0	8.5	309.3	29.2	426.2	5.8	333.7	1.7	379.7	86.8	464.4	39.2	368.0	2,452.5	25,963.5	
	浮上濃縮機	No.1	47,048.4	423.8	315.1	382.7	436.8	410.3	376.0	310.4	401.6	408.6	464.7	410.2	403.9	4,744.1	51,792.5	
	凝集剤供給機	No.1	412.4	3.0	2.4	2.8	3.4	3.2	3.3	2.6	3.4	3.6	3.9	3.6	3.6	38.8	451.2	
		No.2	424.5	3.2	2.2	3.0	3.2	3.4	3.0	2.6	3.4	3.7	3.9	3.2	3.8	38.6	463.1	
	凝集剤注入ポンプ	No.1	23,715.1	418.0	5.8	355.9	10.8	406.9	42.6	310.4	22.0	323.9	0.3	373.6	36.3	2,306.5	26,021.6	
		No.2	23,655.4	8.6	312.1	29.4	428.6	5.9	336.1	1.7	381.8	87.5	467.0	39.4	370.7	2,468.8	26,124.2	
	濃縮汚泥貯留槽攪拌機	No.1	22,696.9	0.0	0.0	0.2	0.1	0.0	0.2	0.0	0.2	4.0	0.1	0.1	0.4	5.3	22,702.2	
	濃縮汚泥移送ポンプ	No.1	1,253.7	21.1	0.5	19.2	0.5	19.5	0.7	14.6	0.6	17.0	0.1	18.6	1.4	113.8	1,367.5	
		No.2	1,214.8	0.6	13.8	1.2	20.7	0.6	18.8	0.1	18.5	4.3	23.7	2.3	21.5	126.1	1,340.9	
	凝集剤溶解槽攪拌機	No.1	4,285.4	25.2	20.2	23.5	28.6	26.9	26.9	21.8	31.9	29.5	32.0	32.8	42.6	341.9	4,627.3	
		No.2	4,331.2	27.3	20.4	24.9	27.4	27.1	28.7	20.3	28.7	29.0	34.0	34.4	47.7	349.9	4,681.1	
	空気圧縮機	No.1	14,103.0	150.0	10.0	140.0	10.0	170.0	10.0	170.0	0.0	160.0	0.0	150.0	20.0	990.0	15,093.0	
		No.2	13,450.0	30.0	140.0	20.0	160.0	10.0	160.0	10.0	170.0	40.0	210.0	20.0	200.0	1,170.0	14,620.0	
	起泡水ポンプ	No.1	23,762.1	410.7	13.0	190.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	3.2	617.2	24,379.3	
		No.3	23,613.9	17.6	305.4	193.0	440.9	411.0	383.4	308.2	402.1	409.4	468.2	414.0	404.2	4,157.4	27,771.3	
	起泡助剤希釈槽攪拌機	No.1	291.3	1.3	0.1	1.4	1.3	2.6	2.6	1.3	2.6	2.9	2.5	2.6	2.7	23.9	315.2	
	起泡助剤注入ポンプ	No.1	133,875.4	410.7	12.9	347.4	19.0	398.4	28.9	303.6	28.8	323.6	0.3	365.6	44.2	2,283.4	136,158.8	
		No.3	23,526.0	17.6	305.5	35.7	421.9	12.6	354.9	4.4	373.3	85.8	467.8	48.4	363.7	2,491.6	26,017.6	
脱気槽攪拌機	No.1	47,690.4	430.4	320.6	385.3	443.1	413.2	385.5	309.9	404.3	412.7	470.5	416.2	409.9	4,801.6	52,492.0		
床排水ポンプ	No.1	682.8	10.8	0.1	1.5	0.1	1.7	0.2	1.5	0.1	8.8	0.0	2.8	0.2	27.8	710.6		
	No.2	715.1	0.1	1.4	0.1	2.0	0.1	1.6	0.1	1.8	0.5	2.0	0.6	1.8	12.1	727.2		

中継ポンプ場（その1）

（単位：時間）

設備	機器名	No	24年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	25年度計	25年度まで累計
獅子崎	細目除塵機	No.1		57.2	24.8	30.0	93.0	93.0	16.8	8.1	10.0	10.3	10.3	9.3	10.3	373.1	
	破砕機	No.1		133.3	57.8	69.9	216.7	216.7	39.1	18.9	23.3	24.0	24.0	21.7	24.0	869.4	
	汚水ポンプ	No.1	55,596.6	3.2	0.1	81.2	786.5	29.3	5.2	2.9	0.0	0.4	0.1	0.1	0.5	909.5	56,506.1
		No.2	54,594.5	4.9	1.8	75.8	786.7	29.2	42.1	2.3	0.0	0.0	0.1	2.7	0.4	946.0	55,540.5
		No.3	5,291.3	0.0	0.0	0.0	0.2	0.4	0.5	0.1	0.0	0.0	0.0	0.0	0.1	1.3	5,292.6
		No.4	38,342.5	730.4	759.6	592.1	0.0	684.7	732.2	713.2	713.3	742.4	759.7	665.9	742.2	7,835.7	46,178.2
		No.5	将来設備														
	水中ミキサー	No.1	72,778.0	740.9	765.2	676.3	787.6	719.7	742.3	723.0	715.6	746.2	764.9	671.7	312.0	8,365.4	81,143.4
		No.2	116,159.7	49.4	234.8	676.3	787.6	719.7	743.0	720.5	715.6	746.2	764.9	671.7	431.6	7,261.3	123,421.0
	脱臭ファン	No.1	67,226.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	744.0	8,760.0
鶴賀	細目除塵機	No.1		25.8	22.6	2.9	3.1	2.6	2.5	2.6	2.5	2.6	1.2	5.0	10.3	83.7	
	破砕機	No.1		60.1	52.7	6.8	7.2	6.1	5.8	6.1	5.8	6.1	2.8	11.7	24.0	195.2	
	汚水ポンプ	No.1	64,718.1	62.0	0.0	46.1	2.1	27.1	0.0	40.5	3.1	39.8	0.0	9.4	39.3	269.4	64,987.5
		No.2	65,094.6	0.0	62.9	0.0	56.3	0.1	86.2	2.0	44.5	2.9	43.5	33.2	6.5	338.1	65,432.7
		No.3	3,688.9	2.0	2.9	2.3	2.5	2.5	2.0	1.6	2.7	2.5	2.4	0.2	2.1	25.7	3,714.6
		No.4	33,348.4	677.0	692.0	623.5	720.8	682.5	690.2	667.3	665.3	694.2	712.0	623.5	691.2	8,139.5	41,487.9
		No.5	将来設備														
	水中ミキサー	No.1	143,645.7	744.9	766.3	675.8	786.4	719.1	126.0	455.1	719.3	744.8	765.7	621.9	743.3	7,868.6	151,514.3
No.2		42,273.9	745.1	766.5	676.4	787.7	719.1	743.6	720.3	719.4	745.1	765.8	629.5	743.3	8,761.8	51,035.7	
脱臭ファン	No.1		720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	672.0	744.0	744.0	8,760.0	
須津	破砕機	No.1-1	103,348.7	692.5	699.4	628.6	729.0	700.9	690.5	677.9	659.9	683.2	711.4	629.3	678.8	8,181.4	111,530.1
		No.1-2	103,388.5	692.5	699.4	628.6	728.9	700.9	690.5	678.0	659.9	684.1	711.5	629.3	679.3	8,182.9	111,571.4
	汚水ポンプ	No.1	55,806.3	688.0	0.2	621.5	0.8	594.4	37.1	699.9	4.0	616.6	4.9	626.8	6.6	3,900.8	59,707.1
		No.2	53,027.3	2.2	694.1	5.6	727.5	107.4	626.2	10.3	652.7	66.1	705.7	0.3	670.4	4,268.5	57,295.8
		No.3	将来設備														
		No.4	191.0	2.8	4.8	1.4	1.8	1.5	31.4	38.3	3.2	1.3	1.3	2.2	2.2	92.2	283.2
	水中ミキサー	No.1	135,874.1	743.5	769.0	671.9	791.1	719.9	743.4	720.3	719.1	742.8	502.1	0.0		7,123.1	142,997.2
			—	—	—	—	—	—	—	—	—	—	—	機器更新	452.3	452.3	452.3
		No.2	67,768.6	743.5	740.5	671.9	791.4	720.0	743.4	720.3	719.1	742.8	767.4	675.8	283.7	8,319.8	76,088.4
		—	—	—	—	—	—	—	—	—	—	—	—	機器更新	452.3	452.3	452.3
	脱臭ファン	No.1	95,207.7	742.7	768.2	671.3	790.2	714.9	742.9	719.6	718.6	741.1	766.6	670.2	739.3	8,785.6	103,993.3
	床排水ポンプ	No.1	28.7	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	28.8
		No.2	16.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	16.4
シール水ポンプ	No.1	22,101.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	22,101.0	
	No.2	15,866.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	15,866.1	

中継ポンプ場（その2）

（単位：時間）

設備	機器名	No	24年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	25年度計	25年度まで累計
堂谷	破 碎 機	No.1-1	83,180.8	582.1	595.9	534.0	630.4	589.8	608.9	591.9	580.9	562.7	640.9	553.4	608.7	7,079.6	90,260.4
		No.1-2	83,180.8	582.1	595.9	534.0	630.4	589.8	608.9	591.9	580.9	562.7	640.9	553.4	608.7	7,079.6	90,260.4
	汚 水 ポ ン プ	No.1	41,295.0	582.1	58.1	534.0	72.9	589.8	96.7	591.9	81.6	562.7	95.7	553.4	78.9	3,897.8	45,192.8
		No.2	45,847.8	49.4	595.9	53.4	630.4	95.1	608.9	87.4	580.9	138.5	640.9	73.1	608.7	4,162.6	50,010.4
		No.3	将来設備														
		No.4	110.7	6.9	8.8	4.1	4.1	3.9	26.0	4.0	9.5	1.1	0.0	0.2	2.5	71.1	181.8
		No.5	将来設備														
	水 中 ミ キ サ ー	No.1	130,741.9	742.7	768.1	671.1	791.1	719.4	742.3	719.7	719.0	718.6	765.9	674.8	739.7	8,772.4	139,514.3
		No.2	47,444.7	742.7	768.1	671.0	791.1	719.4	742.3	719.7	719.0	722.0	767.4	674.8	739.7	8,777.2	56,221.9
	脱 臭 フ ァ ン	No.1	41,671.2	186.1	169.2	144.9	172.1	153.2	157.9	153.8	156.8	161.9	168.1	145.6	160.4	1,930.0	43,601.2
	床 排 水 ポ ン プ	No.1	4.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4.1
		No.2	3.4	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	3.5
	シ ー ル 水 ポ ン プ	No.1	12,108.3	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	12,108.5
		No.2	12,579.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	12,579.7
四辻	破 碎 機	No.1-1	72,533.8	575.2	623.3	481.8	645.1	573.8	593.8	589.8	578.8	508.7	647.6	511.9	610.0	6,939.8	79,473.6
		No.1-2	69,398.4	575.2	623.3	481.8	645.1	573.8	593.8	589.8	578.8	508.7	647.6	511.9	610.0	6,939.8	76,338.2
	汚 水 ポ ン プ	No.1	40,640.6	575.2	84.3	481.8	78.5	573.8	74.8	589.8	61.2	508.7	88.1	511.9	67.2	3,695.3	44,335.9
		No.2	42,798.3	58.3	623.3	22.1	645.1	68.1	593.8	95.5	578.8	80.5	647.6	31.7	610.0	4,054.8	46,853.1
		No.3	33.0	3.5	5.2	3.4	3.2	3.3	3.6	4.0	7.0	3.3	2.7	3.3	3.3	45.8	78.8
		No.4	将来設備														
	水 中 ミ キ サ ー	No.1	137,314.3	741.5	768.9	671.9	791.9	719.9	742.7	697.5	722.4	740.5	768.2	675.8	740.2	8,781.4	146,095.7
		No.2	7,197.8	741.5	768.9	671.9	791.9	719.9	728.5	714.3	722.4	740.5	768.2	675.8	740.2	8,784.0	15,981.8
	脱 臭 フ ァ ン	No.1	37,297.5	180.8	162.4	139.9	164.7	150.1	154.5	150.7	151.5	154.8	161.6	142.1	155.5	1,868.6	39,166.1
	床 排 水 ポ ン プ	No.1	2.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	3.0
		No.2	4.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.0	0.2	4.7
	シ ー ル 水 ポ ン プ	No.1	10,758.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	10,758.4
		No.2	11,718.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	11,718.9