

## 4 機械関係

### (1) 機械設備稼動状況

#### 浄化センター(その1)

(単位：時間)

設備	機器名	No	30年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	元年度計	元年度まで累計
沈砂池設備	揚砂ポンプ	No.1-1	102.4	0.7	0.1	0.2	0.5	0.6	0.7	0.2	0.2	4.3	0.3	0.3	0.4	8.5	110.9
		No.1-2	102.1	0.5	0.2	0.1	0.4	0.4	1.0	1.2	0.6	2.7	0.2	0.6	0.2	8.1	110.2
	細目除塵機	No.1	1,093.1	3.1	3.1	3.0	3.5	3.4	1.2	0.0	0.0	0.0	0.0	0.0	0.0	17.3	1,110.4
	し渣搬出コンベア	No.1	1,038.1	1.6	1.5	1.2	1.7	1.4	1.9	1.9	1.9	8.8	1.0	1.7	1.4	26.0	1,064.1
		No.2	1,055.1	1.7	1.5	1.2	1.7	1.4	1.9	1.9	2.0	8.9	1.0	1.7	1.4	26.3	1,081.4
		No.3	1,115.0	2.6	1.6	2.1	2.6	2.7	4.5	2.2	2.4	12.6	1.0	2.1	2.1	38.5	1,153.5
	着水井攪拌機(※)	No.1	137,317.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	137,317.9
	床排水ポンプ	No.1	27.9	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	1.4	0.1	0.1	0.1	2.6	30.5
し渣・沈砂洗浄機	No.1	1,248.1	3.2	1.6	2.1	2.5	2.5	4.4	2.2	2.2	14.1	1.2	1.6	2.0	39.6	1,287.7	
沈砂搬出コンベア	No.1	317.3	3.0	1.6	2.1	2.6	2.7	4.4	2.2	2.4	13.8	1.1	2.1	2.1	40.1	357.4	
最初沈殿池	生汚泥引抜ポンプ	No.1	13,611.7	89.1	3.0	97.3	2.3	128.4	7.5	134.1	2.3	0.0	0.0	0.5	1.0	465.5	14,077.2
		No.2	13,574.8	1.3	94.1	11.0	129.4	1.7	130.4	2.3	120.1	97.9	83.1	76.4	58.9	806.6	14,381.4
	床排水ポンプ	No.1	672.5	200.8	13.2	9.0	7.5	6.9	3.5	4.6	3.7	5.6	6.5	10.0	9.5	280.8	953.3
	1系初沈汚泥掻寄機	No.1-1	174,530.0	352.9	567.1	717.9	741.9	385.8	482.9	743.4	719.0	382.1	578.1	559.0	243.2	6,473.3	181,003.3
		No.1-2	132,955.4	352.9	567.1	718.0	742.0	385.8	482.9	743.4	719.0	382.1	578.1	559.1	243.2	6,473.6	139,429.0
	2系汚泥掻寄機	No.2	76,889.5	353.4	567.2	718.0	742.0	391.7	486.4	743.4	719.0	386.2	164.0	142.6	243.9	5,657.8	82,547.3
	3系汚泥掻寄機	No.3	94,106.0	353.9	567.8	719.2	743.2	386.4	483.3	744.0	719.7	367.8	366.1	310.3	245.3	6,007.0	100,113.0
	池排水ポンプ	No.1	76.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.8	0.0	0.0	1.8	78.4
初沈スカム排水ポンプ	No.1	4,721.8	47.8	0.8	64.2	1.0	71.5	3.3	79.3	1.1	72.8	4.1	27.8	34.7	408.4	5,130.2	
	No.2	5,310.3	0.8	58.5	5.9	70.4	1.0	78.9	1.3	74.2	4.0	52.6	5.9	1.0	354.5	5,664.8	
汚泥処理設備	濃縮汚泥掻寄機	No.1	130,956.9	717.9	740.9	716.5	740.8	742.2	718.0	740.6	717.1	742.2	742.0	693.2	740.7	8,752.1	139,709.0
		No.2	83,368.9	717.8	738.7	717.3	740.9	741.9	718.6	739.9	718.3	742.8	742.3	693.5	741.2	8,753.2	92,122.1
	脱水ろ液移送ポンプ	No.1	51,353.0	460.2	433.4	381.0	459.9	554.3	539.3	498.4	303.0	371.5	309.3	386.2	502.3	5,198.8	56,551.8
		No.2	58,073.2	465.2	466.1	361.6	504.2	423.5	536.1	443.0	462.4	134.5	319.5	144.8	464.1	4,725.0	62,798.2
	汚泥貯留槽攪拌機	No.1	125,385.1	350.4	372.8	350.4	355.6	359.0	333.2	370.8	342.6	369.2	359.9	346.8	348.6	4,259.3	129,644.4
	汚泥供給ポンプ	No.1	3,804.3	4.3	3.8	20.2	2.0	4.8	2.4	14.3	2.1	108.1	1.5	1.2	0.6	165.3	3,969.6
		No.2	3,537.6	12.3	11.7	23.8	18.1	0.1	7.0	1.3	51.4	13.7	44.0	3.1	13.5	200.0	3,737.6
		No.3	15,691.6	200.6	10.2	168.4	4.4	202.3	3.8	154.2	1.0	83.1	8.2	198.8	4.0	1,039.0	16,730.6
		No.4	15,149.4	7.9	204.5	0.1	172.0	3.8	169.9	4.1	126.6	0.0	157.4	14.8	211.0	1,072.1	16,221.5
	濃縮汚泥移送ポンプ	No.1	8,830.8	33.8	24.8	34.4	2.6	29.0	4.1	29.3	1.2	23.2	17.1	23.8	27.7	251.0	9,081.8
		No.2	7,407.6	29.9	28.5	5.2	40.4	1.0	29.4	1.7	23.9	5.6	21.9	8.5	35.6	231.6	7,639.2
	給水ポンプ	No.1	1,020.5	8.5	0.9	8.2	0.1	9.2	0.0	7.7	0.2	9.7	0.0	8.5	0.0	53.0	1,073.5
		No.2	1,108.5	0.4	8.6	1.0	8.2	0.0	8.4	0.1	8.4	1.0	9.3	0.4	9.4	55.2	1,163.7
	脱臭ファン	No.1	219,823.2	719.2	743.5	718.6	743.1	742.8	716.7	738.6	719.0	743.5	743.6	695.1	742.8	8,766.5	228,589.7
	ろ布洗浄ポンプ	No.3	20,599.4	251.8	11.1	224.7	4.7	259.9	6.4	191.0	0.1	111.0	4.8	244.5	6.9	1,316.9	21,916.3
No.4		21,797.1	9.7	256.5	0.6	235.2	4.2	219.2	9.9	166.6	0.9	205.7	18.4	261.6	1,388.5	23,185.6	
床排水ポンプ	No.1	1,444.6	174.6	20.5	51.8	17.7	115.9	7.9	115.3	7.6	64.3	6.9	17.5	99.7	699.7	2,144.3	
	No.2	1,385.1	22.7	95.4	4.8	75.1	17.7	77.6	18.2	69.2	24.1	28.5	1.8	319.1	754.2	2,139.3	

浄化センター（その2）

（単位：時間）

設備	機器名	No	30年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	元年度計	元年度まで累計
汚泥処理設備	空気圧縮機	No.1	5,778.7	66.6	68.4	73.2	80.9	95.8	64.4	0.1	0.1	0.0	0.1	29.8	76.8	556.2	6,334.9
		No.2	7,958.2	65.9	67.9	67.5	71.3	58.2	80.7	137.1	124.9	129.6	129.4	92.8	69.8	1,095.1	9,053.3
	溶解槽攪拌機	No.1	1,163.1	1.0	3.3	3.7	0.9	1.3	0.8	2.0	5.7	10.7	9.2	1.0	1.7	41.3	1,204.4
		No.2	27,367.0	25.4	20.6	18.4	12.9	17.3	11.6	10.9	8.8	8.2	17.2	17.0	21.0	189.3	27,556.3
	薬品定量供給機	No.1	231.8	0.4	0.6	0.7	0.4	0.2	0.3	0.4	1.5	2.8	1.0	0.1	0.3	8.7	240.5
	薬品供給機	No.1	974.0	4.2	4.2	3.7	3.2	4.2	4.1	3.3	2.3	1.3	3.1	4.7	4.0	42.3	1,016.3
	薬品供給ポンプ	No.1	3,878.7	16.2	14.3	41.3	0.0	3.2	2.4	14.3	2.2	108.5	1.6	1.3	13.6	218.9	4,097.6
		No.2	3,500.9	0.5	1.4	2.8	20.3	1.8	7.0	1.3	51.6	13.7	44.2	3.1	0.5	148.2	3,649.1
		No.3	15,191.1	200.6	8.3	147.6	3.8	202.7	3.8	150.4	0.1	83.1	8.0	195.1	3.0	1,006.5	16,197.6
		No.4	15,704.8	7.8	206.5	20.9	172.9	3.5	170.0	7.9	127.5	0.0	157.7	18.6	212.0	1,105.3	16,810.1
脱水機	No.1	7,341.9	16.6	15.5	44.0	20.1	4.9	9.4	15.6	53.5	121.8	45.5	4.3	14.1	365.3	7,707.2	
	No.2	30,847.0	208.5	214.7	168.5	176.4	206.1	173.7	158.3	127.6	83.1	165.6	213.6	215.0	2,111.1	32,958.1	
送風	送風機	No.1-1	77,321.4	5.4	0.1	0.1	0.1	128.5	0.1	0.2	0.2	0.1	0.3	0.1	0.3	135.5	77,456.9
		No.1-2	72,064.9	5.4	0.1	0.1	0.1	4.2	0.1	0.2	0.2	0.1	0.3	0.1	0.3	11.2	72,076.1
		No.2-1	97,618.7	709.5	91.4	9.0	482.0	239.3	683.5	691.0	699.9	717.8	416.3	541.7	738.5	6,019.9	103,638.6
		No.2-2	37,429.2	1.0	642.1	700.2	255.4	504.5	29.7	49.4	18.7	20.6	321.9	150.2	0.5	2,694.2	40,123.4
エアタンク	水中攪拌機	No.1-1	79,425.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	633.0	633.0	80,058.6
		No.1-2	5,388.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	696.0	111.0	8,151.0	13,539.0
		No.2-1	87,647.7	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	696.0	744.0	8,784.0	96,431.7
		No.2-2	72.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	72.0
	散気装置	No.3-1	105,072.4	714.1	735.5	715.9	735.5	740.0	713.3	741.1	719.0	739.0	738.0	661.0	731.1	8,683.5	113,755.9
		No.3-2	104,849.9	714.2	735.5	715.9	735.5	740.0	713.3	741.1	719.0	739.0	738.0	691.0	735.1	8,717.6	113,567.5
最終沈殿池	1系返送汚泥ポンプ	No.1	45,220.3	706.7	10.7	651.4	10.8	734.1	33.3	730.5	10.0	704.5	34.7	630.7	37.5	4,294.9	49,515.2
		No.2	46,053.4	10.3	723.0	59.6	726.8	9.8	679.8	10.3	707.0	33.8	703.3	62.9	702.1	4,428.7	50,482.1
	2系返送汚泥ポンプ	No.1	52,261.8	701.3	10.7	651.2	10.9	733.9	33.3	730.3	10.0	704.6	34.8	606.0	37.4	4,264.4	56,526.2
		No.2	52,709.1	10.4	723.0	59.7	726.8	9.9	679.8	10.5	677.3	33.8	703.1	87.4	702.1	4,423.8	57,132.9
	余剰汚泥ポンプ	No.1	18,032.3	63.8	58.7	57.5	58.3	66.3	61.0	38.7	60.5	73.4	71.2	63.0	78.0	750.4	18,782.7
		No.2	1,595.8	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.4	0.1	2.5	1,598.3
		No.3	5,061.4	43.2	37.6	24.9	37.3	39.6	39.9	38.3	35.8	31.8	44.5	45.3	42.2	460.4	5,521.8
	1系終沈汚泥掻寄機	No.1-1	204,937.1	714.8	739.0	714.6	735.2	738.3	714.9	738.5	713.0	738.8	738.0	689.5	737.6	8,712.2	213,649.3
		No.1-2	208,873.2	714.8	739.0	714.6	735.4	738.3	715.0	738.5	713.1	739.0	738.0	689.3	737.6	8,712.6	217,585.8
	2系終沈汚泥掻寄機	No.2	181,168.8	714.7	738.9	714.4	735.7	738.2	715.1	738.4	712.9	738.7	737.8	688.6	737.4	8,710.8	189,879.6
	3系終沈汚泥掻寄機	No.3	104,551.0	716.5	740.9	716.7	740.4	740.9	717.1	740.9	715.6	740.6	740.6	691.7	739.7	8,741.6	113,292.6
	A・T床排水ポンプ	No.1	2,862.2	1.2	1.0	0.6	0.8	0.8	1.2	1.6	2.4	1.3	1.6	1.3	0.8	14.6	2,876.8
	終沈床排水ポンプ	No.1	2,239.1	12.5	0.3	10.0	0.5	11.8	0.7	10.8	1.6	13.0	0.6	1.0	0.2	63.0	2,302.1
		No.2	1,989.6	2.3	11.4	0.9	10.4	0.4	8.8	0.4	11.0	0.7	7.4	0.2	1.2	55.1	2,044.7
	終沈スカム排水ポンプ	No.1	12,543.3	116.3	1.6	95.8	1.2	169.8	8.4	163.0	2.2	157.8	8.5	102.7	7.1	834.4	13,377.7
		No.2	10,772.0	1.2	74.2	5.5	95.2	1.4	101.6	1.4	97.0	4.5	106.8	10.2	97.2	596.2	11,368.2
池排水ポンプ	No.1	72.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	72.4	

浄化センター（その3）

（単位：時間）

設備	機器名	No	30年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	元年度計	元年度まで累計
用水設備	原水ポンプ	No.1	36,381.4	3.8	0.1	2.8	0.1	4.3	0.1	2.9	0.2	2.9	0.4	4.8	0.3	22.7	36,404.1
		No.2	32,928.4	2.1	2.9	0.5	4.3	0.1	79.9	0.0	3.9	0.2	5.5	0.4	3.7	103.5	33,031.9
		No.3	19,025.0	393.5	409.0	336.9	373.8	449.3	328.2	392.4	317.6	254.4	351.2	442.5	358.9	4,407.7	23,432.7
	消泡水ポンプ	No.1	2,241.6	22.6	0.0	53.6	0.0	20.6	0.0	25.7	0.0	27.4	0.1	12.9	0.0	162.9	2,404.5
		No.2	1,943.2	0.2	34.4	1.1	20.6	0.1	29.5	0.0	20.6	0.2	16.7	0.0	24.2	147.6	2,090.8
	逆洗排水ポンプ	No.1	4,522.7	8.7	0.0	8.2	0.0	4.1	0.0	4.3	0.0	4.6	0.1	17.3	0.1	47.4	4,570.1
		No.2	4,799.3	0.1	4.4	0.0	4.3	0.2	103.4	0.0	4.6	0.1	14.1	0.0	4.4	135.6	4,934.9
	濾過水移送ポンプ	No.1	8,582.9	92.7	1.5	77.5	2.5	93.9	2.5	74.2	10.3	49.5	2.5	86.4	4.4	497.9	9,080.8
		No.2	9,114.8	2.0	101.3	2.2	92.5	3.1	86.8	1.7	57.4	1.7	80.0	7.4	95.0	531.1	9,645.9
	空気圧縮機	No.1	13,150.2	1.9	0.1	1.5	0.0	4.2	0.0	2.0	0.1	4.3	0.4	7.6	0.6	22.7	13,172.9
		No.2	13,643.1	0.1	4.4	0.3	5.7	0.1	37.0	0.1	9.0	0.4	10.3	1.2	11.5	80.1	13,723.2
	用水床排水ポンプ	No.1	1,073.8	65.0	1.2	38.1	0.5	75.6	3.4	61.8	45.3	52.0	2.5	40.5	2.3	388.2	1,462.0
		No.2	1,225.3	1.4	64.7	5.3	31.6	1.9	67.5	1.0	17.2	0.2	50.1	4.4	55.0	300.3	1,525.6
	ろ過器	No.2	19,025.0	393.5	409.0	336.9	373.8	449.3	328.2	392.4	317.6	254.4	351.2	442.5	358.9	4,407.7	23,432.7
	次亜塩素酸ソーダ注入ポンプ	No.1	100,846.9	715.9	732.4	708.7	737.7	743.5	691.9	740.8	718.9	738.8	738.3	692.0	739.2	8,698.1	109,545.0
No.2		88,407.1	0.3	0.3	0.2	0.2	0.1	21.6	0.1	0.2	0.2	0.2	0.1	0.2	23.7	88,430.8	
No.3		10,255.8	0.2	0.5	0.2	0.2	0.4	0.2	0.1	0.1	0.1	0.3	0.1	0.2	2.6	10,258.4	
機械濃縮設備	余剰汚泥貯留槽攪拌機	No.1	1,061.0	717.0	744.0	720.0	743.5	743.7	712.0	744.0	711.6	742.7	743.9	695.2	741.2	8,758.8	9,819.8
	汚泥供給ポンプ	No.1	37,361.6	424.1	30.2	309.8	9.9	424.8	25.1	307.7	8.8	365.8	25.9	363.5	245.6	2,541.2	39,902.8
		No.3	37,681.5	13.4	364.4	34.4	399.7	10.5	402.4	10.1	354.4	21.8	405.5	52.1	200.1	2,268.8	39,950.3
	浮上濃縮機	No.1	75,040.4	437.5	394.5	344.2	409.5	435.2	427.5	317.8	363.3	387.5	431.2	415.7	445.9	4,809.8	79,850.2
	凝集剤供給機	No.1	789.5	5.8	5.4	4.6	6.0	4.1	6.2	4.5	5.3	5.5	6.0	6.5	6.7	66.6	856.1
		No.2	805.8	6.3	5.4	4.8	5.7	9.7	6.1	4.8	5.1	5.7	6.3	6.3	7.0	73.2	879.0
	凝集剤注入ポンプ	No.1	37,651.9	427.6	30.3	310.2	9.9	425.5	25.2	308.1	8.9	368.5	26.0	377.1	17.4	2,334.7	39,986.6
		No.2	37,850.3	11.1	365.5	34.4	400.5	10.5	403.5	10.2	355.0	21.4	406.9	39.4	429.8	2,488.2	40,338.5
	濃縮汚泥貯留槽攪拌機	No.1	23,045.4	5.6	17.1	3.8	4.4	13.3	8.6	0.0	2.3	10.6	7.1	3.3	6.2	82.3	23,127.7
	濃縮汚泥移送ポンプ	No.1	1,961.9	8.4	8.7	7.9	8.2	9.8	10.8	6.1	7.2	8.8	9.7	9.2	9.4	104.2	2,066.1
		No.2	1,909.4	11.5	9.5	8.2	8.5	10.5	10.1	7.3	7.8	8.1	9.8	8.1	9.5	108.9	2,018.3
	凝集剤溶解槽攪拌機	No.1	6,211.1	25.4	22.9	20.3	25.2	18.0	26.7	19.1	22.9	23.1	26.2	26.7	29.2	285.7	6,496.8
		No.2	6,248.5	25.1	23.3	20.6	24.0	42.7	26.4	20.2	21.3	23.8	26.3	26.3	29.1	309.1	6,557.6
	空気圧縮機	No.1	20,873.0	230.0	10.0	200.0	10.0	240.0	10.0	220.0	10.0	210.0	20.0	200.0	10.0	1,370.0	22,243.0
		No.2	22,590.0	10.0	290.0	30.0	380.0	10.0	290.0	10.0	280.0	20.0	310.0	40.0	360.0	2,030.0	24,620.0
	起泡用水ポンプ	No.1	36,424.3	419.4	37.8	307.2	12.6	418.5	32.3	303.7	13.0	360.3	33.2	365.0	29.0	2,332.0	38,756.3
		No.3	39,028.1	17.7	359.6	39.7	396.2	14.5	397.0	16.3	351.8	24.6	398.1	47.3	421.8	2,484.6	41,512.7
	起泡助剤希釈槽攪拌機	No.1	430.0	1.3	1.3	1.3	1.2	1.2	1.3	1.3	1.3	1.3	2.3	1.2	1.4	16.4	446.4
	起泡助剤注入ポンプ	No.1	37,763.4	419.4	37.8	307.2	12.6	418.5	46.3	303.7	13.0	360.3	33.1	365.0	29.0	2,345.9	40,109.3
		No.3	37,734.7	17.9	359.6	39.7	396.2	14.5	383.5	16.3	351.8	24.6	398.2	47.3	422.7	2,472.3	40,207.0
脱気槽攪拌機	No.1	76,190.4	439.0	399.0	348.5	410.5	434.8	430.9	321.6	366.3	386.6	432.9	413.6	452.1	4,835.8	81,026.2	
床排水ポンプ	No.1	801.1	2.0	0.1	1.7	0.0	19.3	0.2	1.7	0.1	11.8	0.1	1.6	0.2	38.8	839.9	
	No.2	827.9	0.2	2.0	0.1	2.0	0.1	1.9	0.1	1.9	0.1	2.5	0.2	2.4	13.5	841.4	

中継ポンプ場（その1）

（単位：時間）

設備	機 器 名	No	30年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	元年度計	元年度まで累計	
獅子崎	細目除塵機	No.1		15.0	15.5	15.0	15.5	15.5	15.0	15.5	15.0	15.5	15.5	14.5	15.5	183.0		
	破砕機	No.1		35.0	36.1	35.0	36.1	36.1	35.0	36.1	35.0	36.1	36.1	33.8	36.1	426.5		
	汚水ポンプ	No.1	56,638.1	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.0	0.2	0.2	7.0	0.1	0.7	8.7	56,646.8
		No.2	55,715.5	5.5	0.0	0.0	0.1	0.0	0.1	0.0	0.0	4.0	0.3	0.1	0.1	0.7	10.9	55,726.4
		No.3	5,298.0	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.0	0.9	5,298.9
		No.4	89,647.8	757.6	731.8	668.2	777.3	723.7	732.3	715.6	714.5	737.8	749.4	667.4	737.1	8,712.7	98,360.5	
		No.5	将来設備	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	水中ミキサー	No.1	122,143.5	768.2	743.8	676.5	787.5	724.4	738.8	718.2	720.0	744.2	767.4	672.3	731.6	8,792.9	130,936.4	
No.2		166,521.4	768.2	743.8	676.4	787.5	724.4	738.6	718.2	720.0	741.9	767.4	672.3	738.2	8,796.9	175,318.3		
脱臭ファン	No.1	119,810.0	720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	696.0	744.0	8,784.0	128,594.0		
鶴賀	細目除塵機	No.1		20.1	20.8	20.1	20.8	20.8	20.1	20.8	24.9	25.7	25.7	24.1	25.7	269.6		
	破砕機	No.1		46.8	48.5	46.8	48.5	48.5	46.8	48.5	58.0	59.9	59.9	56.2	59.9	628.3		
	汚水ポンプ	No.1	68,235.3	19.7	0.1	12.1	3.2	12.4	0.1	10.1	1.6	8.0	0.1	14.3	14.3	96.0	68,331.3	
		No.2	68,714.2	0.7	16.5	1.6	19.0	3.3	21.1	0.0	6.6	0.1	6.8	0.1	10.1	85.9	68,800.1	
		No.3	5,688.7	1.8	1.3	1.5	1.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.5	5,695.2	
		No.4	79,454.9	740.8	708.8	647.5	758.8	702.0	717.8	705.6	706.4	726.9	751.1	653.4	724.4	8,543.5	87,998.4	
		No.5	将来設備	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	水中ミキサー	No.1	11,324.0	768.3	743.8	673.5	790.5	715.3	744.1	719.7	719.3	744.4	767.9	669.8	743.6	8,800.2	20,124.2	
No.2		10,739.1	768.3	743.8	673.5	790.5	719.7	744.1	719.7	719.3	744.4	767.9	667.9	743.6	8,802.7	19,541.8		
脱臭ファン	No.1		720.0	744.0	720.0	744.0	744.0	720.0	744.0	720.0	744.0	744.0	696.0	744.0	8,784.0			
須津	破砕機	No.1-1	151,250.3	727.5	698.0	640.8	743.4	686.7	674.7	679.3	664.6	700.5	713.3	641.2	684.2	8,254.2	159,504.5	
		No.1-2	152,102.0	727.5	698.0	640.8	743.5	686.7	674.7	679.4	664.6	700.5	713.3	641.2	684.2	8,254.4	160,356.4	
	汚水ポンプ	No.1	79,220.7	720.6	2.8	635.7	0.4	675.5	0.1	673.1	0.6	692.0	4.1	636.5	0.1	4,041.5	83,262.2	
		No.2	78,895.7	0.3	689.7	1.0	727.7	2.1	669.6	0.5	660.2	0.2	708.8	0.2	681.8	4,142.1	83,037.8	
		No.3	将来設備	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
		No.4	1,867.2	6.9	0.2	4.9	15.4	11.0	3.9	6.4	4.1	0.4	3.5	3.9	2.3	62.9	1,930.1	
	水中ミキサー	No.1	42,846.0	768.2	743.9	670.1	791.9	719.8	744.2	719.4	718.9	743.6	766.4	672.4	743.0	8,801.8	51,647.8	
		No.2	41,797.4	768.2	743.9	670.1	775.2	705.7	663.5	719.4	718.9	743.6	766.4	672.4	743.0	8,690.3	50,487.7	
	脱臭ファン	No.1	147,630.9	767.9	743.5	669.2	791.0	713.6	743.7	718.8	718.1	743.1	765.9	667.1	743.0	8,784.9	156,415.8	
	床排水ポンプ	No.1	33.1	0.1	0.0	0.0	0.1	0.1	0.0	0.1	0.0	0.1	0.0	0.1	0.0	0.6	33.7	
No.2		19.2	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.6	19.8		
シール水ポンプ	No.1	22,101.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	22,101.5		
	No.2	15,866.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	15,866.6		

中継ポンプ場（その2）

（単位：時間）

設備	機 器 名	No	30年度まで累計	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	元年度計	元年度まで累計	
堂谷	破砕機	No.1-1	126,266.8	623.5	595.7	531.3	631.4	571.4	543.0	310.0	300.0	310.0	310.0	290.0	310.0	5,326.3	131,593.1	
		No.1-2	126,366.8	623.5	595.7	531.3	631.4	571.4	543.0	310.0	300.0	310.0	310.0	290.0	310.0	5,326.3	131,693.1	
	汚水ポンプ	No.1	65,391.6	70.2	75.5	50.4	84.4	74.5	86.9	74.1	40.5	0.3	0.0	18.9	24.7	600.4	65,992.0	
		No.2	72,778.9	623.5	595.7	531.3	631.4	571.4	543.0	545.9	274.2	23.3	28.8	14.4	5.4	4,388.3	77,167.2	
		No.3	将来設備	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		No.4	437.1	0.1	0.1	0.0	3.7	0.4	8.1	11.0	267.0	511.9	536.3	472.3	519.7	2,330.6	2,767.7	
		No.5	将来設備	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	水中ミキサー	No.1	183,196.9	767.9	743.0	670.3	791.2	715.3	730.0	719.0	718.9	738.7	765.2	672.0	742.4	8,773.9	191,970.8	
		No.2	714.7	767.9	743.0	670.2	792.1	715.3	730.0	719.0	718.9	738.7	765.2	672.0	742.4	8,774.7	9,489.4	
	脱臭ファン	No.1	58,055.5	268.9	257.7	269.0	272.4	244.4	254.4	248.2	249.8	47.7	17.2	226.8	160.8	2,517.3	60,572.8	
	床排水ポンプ	No.1	7.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.2	7.2	
		No.2	12.0	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.0	0.1	0.1	0.1	0.0	0.5	12.5	
	シール水ポンプ	No.1	12,109.3	0.0	0.0	0.2	0.1	0.1	0.0	0.1	0.0	0.1	0.0	0.1	0.0	0.7	12,110.0	
		No.2	12,580.9	0.0	0.1	0.0	0.0	0.0	0.1	0.0	0.1	0.3	0.1	0.1	0.1	0.9	12,581.8	
四辻	破砕機	No.1-1	116,097.9	587.1	665.5	475.1	721.3	389.5	328.2	465.0	450.0	465.0	465.0	435.0	465.0	5,911.7	122,009.6	
		No.1-2	112,962.5	587.1	665.5	475.1	721.3	389.5	328.2	465.0	450.0	465.0	465.0	435.0	465.0	5,911.7	118,874.2	
	汚水ポンプ	No.1	67,824.6	587.1	97.5	475.1	132.6	389.5	3.3	4.2	4.0	4.8	2.7	5.2	7.9	1,713.9	69,538.5	
		No.2	68,603.8	24.5	665.5	1.9	721.3	14.5	3.3	4.0	4.0	4.7	2.7	4.7	8.2	1,459.3	70,063.1	
		No.3	282.3	3.4	3.3	2.9	2.8	119.2	328.2	348.5	322.7	344.8	341.3	323.6	334.1	2,474.8	2,757.1	
		No.4	将来設備	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	水中ミキサー	No.1	1,739,788.3	764.0	743.5	671.2	792.4	719.3	743.0	712.4	719.8	744.7	767.6	672.4	743.4	8,793.7	1,748,582.0	
		No.2	58,764.0	768.0	743.5	671.2	792.4	719.3	743.0	717.4	719.6	744.7	767.6	672.4	743.4	8,802.5	67,566.5	
	脱臭ファン	No.1	48,166.3	154.3	301.7	133.2	157.2	140.7	146.1	141.9	145.0	166.2	170.8	149.6	165.0	1,971.7	50,138.0	
	床排水ポンプ	No.1	3.9	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.3	4.2	
		No.2	5.9	0.1	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.4	6.3	
	シール水ポンプ	No.1	10,758.5	0.0	0.0	0.8	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0	10,759.5	
		No.2	11,719.2	0.0	0.7	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.9	11,720.1	